



TiXML Reference Manual

for Tixi Alarm Modem
 HM100/400
 HG100/400
 Tixi Data Gateway
 HW100/400
 HE100/400
 and Tixi.Gate 600 Series

V 3.2

© 2012 Tixi.Com GmbH, Berlin

Publication close: 29. June 2012. Supported Tixi Device Firmware: 3.2.0.52

This manual is protected by copyright. Any further sale is prohibited without the consent of the publisher. This applies in particular to copies, translations, microfilm copies and the storage and processing on electronic data-processing systems.

Various registered trademarks, company names and brand names appear in this manual. Even if they are not designated as such, the relevant proprietary rights still apply.

1	OVERVIEW	5
2	CONTROLLING A TIXI DEVICE	7
2.1	OVERVIEW	7
2.2	RS232 COMMUNICATION PARAMETERS	7
2.3	COMMUNICATION MODE	7
2.4	TIXML - CONTROL PROTOCOL (TIXML).....	7
2.4.1	Overview	7
2.4.2	Framing.....	8
2.4.3	Command Encoding.....	8
2.4.4	Error Frame.....	11
2.4.5	Error codes	14
2.4.6	Commands.....	15
2.4.6.1	Device control	15
2.4.6.2	Authentication	20
2.4.6.3	Event processing.....	23
2.4.6.4	Configuration	27
2.4.6.5	Process values	30
2.4.6.6	Logging	35
2.5	TIXML ON SD-CARD.....	39
3	MAIN XML DATABASES	41
3.1	INTRODUCTION.....	41
3.1.1	References	41
3.1.2	Time parameters	42
3.2	DIALLING PROPERTIES OF THE LOCATION	42
3.2.1	How the Modem dials	44
3.3	DEVICE'S USER DATA.....	46
3.4	ADDRESS BOOK.....	48
3.5	INTERNET ACCESS (ISP).....	50
3.6	ACCESS RIGHTS	52
3.7	EVENT HANDLER.....	54
3.7.1	Commands.....	55
3.7.2	Conditions	70
3.7.3	System events.....	71
3.8	MESSAGE TEXT TEMPLATE	72
3.9	MESSAGE JOB TEMPLATE	78
3.10	SMS PROVIDER.....	83
3.11	SERVICE CENTER FOR INCOMING SMS.....	84
3.12	AUTOMATIC TRANSMODE.....	85
3.13	INTERNET-TIME SYNCHRONIZATION.....	86
3.14	ETHERNET	88
3.15	WLAN	89
3.16	TIXML/IP	92
3.17	WEBSERVER, PPP-SERVER, TFTP-SERVER.....	93
4	DATA LOGGING.....	93
4.1	LOGDEFINITION	93
4.1.1	LogFiles Group.....	93
4.1.1.1	SupportLog.....	94
4.1.2	Records Group.....	94
4.2	EVENTLOGGING	97
4.3	LOGGING COMMANDS.....	98
4.4	LOGFILE MEMORY CALCULATION	100
4.5	READING AND CLEARING LOGFILES	100
4.6	SENDING AND FORMATTING LOG REPORTS	100
4.6.1	Predefined format tags.....	107
4.6.2	Sending logfiles as attachment.....	107
4.7	LOGFILE COUNTER	108

5	REMOTE CONTROL.....	109
5.1	OVERVIEW	109
5.2	REMOTE CONTROL OF THE TIXI DEVICE.....	109
5.3	REMOTE CONTROL OF AN ATTACHED DEVICE.....	110
6	PROCESS I/O PORTS AND VARIABLES	111
6.1	INTRODUCTION.....	111
6.2	EVENT STATES	112
6.3	PROCESS VARIABLES.....	113
6.3.1	<i>RPN Instruction List.....</i>	<i>116</i>
6.3.1.1	Logical instructions	117
6.3.1.2	Stack operations	125
6.3.1.3	Comparison instructions.....	128
6.3.1.4	Math operations.....	133
6.3.1.5	Time instruction	136
6.3.1.6	Power-on/off delay instruction.....	137
6.3.1.7	IF instructions.....	138
6.3.1.8	Text parser instruction.....	139
6.3.1.9	Bit mask instruction.....	140
6.3.1.10	FIND_BIT_ADDRESS instruction	141
6.3.1.11	FORTH instruction.....	143
6.3.2	<i>RPN Error Codes.....</i>	<i>143</i>
6.4	ACCESS I/Os AND VARIABLES.....	143
6.4.1	<i>Refer to variable values</i>	<i>143</i>
6.4.2	<i>Read variable values.....</i>	<i>144</i>
6.4.3	<i>Set outputs, Process- and PLC Variables</i>	<i>144</i>
6.5	VARIABLE DATA TYPES AND FORMATS	145
6.5.1	<i>Variable data types</i>	<i>145</i>
6.5.2	<i>Variable data formats</i>	<i>146</i>
6.6	ANALOG INPUT.....	151
6.7	S0-INTERFACE.....	153
6.8	SIGNAL LED	156
7	SCHEDULER.....	157
7.1	CONFIGURATION	157
7.2	TIME PARAMETERS	158
7.3	SCHEDULEDEFINITION	160
7.4	TESTING	161
8	SEQUENCER.....	163
8.1	CONFIGURATION	163
8.2	CHANGING SEQUENCES	164
8.2.1	<i>Profile priorities.....</i>	<i>166</i>
8.3	TESTING	167
8.4	EXAMPLE	168
9	PROCESSING INCOMING MESSAGES	169
9.1	INTRODUCTION.....	169
9.2	EVENT VIA INCOMING CALL (CALLERID).....	170
9.3	EVENT VIA INCOMING MESSAGE (EXPRESS-E-MAIL, SMS, EMAIL).....	170
9.3.1	<i>Event paramater generated by an incoming message.....</i>	<i>172</i>
9.3.2	<i>System events for invalid incoming messages.....</i>	<i>174</i>
9.3.3	<i>Receiving Express-E-Mail.....</i>	<i>179</i>
9.3.4	<i>Receiving SMS (GSM and PSTN)</i>	<i>179</i>
9.3.5	<i>Collecting Internet emails (POP3).....</i>	<i>179</i>
9.3.5.1	Email filter	180
9.3.6	<i>Example.....</i>	<i>180</i>
9.3.6.1	Event Handler.....	180
9.3.6.2	Message Job Templates for the answer messages	182
9.4	CONFIGURATION VIA EMAIL	183
9.5	AUTHENTICATION	184

10	TIXI DEVICE AND PLC / METER / FIELDBUS OPERATION.....	187
11	ADDRESSES OF SERIAL INTERFACES AND I/OS	188
11.1	BIT / BYTE / WORD / DWORD ADDRESSING OF I/OS	189
12	SYSTEM PROPERTIES.....	191
13	PROJECT STRUCTURE AND CONNECTIONS.....	197
13.1	EVENT HANDLER, SCHEDULER.....	197
13.2	EVENT STATES, EXTERNAL, PROCESS VARS, SYSTEM-IOS	198
13.3	MESSAGEJOBTEMPLATES, USERTEMPLATES, ADDRESSBOOK	198
13.4	LOGFILES, RECORDS, EVENTLOGGING	199
14	FIRMWARE	200
14.1	REMOTE FIRMWARE UPDATE	200
14.2	COMPATIBILITY.....	200
14.3	FEATURE HISTORY	201
INDEX	203

1 Overview

The **Tixi Alarm Modem / Tixi Data Gateway** provides you with a completely new type of communication device, which can be integrated into existing systems with ease.

The communication protocols of common PLCs are already implemented into the Tixi Device, so there's no need to change the PLC or its programming. Other PLCs can control the Tixi Device via simple text strings: the **TiXML Commands**.

Imagine this as a simple application of Tixi Alarm Modem:




The purpose of this manual is a reference for the features and functions of the Tixi Device. A step-by-step guide for creating projects can be found in the "TiXML-Tutorial" which is available on our website <http://www.tixi.com>.

The development of the Tixi Device firmware never end, therefore some of the described features may not be available with your "older" hard- or firmware version. The cover tells you which firmware is required to use all described features (Note "Supported Tixi Device Firmware x.x.x"). See chapter 14.3 for a firmware history.

The TiXML-Reference for devices with firmware version older than 3.0 has the manual code "TiXML-EN" and is also available on our website.

The following picture will help you to understand the processing and relation of all databases.



At first there is a “**system to check**” which may be a **PLC** connected via serial port or some switches and measure instruments connected to the Tixi Device **I/O-Ports**.

The configuration of PLCs is documented in a separate “PLC TiXML Manual”.

The processing of I/Os or PLC variables is explained in **chapter 6**. A not supported PLC may control the Tixi Device via TiXML-commands, e.g. the DoOn-Command to activate alarms (see. **Chapter 0**)

The process “**Event States**” are defining what to do if a variable or I/O-port changes (**chapter 6.2**). The condition for an event state can be configured in the event state itself, or via “**process variables**” which offer some logical instructions (**chapter 6.2**).

As soon as an “**Event Handler**” (**chapter 3.7**) is triggered by an event state, the “**Job Generator**” starts to process the event handler commands e.g. for logging data (**chapter 4**) or creates a “Sendmail” job using the predefined text templates and address book contacts. A “**Message Job Template**” (**chapter 0**) defines the message type (e.g. SMS) and refers to the recipient from the **address book** (**chapter 3.4**) and the message templates (**chapter 3.8**).

Thereafter the “**Job Server**” starts to send the alarm message using the **location** (**chapter 3.2**) and **user data** (**chapter 3.2**) settings to calculate the number to dial. For email messages the **Internet Access (ISP)** settings (**chapter 3.5**) are used to connect to the internet mail servers. For SMS the database of **SMS providers** (**chapter 3.10**) is used.

2 Controlling a Tixi Device

2.1 Overview

The Tixi Device has a serial interface (RS232) used to control it by a client (control unit, PC, Laptop etc.). The TiXML - Control Protocol is used to control and configure the Tixi Device as a messaging system. TiXML may also be used to control a Tixi Device remotely via a phone line (see chapter 5.2) or via the LAN/Internet (see chapter 3.16).

2.2 RS232 Communication parameters

On the RS232 host port "COM1" TiXML commands must be send with baudrate 115200bps using 1 start bit, 8 databits, none parity, 1 stop bit (8N1).

2.3 Communication Mode

TiXML-Mode uses serial communication at 115200bps with data format 8N1. Hardware handshake (RTS/CTS) is necessary for TiXML communication.

Modem Mode (known from version 2.X) is no longer supported.

TiXML Mode

In this mode Tixi Alarm Modem / Tixi Data Gateway works as a messaging system. A client (for example the control unit or a PC) can now send commands and configurations to the device and can receive responses. You can use a simple terminal program to do this. In this mode the device is responsible for the Simple Tixi Control Protocol (TiXML).

2.4 TiXML - Control Protocol (TiXML)

The Simple Tixi Control Protocol (TiXML) is designed for use of Tixi Alarm Modem / Tixi Data Gateway as a messaging system in industrial applications. As clients cannot implement difficult multi-layer protocols like TCP/IP, Tixi decided to create a simple text based protocol that is as easy to use as AT commands. Typically, the client reacts to an event by sending an event message to the Tixi device. The TiXML protocol is reduced to a minimum so that only the really necessary data about an event is transmitted. Furthermore, the use of a text based protocol makes debugging very simple and the time and effort required for learning and understanding of the protocol is very small.

The protocol is derived from Simple Object Access Protocol (SOAP)¹ which is designed for message transports via HTTP and Internet to implement remote procedure calls via the Internet. In TiXML the complete message envelope is replaced by a simple frame "[...]". Only the message contents (body) are used. Like SOAP, the TiXML uses the Extensible Mark-up Language (XML)² as the message format. TiXML messages can therefore be edited as XML documents using third party XML editor programs. This reduces the occurrence of syntactical errors.

2.4.1 Overview


TiXML implements a simple text-based remote procedure call mechanism. The client calls a procedure prepared by the Tixi device (which is in the role of the server) and the Tixi device answers with a return value (in fact a return message, containing more than one value). To call a procedure, a message is sent by the client to the Tixi device. The message is enclosed by a message frame (see "Framing"). The procedure and the parameters are encoded as a XML document (see "Command Encoding").

¹ <http://www.w3.org/TR/SOAP> or msdn.microsoft.com/soap


² <http://www.w3.org/XML>

2.4.2 Framing

Each Message is enclosed in square brackets:



The example shows a message body with one line. Messages with multiple lines are also allowed. Only one <> element is allowed per single line. In this case the message is enclosed in the same way as with one line: the first character is a '[' and the last character in the last line is a closing ']'. No CR/LF is needed at the end of the frame.



The framing is the same for messages send to the Tixi device as for messages received from the Tixi device.

The Tixi device does not answer until it has received a complete frame.

Note: The first two characters of a TiXML command [< have to be entered without delay, otherwise the command will not be recognized.

2.4.3 Command Encoding

Each procedure call and corresponding answer is encoded as a simple XML document. A XML document has a single root element. The name of this element is the name of the called procedure. Both, the procedure call message and the answer message have the same root element name. When the message is send by the client to the Tixi device, the message is interpreted as a procedure call. In the opposite direction the message is the answer to a procedure call. Each procedure call is answered by an answering message. If there is an error in the command processing, an error frame is sent by the Tixi device.

The client should wait with a timeout of 10s for an answer from the Tixi Device before it makes the next procedure call. In some conditions (e.g. creating an email with large Logfile attachment) the response to a DoOn command may even take several minutes.


To generate something like an "AT command set" for controlling a Tixi Device, each procedure is equivalent to a command. Therefore the procedure name is the command name.

The simplest XML document consists of a single element which is also the root element.

```
<DoOn _="Event" /> single element document.
```

This is equivalent to <DoOn _="Event"></DoOn>. As it has no value, the end tag </DoOn> can be removed and the tag ends with /> instead.

A complex XML document has a tree structure:



where the children are enclosed by the tags of the parent.

Only one <> element is allowed per line.

Character Set

TiXML uses character set ISO-8859-1 (ASCII + Latin-1).

ASCII											iso-8859-1										
+	0	1	2	3	4	5	6	7	8	9	+	0	1	2	3	4	5	6	7	8	9
30			!	"	#	\$	%	&	'		160		ı	ç	£	¥	ı	§	"	ø	
40	()	*	+	,	-	.	/	0	1	170	ª	«	¬	-	®	-	°	±	²	³
50	2	3	4	5	6	7	8	9	:	;	180	ˆ	µ	¶	.	¸	¹	º	»	¼	½
60	<	=	>	?	@	A	B	C	D	E	190	¸	ˆ	À	Á	Â	Ã	Ä	Å	Æ	Ç
70	F	G	H	I	J	K	L	M	N	O	200	È	É	Ê	Ë	Ì	Í	Î	Ï	Ð	Ñ
80	P	Q	R	S	T	U	V	W	X	Y	210	Ò	Ó	Ô	Õ	Ö	×	Ø	Ù	Ú	Û
90	Z	[\]	^	_	`	a	b	c	220	Ü	Ý	Þ	ß	à	á	â	ã	ä	å
100	d	e	f	g	h	i	j	k	l	m	230	æ	ç	è	é	ê	ë	ì	í	î	ï
110	n	o	p	q	r	s	t	u	v	w	240	ð	ñ	ò	ó	ô	õ	ö	÷	ø	ù
120	x	y	z	{		}	~				250	ú	û	ü	ý	þ	ÿ				

Some ASCII characters are part of the TiXML syntax, and therefore have to be replaced by "entities" if used inside attribute values:

Character	Entity
<	<
>	>
&	&
"	"

All Latin-1 character (iso-8859-1 supplement) have to be inserted as HEX entity &#x[code];

Character	Entity
ö	ö
ä	ä
ü	ü

The complete code charts can be found here: <http://www.unicode.org/charts/PDF/U0080.pdf>

Command Name

The example shows the procedure call message and its answer. Both have the same root element name.

```
Control Unit sends: [ <DoOn _="Alarm_0">
                    <Barn _="12"/>
                    <Temperature _="10"/>
                    </DoOn> ]
```

```
Tixi Device responds: [ <DoOn/> ]
```

Please note that a command name or tag name must not exceed 20 characters. Only characters [a-z][A-Z][0-9] and [_] are valid, no digit at the beginning.

Parameters

The parameters of the command and result values can be encoded in different ways:

The command and the answer can have an **owned** parameter. Its name is implicitly known or has the same name as the command. The value of the parameter is encoded as an XML attribute with the character '_' as XML attribute. The attribute value has to be in quotes "" (ASCII dec 34) and assigned by an equals sign '='.

Note that there is a **space character between the tag name and the '_' character**.

Additional parameters can be encoded as a **list of Parameters** (pairs of names and values) like in the example above. <Barn _="12"/> is a Parameter with the name 'Barn' and the value '12'.

```
[ <DoOn _="Alarm_0">
  <Barn _="12"/>
  <Temperature _="10"/>
</DoOn> ]
```

Owned Parameter of the Command

Parameter List

In the root element tag some additional parameters can be inserted. These parameters are **optional** and have a default value, which is used when the parameter is not written in the command message.

```
[ <DoOn _="Alarm_0" ver="y">
  <Barn _="12"/>
  <Temperature _="10"/>
</DoOn> ]
```

Optional Parameter

Parameter List

Any parameter may include references to system properties (see chapters 3.1.1 and 12):

```
[ <DoOn _="Alarm_0">
  <Barn _="&#xae;/Process/Bus1/Device_0/Variable_0"/>
  <Temperature _="&#xae;/Process/Bus1/Device_0/Variable_1"/>
</DoOn> ]
```

References

If you have complex parameters you can encode it as a structured XML document. The following example shows the command to write a complete database where the database is the complex parameter.

```
[<SetConfig _="ISP" ver="y">
  <ISP>
    <PPPComm>
      <PPPUserName _="user" />
      <PPPPassword _="pass" />
      <AuthentFlags _="3" />
      <FirstDNSAddr _="194.25.2.129" />
      <SecondDNSAddr _="193.158.131.19" />
    </PPPComm>
    <SMTP>
      <mailserver_name _="domain.com" />
    </SMTP>
    <Modem>
      <RemotePhoneNumber _="+49-30-1234567" />
      <MediaType _="DATA" />
      <ModemProtocol _="syncPPP" />
    </Modem>
  </ISP>
</SetConfig>]
```

Complex parameter

Important:

If you send complete projects or large databases to the modem, we recommend stopping the job processing before sending the first SetConfig:

```
[<Set _="/Process/Program/Mode" value="Stop" ver="v" />]
```

After uploading the project/database you have to start the job processing (this is automatically done by modem reset):

```
[<Set _="/Process/Program/Mode" value="Run" ver="v" />]
```

2.4.4 Error Frame

When the command processing produces an error, the Tixi device responds with an error frame. The size of this frame is controlled by the **optional verbose parameter which can be included in each command**:

ver - verbose parameter controlling the error response size

Syntax:

```
ver="e"
```

Description:

This optional parameter can be inserted at each command and controls the size of the error message returned by the Tixi Device.

Elements:

e:

n...short error message - returns an error code (**default**).

y...verbose error message – returns a short description

v...extended error message – returns an extended verbose description

Example:

Short error message:

```
[<GetConfig _="Event/Alert1" ver="n"/>]
  <Error _="-1498"/>
```

Verbose Error Message:

```
[<GetConfig _="Event/Alert1" ver="y"/>]
  <Error>
    <ErrNo _="-1498"/>
    <ErrText _="path not found"/>
    <ErrorCause>
      <ErrNo _="-1498"/>
      <ErrText _="path not found"/>
      <Class _="TXSTCPReadDatabaseCmd"/>
    </ErrorCause>
  </Error>
```

If there are simple microcontroller driven clients, which cannot parse XML data, the default verbose flag 'n' can be used. This returns a single line error frame with an error number. It can be easily processed by this type of device. The verbose flag 'y' should be used during the configuration, when the error frame is not automatically processed but the user needs verbose information on the cause of the error.

For most commands, the following default error frame is created.

Default Error Frame**Description:**

Error frame returned by most commands when an error occurs during command processing. This frame is sent instead of the answer frame which is sent when no error occurs.

Note:

Some commands extend this frame by additional classes of errors.

ver="n":

```
<Error _="errn"/>
```

ver="y":

```
<Error>
  TiXML Error:
  ErrorCause:
</Error>
```

TiXML Error:

Error of the TiXML protocol.

```
<ErrNo _="errn"/>
<ErrText _="Error Description"/>
```

ErrorCause:

Original error detected in the system.

```
<ErrorCause>
  <ErrNo _="errn" />
  <ErrText _="Error Description" />
  <Class _="Class Name" />
  ErrorContext
</ErrorCause>
```

ErrorContext:

Optional context information on the error.

```
<Context1 _="ContextValue" />
<Context2 _="ContextValue" />
<Context3 _="ContextValue" />
```

errn:

<0...Error code.

Error Description:

Short description text of the error.

Class Name:

ID where the error number is related.

ContextValue:

The context information.

Example:

Short error message:

```
[<GetConfig _="Event/Alert1" />]
< Error _="-1498" />
```

Verbose Error Message:

```
[<GetConfig _="Event/Alert1" ver="y" />]
```

```
<Error>
  <ErrNo _="-1498" />
  <ErrText _="path not found" />
  <ErrorCause>
    <ErrNo _="-1498" />
    <ErrText _="path not found" />
    <Class _="TXSTCPReadDatabaseCmd" />
  </ErrorCause>
</Error>
```

2.4.5 Error codes

There are several errors returned or logged if a command or a job could not be processed. The answer frame in this case is a single line error frame. The following error numbers are returned:

Number	Description
-24	unable to read from disk
-38	failure to receive expected frame
-43	cannot send EOP frame
-45	disconnection requested by remote
-46	can't transmit end of data
-100	Key not found
-102	last write not yet finished
-102	event contains unknown command
-104	the referenced process variable was invalid
-105	unknown variable type
-105	log file empty on delete
-106	requested path not found
-107	current task already writes to logfile
-107	no event given
-108	unknown error
-109	the syntax of the database is incorrect
-110	the config data is faulty
-112	script terminated with error
-112	no value given
-114	the set command failed
-117	invalid log file content type
-151	required parameter in configuration missing
-200	no address for this station given
-201	template header not found
-202	unknown log file
-204	connection lost
-204	unknown keyword
-204	invalid mail type
-204	the tag name was too long
-205	the requested bus type is not supported
-206	no record given
-207	no memory for mail
-208	temporary no memory for mail
-210	the last write yield an error
-213	no job type given
-215	configuration not found (invalid path)
-219	length of SMS message exceeds 160 chars
-225	no for_all given
-229	copy operation failed
-232	command parameter missing
-239	second StartChecksum command. Only one is allowed
-240	illegal command parameter (StopChecksum)
-300	modem connection failed
-306	error writing a read only variable
-307	build up PPP stack failed
-399	modem not connected
-401	Frame stream error
-510	file does not exist
-516	select function for send timed out
-520	ordered file space can't be reserved
-607	stack level incomplete on exit
-1095	command is remotely not available
-1097	connection lost - still in remote mode
-1098	authentication required
-1099	command not recognized

-1193	the accessed database is corrupt
-1194	database does not exist
-1195	failed to store database
-1197	could not copy content to file/db
-1199	could not open database
-1496	could not open database
-1497	could not read database
-1498	path not found
-1499	no path given
-1885	the set command failed
-1886	DoOn parameter missing
-1889	could not open journal
-1896	an error in the job creation occurred
-1899	event not in list
-2093	CHAP error - no default user defined
-2094	modem connection lost
-2095	no modem connection
-2099	no phone number given
-2194	value exists, but does not contain valid data
-2196	path to key not found
-2197	cannot interpret the value to set
-2297	invalid magic number for factory reset
-2298	reset command remotely not allowed
-2299	invalid reset command
-2391	comport used by configuration tool
-2397	the requested comport does not exist
-2491	no authentication method given
-2493	invalid authentication method
-2497	the user/password is invalid
-2698	error during reading the logfile
-2699	the log entry range is invalid

2.4.6 Commands

TiXML implements several commands (equivalent to the AT command set of a modem) for the control of the device. The commands can be divided into the following groups:

2.4.6.1 Device control

Reset – Reset the device

Syntax:

```
<Reset _="Mode" magic="number" />
```

Description:

This command resets the device.

Note: The reset is started when the command is received by the device. Depending on the device (especially Flash Memory Size) 6s to 30s will elapse before the device is ready again.

Parameter:**Mode:**

- Keep** Keep the current settings.
- Factory** Sets the device to its factory settings.
Note: All configurations set with the 'SetConfig' command are deleted. GSM and even Ethernet settings (if "persistent") will be kept to guarantee remote access.
- Update** Checks the SD-Card for a firmware update.

Download

Sets the Modem into firmware update mode. The command has to be followed by ATi9 <CRLF> to detect the upload baudrate (answer: "Serial mode, no modem code!") Thereafter the binary firmware file may be sent using Z-Modem protocol.

- Format** Reformats the flash memory

number: A magic number is necessary for the factory reset of a remote device or a factory reset via SD card.
The magic number is "030406080".

Return:***If no error (command is processed):***

<Reset />

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Reset the Tixi Device and keep the current settings.

Client sends: [<Reset _="Keep" />]

Tixi Device responds: [<Reset />]

SetTime - Sets the system time of the device**Syntax:**

<SetTime _="YYYY/MM/DD, hh:mm:ss" />

Description:

This command sets the system time of the Tixi device to the value of the parameter.

Note: The Tixi device contains a Real Time Clock (RTC) that keeps the system time when the power is off. Use this command to set the device time.

Parameter:**YYYY:**

1970...2034 - year.

MM:

01...12- month.

DD:

01...31- day.

hh:

00...23- hour.

mm:

00...59- minutes.

ss:

00...59- seconds.

Return:**If no error (command is processed):**

```
<SetTime/>
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Set the Tixi Device system time to 18 Aug 2000 13:10 hour and 34 seconds.

```
Client sends:      [<SetTime _="2000/08/18,13:10:34" />]
Tixi Device responds: [<SetTime />]
```

GetTime - Gets the current system time of the device**Syntax:**

```
<GetTime />
```

Description:

This command returns the current system time of the Tixi device.

Note: This command is used by our programming tools to check whether the Tixi device responds to TiXML commands or not.

Parameter:

No Parameter.

Return:**If no error (command is processed):**

```
<GetTime _="YYYY/MM/DD, hh:mm:ss" />
```

YYYY:

1970...2034 - year.

MM:

01...12 - month.

DD:

01...31 - day.

hh:

00...23 - hour.

mm:

00...59 - minutes.

ss:

00...59 - seconds.

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Get the current system time of the Tixi Device.

```
Client sends:      [<GetTime />]
Tixi Device responds: [<GetTime _="2000/08/18,13:10:34" />]
```

TransMode - Set the Tixi Device to a transparent mode to control the connected client device

Syntax:

```
<TransMode format="SerialFormat" local="localSerialFormat"
  baud="Baud Rate" com="comport" handshake="Handshake" keep="time"
  wait="timeout" />
```

Description:

1. It switches the Tixi Device to a transparent mode.
Two modes are possible:
 - Local transparent mode: data from COM1 will be routed to the selected extension com port (COM2/COM3).
 - Remote transparent mode: data from the local dialing modem will be routed to the selected com port or the host port COM1 (if parameter com was omitted) of the remote modem.
2. It transforms the baud rate and the serial data format from the local (COM1 or dialing modem) values to the values that the client device, e.g. PLC, uses.

Note: It takes about 100ms to forward the first data after establishing the transparent mode.

This transparent mode of the remote Tixi Alarm Modem is left when the dialup connection is interrupted. Thereafter the remote Tixi Alarm Modem goes back in the TiXML-Mode. To disconnect a remote transparent mode, the local desktop PC must send the escape sequence (+++) and ATH.

A transparent mode to the host port MB (COM1) is denied if a local login session is open (see chapter 0).

If a local TransMode was issued (e.g. from COM1 to COM2), the Modem goes back to TiXML Mode after DTR-low (after "keep" timeout) on COM1 or after a PnP initialization.

Remote TransMode is not available for Ethernet devices (Tixi Data Gateways).

Parameter:

SerialFormat:

String which encodes the serial format that is used between modem and client device. It has the following syntax (**default "8N1"**):

DataBitsParityBitsStopBits

DataBits

8...8 data bits are used.

7...7 data bits are used.

ParityBits

N...No parity bit.

E...Even parity.

O...Odd parity.

StopBits

1...one stop bit.

2...two stop bits.

localSerialFormat:

Same as "SerialFormat" but used between PC and modem.

Baud Rate:

Baudrate in bits per second (bps) (**Default 115200**).

comport:

Specifies the COM port on the Tixi device used for the connection.

COM1	Programming port (labeled COM1 RS232) (default)
COM2	PLC port (labeled COM2 RS232 or COM2 R-485/422) (if available)
COM3	M-Bus interface (labeled M-Bus) (if available)

Handshake:

Used communication handshake.

None	communication without handshake
XONXOFF	software handshake
XONXOFFPASS	software handshake, XONXOFF forwarded to application
RTSCTS	hardware handshake with RTS CTS
DTRDSR	hardware handshake with DTR DSR
HALF	Halfduplex RS 485 communication
FULL	Fullduplex RS 485/422
HALFX	Halfduplex RS 485 communication with XON XOFF
FULLX	Fullduplex RS 485/422 with XON XOFF
noDTR	disables DTR control, DTR will be always active

time:

There are two different functions for this parameter, depending on the connection:

During connection from one Tixi device port to its second port:

Specifies the time period the Tixi device will wait for the application to take over the serial port (**Default 0s**). After this time the modem will automatically leave the TransMode.

During remote connection (optional):

Specifies the time period the Tixi Device will try to disable the bus protocol at the specified com port to establish a transparent connection.

timeout:

Specifies the time the Tixi Device will try to disable a PLC bus protocol on the remote com port (Default: 20s).

Return:

This command returns no TiXML frame because the TiXML protocol is left. The string **CONNECT** acknowledges the established transparent mode.

Example:

1.

Set the Tixi Device to the transparent mode and connect it to the client device with 57600bps and 8 data bits, even parity bit and one stop bit. Data from COM1 will be routed to COM2 vice versa:

Client sends:

```
[<TransMode baud="57600" local="8E1" format="8E1" com="COM2" />]
```

Tixi Device responds:CONNECT

2.

Connect to a remote Tixi Alarm Modem, switch the device to the transparent mode with a baud rate of 9600 and a format of 8N1 on RS 485 halfduplex interface COM2.

Client sends: [<TransMode baud="9600" format="8N1" com="COM2"
 handshake="HALF" keep="20s" />]

Tixi Alarm Modem responds: CONNECT

Steps after CONNECT message:

1. Disconnect the client (R-CON, TILA2, TICO) from COM Port.
2. Connect the other control program (e.g. PLC software) to the COM Port.
3. Control the remote client through the Tixi Alarm Modem.
4. Disconnect the control program from COM port.
5. Connect the client (R-CON, TILA2, TICO) to the Tixi Alarm Modem COM port.
6. Disconnect:

Local TransMode:

Client sends: Plug&Play sequence

Remote TransMode:

Client sends: (wait one second) +++ (wait one second)

Modem responds: OK

Client sends: ATH

ScanWLAN – Scan for available WLAN access points**Syntax:**

See chapter 3.15

2.4.6.2 Authentication**Login – Start a TiXML session****Syntax:**

```
<Login _="type" user="User Name" password="Password" />
```

Description:

This command starts a TiXML session for a user. By this command the user makes an authentication to the device.

Note: The Tixi device can be protected against unauthorized access. In the factory configuration no access protection is provided. In this system state the **Login** command doesn't need to be sent to control the device. In this state each command has its own session, i.e. the session starts implicitly with the command and ends after command return.

When the Login command is sent in this state, user name and password are ignored.

If you need to upload several databases to the modem (configuration session), and one of the databases includes user access configuration, it is recommended to send a [`<Login/>`] command at first to open a TiXML session. Otherwise all SetConfig commands after uploading the new user access configuration will be blocked according to the new access protection users.

To limit the access to certain users you can create a service/group/user/password map in the configuration of the Tixi device. If this map is not empty, no command is processed until the login command with a valid user-password pair is sent, for example, by the client. This protection is related to the connection (RS232, LAN or phone line connection) where the commands are sent. If there is another connection at the same time this connection needs its own authentication.

An accepted login is valid until:

- The **Logout** command is sent
- or a **Login** command with an invalid user-password pair is sent
- or the power goes off
- or the DTR is low

- or the remote connection is broken (for remote control only).
- or no commands are received for 5 minutes (idle timeout)

To create the access protection, see chapter 3.6.

There are two ways to remove the access limitation:

1. Send an empty AccRights configuration (see chapter 3.6).
2. Make a factory reset using the **Reset** command with the parameter `Factory`. See chapter 2.4.6.1 for details on resetting the Tixi device. Keep in mind that a factory reset deletes all other settings as well.

Parameter:

type:

- PAP (Password Authentication Protocol)** sends the password without encoding.
- CHAP (Challenge Handshake Authentication Protocol)** multistep protocol does not send the password, a challenge is exchanged.

User Name

User name can be empty if no authentication is required or it must be empty if the "Def_Service" users are configured (password protection).

Password

Password. Can be empty.

Return:

If no error (command is processed):

```
<Login/>
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Login successful:

Client sends: [`<Login _="PAP" user="Name" password="secret" />`]*Tixi Device returns:* [`<Login/>`]

Login not successful:

Client sends: [`<Login _="PAP" user="Name" password="try" />`]*Tixi Device returns:* [`<Error _="-1098" />`]

CHAP Login Sequence (Username "Daniel", Plain-Password "test")

Client sends: [`<Login _="CHAP" user="Daniel" />`]*Tixi Device returns:*

```
[<Login _="Challenge">
  <key _="b0a12c96ef9b01f8c07fd98b332c165ffdab5764872ef049" />
  <id _="31" />
</Login>]
```

Client sends: [`<Login _="Response" id="31" md5="468041b48c6bca5ffd9834209d8b1935" ver="y" />`]*Tixi Device returns:* [`<Login/>`]

The hash for the MD5 response is calculated over the string "ID+password+key". The string in the above example would be
 "31testb0a12c96ef9b01f8c07fd98b332c165ffdab5764872ef049"

Logout – Quit a controlling session**Syntax:**`<Logout />`**Description:**

This command quits a TiXML session - started with a successful Login. It denies the access right to the Tixi Device for the connection where the command is sent.

Note: This command can be sent at any time. It affects the access to the Tixi device if a Login command was sent before. In this case the access right is denied and a new Login will be necessary to get access again. If no access protection is configured or no login session is established, this command does nothing.

Parameter:**No Parameter.****Return:****If no error (command is processed):**`<Logout />`**On error (command is not processed):**

see default error frame (chapter 2.4.4)

Example:

Login successful

Client sends: [`<Logout />`]*Tixi Device returns:* [`<Logout />`]

2.4.6.3 Event processing

DoOn – Trigger an Event

Syntax:

```
<DoOn _="EventName" >
    ParameterList
</DoOn>
or
<DoOn _="EventName" />
```

Description:

This starts the processing of a client event. The command can be used to test the processing of events without need to change the associated trigger variables.

Note: There are two forms of syntax; one is the long form which allows the transmission of additional attributes representing the parameters of the event context. If no event context is present, the short form is used. The command starts the event processing when the result is sent back to the client.

In most cases this leads to the creation of message jobs. The sending process of the messages is done while the client can create new event messages. The results of the processing are observed by the Tixi device itself. The results can be observed by the client using the `ReadLog` command which is described in chapters 2.4.6.6 (how to read logfiles) and 4 (how to create logfiles). Active jobs can be read using the `GetJob` command (see following pages)

Parameter:

EventName:

Name of the event to be processed. There must be an `EventHandler` configuration in the 'EVENTS' database using this name. See chapter 3.2 for details on `EventHandler` database.

ParameterList:

List of XML encoded parameters representing the event context. A parameter is written in a single XML tag:

```
<ParameterKey _="Value" />
```

where

ParameterKey: is the unique name of the parameter.
Value: is the value of the parameter.

Return:

If no error (command is processed):

```
<DoOn/>
```

On error (command is not processed):

ver="n":

```
<Error _="errn" />
```

ver="y":

```
<Error>
    TiXML Error:
    JobGeneratorError
    ErrorCause:
</Error>
```

TiXML Error:

Error of the TiXML protocol.

```
<ErrNo _="errn" />
<ErrText _="Error Description" />
```

JobGeneratorError:

Error during Job generation.

```
<JobGeneratorError>
  <ErrNo _="errn" />
  <ErrText _="Error Description" />
  ErrorContext
</JobGeneratorError>
```

ErrorCause:

Original error detected in the system.

```
<ErrorCause>
  <ErrNo _="errn" />
  <ErrText _="Error Description" />
  <Class _="Class Name" />
  ErrorContext
</ErrorCause>
```

ErrorContext:

Optional context information on the error.

```
<Context1 _="ContextValue" />
<Context2 _="ContextValue" />
<Context3 _="ContextValue" />
```

errn:

0...OK

<0...Error code.

Error Description:

Short description text of the error.

Class Name:

ID where the error number is related.

ContextValue:

The context information text.

Example:

Process the 'TemperatureAlert' event. The event context contains the barn ID = 12 where the temperature is in a critical range and the value of the temperature in degrees of Celsius.

```
Control Unit sends:  [ <DoOn _ "TemperatureAlert" >
                      <Barn _="12" />
                      <Temperature _="10" />
                    </DoOn> ]
```

```
Tixi Device responds: [ <DoOn/> ]
```


GetJob – Shows a list of currently active jobs**Syntax:**

```
<GetJob del="Mode" />
```

Description:

This command shows a list of job groups and currently active jobs.

Note: This command may also be used to cancel currently active jobs, e.g. to delete messages from the message queue.

Parameter:

Mode:	y	delete all active jobs (running jobs can't be deleted!)
	n	don't delete active jobs (default)

Return:**If no error (command is processed):**

```
<GetJob>
  <JobGroup _="State">
    <Job_X>
      <Time _="Date,Time" />
      <Type _="Type" />
      <Priority _="Priority" />
      <Origin _="Origin" />
    </Job_X>
  </JobGroup>
  ...
</GetJob>
```

JobGroup: Name of job group.
Currently known groups:

- Modem_Mode
- Default
- Express_E-mail_Send
- Express_E-mail_Recv
- TSAdapter
- SMS_Receive
- SMS_Send
- POP3_Client
- HTTP_Server_In
- CGI_DoOn
- HTTP_Server_Out
- Time_Client
- URL_Send
- SMTP_Client
- Fax_Send
- Text_Fax
- Fax_Receive
- Script_Send
- Incoming_Call
- Auto_Transmode
- Job_Result_Processor
- Remote_ModemMode
- TSAdapterCallback

State:	State of job group	
	Started	Jobs will be processed
	Stopped	Jobs are not processed (service not licensed)

X: Active job number (increases)

Date, Time: Start time of job

Type: Job type number, e.g. 5=GSMSMS

Priority: Priority of job (see chapter 3.7.1)

Origin: EventHandler name

On error (command is not processed):
see default error frame (chapter 2.4.4)

Examples:

GetJob on idle system state:

```
Client sends:  [<GetJob/>]
Tixi Alarm Modem responds:
[<GetJob>
  <Modem_Mode _="Started"/>
  <Default _="Started"/>
  <Express_E-mail_Send _="Started"/>
  <Express_E-mail_Recv _="Started"/>
  <TSAdapter _="Started"/>
  <SMS_Receive _="Started"/>
  <SMS_Send _="Started"/>
  <POP3_Client _="Started"/>
  <HTTP_Server_In _="Started"/>
  <CGI_DoOn _="Started"/>
  <HTTP_Server_Out _="Started"/>
  <Time_Client _="Started"/>
  <URL_Send _="Started"/>
  <SMTP_Client _="Started"/>
  <Fax_Send _="Started"/>
  <Text_Fax _="Started"/>
  <Fax_Receive _="Started"/>
  <Script_Send _="Started"/>
  <Print_Jobs _="Started"/>
  <Incoming_Call _="Started"/>
  <Auto_Transmode _="Started"/>
  <Job_Result_Processor _="Started"/>
  <Remote_ModemMode _="Started"/>
  <TSAdapterCallback _="Started"/>
</GetJob>]
```

GetJob with SMS in message queue, waiting for acknowledge:

```

Client sends:    [<GetJob/>]
Tixi Alarm Modem responds:
[<GetJob>
  <Modem_Mode _="Started" />
  ...
  <Text_Fax _="Started" />
  <Script_Send _="Started">
    <Job_3>
      <Time _="2008/04/26,17:25:47" />
      <Type _="5" />
      <Priority _="1" />
      <Origin _="currently unavailable (running)!" />
    </Job_3>
  </Script_Send>
  <Incoming_Call_Trigger _="Started" />
  <Job_Result_Processor _="Started">
    <Job_3>
      <Time _="2038/01/19,03:14:07" />
      <Type _="65" />
      <Priority _="99" />
      <Origin _="Alarm_0" />
    </Job_3>
  </Job_Result_Processor>
  <Remote_ModemMode _="Started" />
</GetJob>]

```

GetJob delete:

```

Client sends:    [<GetJob del="y" />]

```

The Tixi Device answers with the list of all active jobs including the deleted jobs. A thereafter immediately send [<GetJob/>] will show a list without active jobs (if no new jobs are started in the meantime).

2.4.6.4 Configuration

SetConfig - Set configuration data.

Syntax:

```

<SetConfig _="Path">
  XML-Data
</SetConfig>

```

Description:

This command writes configuration data into a database.

Note: The Tixi device stores its data permanently in an embedded XML database. The database is prepared by the firmware of the Tixi device. It can't be deleted or created by the client. Only the contents of the database can be changed.

Parameter:

Path:

DataBase/GroupPath

DataBase Name of the database where the data has to be written.

GroupPath Path name in the database where the attribute group is to be inserted/replaced (**optional** and for attribute groups only).

XML-Data:

Attribute group or complete XML database document.

Note: **Complete attribute groups or databases** can be changed only! The command handler replaces the old attribute group by the new one. Separate attributes of an attribute group cannot be changed. If the attribute group does not exist in the database, the database is extended by the attribute group.

Return:

If no error (command is processed):

```
<SetConfig/>
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example 1:

Replace the contents of the 'Modem' attribute group inside the database 'ISP' and the attribute group 'ISP'

Client sends:

```
[<SetConfig _="ISP/ISP">
  <Modem>
    <RemotePhoneNumber _="+49-30-40608117" />
    <MediaType _="DATA" />
    <ModemProtocol _="syncPPP" />
  </Modem>
</SetConfig>]
```

Tixi Device responds: [<SetConfig/>]

Example 2:

Replace the contents of the ISP group inside the database with the name 'ISP'.

Client sends:

```
[<SetConfig _="ISP">
  <ISP>
    <PPPComm>
      <PPPUserName _="user" />
      <PPPPassword _="pass" />
      <AuthentFlags _="3" />
      <FirstDNSAddr _="194.25.2.129" />
      <SecondDNSAddr _="193.158.131.19" />
    </PPPComm>
    <SMTP>
      <mailserver_name _="domain.com" />
    </SMTP>

    <Modem>
      <RemotePhoneNumber _="+49-30-1234567" />
      <MediaType _="DATA" />
      <ModemProtocol _="syncPPP" />
    </Modem>
  </ISP>
</SetConfig>]
```

Tixi Device responds: [<SetConfig/>]

GetConfig - Get configuration data.**Syntax:**

```
<GetConfig _="Path" />
```

Description:

This command reads the configuration data from a database of the Tixi device

Parameter:**Path:****DataBase/GroupPath**

DataBase Name of the database to read.

GroupPath Path name in the database to read (**optional** and for attribute groups only).

Return:**If no error (command is processed):**

```
<GetConfig>
  XML-Data
</GetConfig>
```

XML-Data:

Sub tree or complete XML database document.

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example

Get the contents of the ISP group inside the database with the name 'ISP'.

Client sends: [<GetConfig _="ISP/ISP" />]

Tixi Device responds:[<GetConfig>

```
  <ISP>
    <PPPComm>
      <PPPUserName _="user" />
      <PPPPassword _="pass" />
      <AuthentFlags _="3" />
      <FirstDNSAddr _="194.25.2.129" />
      <SecondDNSAddr _="193.158.131.19" />
    </PPPComm>

    <SMTP>
      <mailserver_name _="domain.com" />
    </SMTP>

    <Modem>
      <RemotePhoneNumber _="+49-30-1234567" />
      <MediaType _="DATA" />
      <ModemProtocol _="syncPPP" />
    </Modem>
  </ISP>
</GetConfig>]
```

2.4.6.5 Process values

Get - Get System Property

Syntax:

```
<Get _="Path" AddInfo="Error" exp="Exponent" multip="Factor+Offset"
format="FormatString" ViewProperties="Flags" />
```

Description:

Get the value of the system properties referred by the *Path* value.

The System Properties are the set of data describing a Tixi Device. This includes administrative information like version numbers, licenses etc. which are defined at the creation time of the firmware as well as information on the hardware configuration and also the system state. The system state includes the system time, the system mode, the states of the I/O ports and PLC variables etc. The configuration settings defined by the SetConfig are a part of the system state and therefore a part of the system properties. They can therefore also be accessed by the Get command. The difference to the GetConfig command is the way the data is addressed and the structure of the returned data. Both commands use a slash separated path to address the data but Get addresses a single value only where GetConfig addresses complex values, for example a complete attribute group.

A second difference is in the data itself. All System Properties have a unique address defined by their path. Configurations contain parts which have no unique addresses: For example the PLC "External" could contain several "Devices" on a "Bus" which all have the same tag name "Device". In this case an element can't be addressed uniquely by a path. Therefore, not all elements of the configuration can be addressed by the Get command. Use GetConfig instead.

Parameters:

empty:

If no parameter is given, the Tixi Device will send a list of all system properties.

Path:

Path which addresses the system property. See chapter 12 "Appendix - System Properties" for details on system properties. The last element of the path may be a variable name or the name of a system property tree followed by a slash.

Error :

For directly reading the error state of a process variable or PLC variable, the "Get" command may be extended by the AddInfo attribute that displays the value of an additional information ("ErrorClass, ErrorValue") instead of displaying the variable value

ErrorClass:

0 = no error

1 = error (see ErrorValue)

ErrorValue:

See chapter 6.3.2 for ErrorValues.

See PLC-TiXML-Manual for further information.

Exponent:

Exponent of base 10 to specify fix point precision of simpleType = UInt8, UInt16, UInt32, Int8, Int16, Int32 (see 6.5.1).

The process variable value will be multiplied by $10^{\text{exp}(\text{Exp})}$ to get the parameter value.

$\text{valueParameter} = 10^{\text{Exp}} * \text{value process variable.}$

The exponent therefore specifies the position of comma within a fix point value
Following values are possible:

Exp value	Description
-6	Precision = 0,000001
-5	Precision = 0,00001
-4	Precision = 0,0001
-3	Precision = 0,001
-2	Precision = 0,01
-1	Precision = 0,1
0	Precision = 1 (default)
1	Precision = 10
2	Precision = 100
3	Precision = 1000
4	Precision = 10000
5	Precision = 100000
6	precision = 1000000

Factor+Offset

The value will be multiplied by this factor and the offset will be added to get the output value.

simpleType = Uint8, Uint16, Uint32, Int8, Int16, Int32 (see 6.5.1).

Output value = Factor * Logged value + Offset

The factor is used as a fraction, e.g.: „1/1000“ or „3600/1“, the denominator and numerator must not be zero. The offset may be negative or positive.

FormatString:

integer: (for PLC and process variables)

1. simpleType = Uint8, Uint16, Uint32, Int8, Int16, Int32 (see 6.5.1).

The value is displayed as integer. The integer calculates itself by using the exponent specified with the variable and its value :

Value as integer = $10^{-Exp} * value$

2. simpleType = float, double (see 6.5.1).

The value is displayed as integer. The integer calculates itself by using the precision specified with the variable and its value:

Value as integer = $10^{-Precision} * value$

3. all other data types

The value is displayed native (see 6.5.1).

native: (or empty)

The value is displayed native. (see 6.5.1).

FormatString:

String that defines the value output format.

For a list of available format option see chapter 6.5.

Flags:

Additional informations of external device variables (tree /Process/BusX/) will be displayed:

Name: Variable alias name if attribute Name is specified within External database. See PLC TiXML manual for more details.

TimeStamp:

Time stamp of the last successful polling of an external device variable.

Return:**If no error (command is processed):**

```
<Get _="value" />
value: value of the system properties
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Get the complete Tixi Device system properties:

```
Client sends: [ <Get ver="y" /> ]
```

Get the state of all digital inputs of the mainboard:

```
Client sends: [ <Get _=" /Process/MB/IO/I/ " /> ]
Tixi Device responds: [ <Get>
    <I>
        <P0 _="1" />
        <P1 _="1" />
    </I>
</Get> ]
```

Get the state of the first digital input of the mainboard:

```
Client sends: [ <Get _=" /Process/MB/IO/I/P0 " /> ]
Tixi Device responds: [ <Get _="1" /> ]
```

The status of the Tixi Device digital I/Os can also be read as a byte, word or dword value by adding B (byte), W (word) or D (dword) to the branch "I" within the system property path and referring to the first port within the group (see chapter 11.1):

Get mainboard inputs as a byte value:

```
Client sends: [ <Get _=" /Process/MB/IO/IB/P0 " /> ]
Tixi Device responds: [ <Get _="3" /> ]
```

Get mainboard inputs as a dword value:

```
Client sends: [ <Get _=" /Process/MB/IO/ID/P0 " /> ]
Tixi Device responds: [ <Get _="3" /> ]
```

Get the Tixi Device serial number:

```
Client sends: [ <Get _="/SerialNo" ver="y" /> ]
Tixi Device responds: [ <Get _="00081101" /> ]
```

Get and reformat the state of the analog input of the mainboard with two decimal places:

```
Client sends: [ <Get _=" /Process/MB/A/AI/P0 " format="F,2" /> ]
Tixi Device responds: [ <Get _="31,45" /> ]
```

Get the state of the analog input of the mainboard with an offset of 50:

```
Client sends: [ <Get _=" /Process/MB/A/AI/P0 " multip="1/1+50" /> ]
Tixi Device responds: [ <Get _="3195" /> ]
```

Get the native value of a formatted process variable:

```
Client sends: [ <Get _=" /Process/PV/Variable " format="native" /> ]
Tixi Device responds: [ <Get _="12345" /> ]
```

Get the error state of the PLC variable "Variable_0" at "Device_0" on PLC-bus "Bus1":

```
Client sends: [ <Get _=" /Process/Bus1/Device_0/Variable_0 "
    AddInfo="Error" /> ]
```


Tixi Device responds: [<Get _=" 0,0" />]

Get the alias name and the last successful polling of the PLC variable "Variable_0" at "Device_0" on PLC-bus "Bus1":

Client sends: [<Get _="/Process/Bus1/Device_0/Variable_0" ViewProperties="Name,TimeStamp" />]

Tixi Device responds: [<Get>
 <Variable_0 _="3.373" Name="Energie"
 TimeStamp="2009/01/22,14:03:09" />
 </Get>]

Get the maximal dial attempts defined in the USER database USER section:

Client sends: [<Get _="/USER/USER/MaxDialAttempts" />]

Tixi Device responds: [<Get _=" 2" />]

Set - Set System Properties

Syntax:

```
<Set _="Path" value="Value" exp="Exponent" />
```

Description:

Set the *Value* of the system properties referred by the *Path* value.

Note: There are many System Properties which are read only.

The System Properties are the set of data describing a Tixi Device. This includes administrative information like version numbers, licenses etc. which are defined at the creation time of the firmware, as well as information on the hardware configuration and the system state. The system state includes the system time, the system mode the states of the I/O ports etc. The configuration settings defined by the SetConfig are a part of the system state and therefore a part of the system properties. They can therefore also be accessed by the Set command. The difference to the SetConfig command is the way the data is addressed and the structure of the data set. Both commands use a slash separated path to address the data but Set addresses a single value only where SetConfig addresses complex values, for example a complete attribute group.

A second difference is in the data itself. All System Properties have a unique address defined by their path. Configurations contain parts which have no unique addresses: For example the PLC "External" could contain several "Devices" on a "Bus" which all have the same tag name "Device". In this case an element can't be addressed uniquely by a path. Therefore, not all elements of the configuration can be addressed by the Set command. Use SetConfig instead.

Parameters:

Path:

Path which addresses the system properties. See Appendix - System Properties for details on system properties.

Value:

Value to set. The syntactical format depends on the value to set. See Appendix - System Properties for details on system properties.

Values may be entered directly as decimal, hex, octal or binary values using following special syntax:

Example for decimal value "12":

value="12" (decimal)

value="0xC" (HEX)

value="0o14" (octal)
value="0b1100" (binary)

Set command with HEX format is only supported for unsigned values.

Process and PLC variables may be defined with exponent. In this case the new value has to be entered relatively to the exponent. Use a dot as decimal point.

Exponent:

Exponent of base 10 to specify fix point precision of
simpleType = Uint8, Uint16, Uint32, Int8, Int16, Int32 (see 6.5.1).
The variable value will be divided by 10^{Exp} to get the parameter value.

valueParameter = 10^{Exp} / value variable.

The exponent therefore specifies the position of comma within a fix point value

Following values are possible:

Exp value	Description
-6	Precision = 0,000001
-5	Precision = 0,00001
-4	Precision = 0,0001
-3	Precision = 0,001
-2	Precision = 0,01
-1	Precision = 0,1
0	Precision = 1 (default)
1	Precision = 10
2	Precision = 100
3	Precision = 1000
4	Precision = 10000
5	Precision = 100000
6	precision = 1000000

If no error (command is processed):

<Set />

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Set the mode of the Process subsystem:

Client sends: [<Set _="/Process/Program/Mode" value="Run" />]
Tixi Device responds: [<Set />]

Set the the first digital output of the mainboard:

Client sends: [<Set _="/Process/MB/IO/Q/P0" value="1" />]
Tixi Device responds: [<Set />]

Set a process variable defined with exp="-2":

Client sends: [<Set _="/Process/PV/Variable" value="3.12" />]
Tixi Device responds: [<Set />]

Set the Signalled to green (value=1) using an exponent:

Client sends: [<Set _="/Process/MB/Signalled" exp="1" value="10" />]
Tixi Device responds: [<Set />]

SetSequence - Set Sequencer profile**Syntax:**

See chapter 8

2.4.6.6 Logging**ReadLog – Read entries from the system's log files.****Syntax:**

```
<ReadLog _="LogFileName" range="entryrange" type="templates"
flags="header" fillInterval="interval" maxInterval="tolerance"
fillText="string" Viewset="variables" Formats/>
```

Description:

The Tixi Device returns the entries from the log file which are in the given range. The range can be composed from entry ids, time and counts. Some special range commands are also allowed. See chapter 4 on logfiles.

Parameter:**LogFileName:**

Name of the logfile to be read.

entryrange: *all* | *previous n timespan* | *last n timespan* | *start-end*

all This returns all entries contained inside the given logfile.

last n timespan (exact calculation)

indicates that all entries from the given previous timespan calculated from the actual time are to be returned. Where **n** is the number of units (must be higher than zero) and **unit** the unit itself. Valid **unit** values are:

years	indicates that n represents a number of years
months	indicates that n represents a number of months
days	indicates that n represents a number of days
hours	indicates that n represents a number of hours
minutes	indicates that n represents a number of minutes
seconds	indicates that n represents a number of seconds

previous n timespan (smooth calculation)

indicates that all entries from the given previous timespan calculated from the last unit are to be returned. Where **n** is the number of units (must be higher than zero) and **unit** the unit itself. Valid **unit** values are:

years	indicates that n represents a number of years
months	indicates that n represents a number of months
days	indicates that n represents a number of days
hours	indicates that n represents a number of hours
minutes	indicates that n represents a number of minutes
seconds	indicates that n represents a number of seconds

“Previous” will not show values written in the “future”, e.g. if you set the clock -1h during daylight saving. During this hour you’ll have to use one of the other parameters (e.g. “last”) instead.

start-end

Returns all entries contained between the given identifiers. These identifiers - **start** and **end** - may have one of these formats:

[empty] Means either the first (if **start**) or the last (if **end**) entry in the

logfile.

- #c** counts either from start or from end (depends on if used for **start** or for **end**) onto the **c**-th entry.
- Date,Time** defines a moment. **Time** is in *hh:mm:ss* format (24 hours) and **Date** in *YYYY/MM/DD*, and **Date** can be omitted if it's about the current day.
- ID** defines the ID of the entry (if only one ID is given) or entries (if range of Ids is given).

Important!

Keep in mind that when using **start-end** you must specify at least **start** or **end** along with the hyphen. Even if **start** or **end** is empty, the hyphen must be used.

If **Time** range is in the future, data of previous day will be read

Date has to be used with start AND end, or none of both.

Start Time must be before **end Time**.

If **Time** span reached next day, **Date** has to be used.

Last given value will be **end Time** – 1s.

templates:

Predefined logfile formats:

- XML:** Logfile will be displayed as XML file
- CSV:** "character separated value", e.g. for easy Excel import. (embedded XML frame)
- HTML:** Logdata will be formatted as HTML table (embedded XML frame)

header:

flags="NoId,NoDate,NoTime,NoNames,NoSec,UseAlias,CRC16,CRC32"

- NoId:** removes the ID of each entry (only for none XML structures)
- NoDate:** removes the Date of each entry (only for none XML structures)
- NoTime:** removes the Time of each entry (only for none XML structures)
- NoNames:** removes the first row with variable names (only for none XML structures)
- NoSec:** removes the seconds of the time stamp
- UseAlias:** adds the variable alias names to the XML logfile output
- CRC16:** calculates a CRC16 over the logfile output and writes it under the data (only for CSV). See chapter 4.6.
- CRC32:** calculates a CRC32 over the logfile output and writes it under the data (only for CSV). See chapter 4.6.

interval:

Expected log interval. If the time between two log entries exceeds the **tolerance** interval, an entry with the content of **string** will be added with the timestamp of the last entry + **interval**.

Can be used to create a fixed log content length if the Tixi Device was switched off or the logging was stopped for a while.

tolerance:

Maximum time between two log entries before **string** will be added.

string: String added to the log output if **tolerance** interval was exceeded (only for CSV)

format).

variables:

List of variables (separated by comma) to be selected for logfile output. The variable names must match the tag names of the record entries.

Formats:

See chapter 4.6 for format options like "tabstart", "tabend" etc.

Return:

If no error (command is processed), type XML:

```
<ReadLog _="Journal" range="all">
<ReadLog>
  <LogEntry_ID _="Date,Time">
    <Element _="Logged Data" Name="Alias"/>
    ...
  </LogEntry_ID>
</ReadLog>
```

If no error (command is processed), type CSV:

```
<ReadLog _="Journal" range="all" type="CSV">
<ReadLog>
  <LogData>
    ID;Date;Time;Element;Element;...;...
    LogEntry_ID;Date;Time;Logged Data;Logged Data;...;...
  </LogData>
</ReadLog>
```

If no error (command is processed), type HTML:

```
<ReadLog _="Journal" range="all" type="HTML">
<ReadLog>
  <LogData>
    <table border="1">
      <tr>
        <td>ID</td>
        <td>Date</td>
        <td>Time</td>
        <td>Element</td>
        <td>Element</td>
        ...
      </tr>
      <tr>
        <td>LogEntry_ID</td>
        <td>Date</td>
        <td>Time</td>
        <td>Logged Data</td>
        <td>Logged Data</td>
        ...
      </tr>
    </table>
  </LogData>
</ReadLog>
```

Elements:

LogEntry_ID:

ID identifying the logfile entry.

Date:

The creation date "YYYY/MM/DD" of the logfile entry.

Time:

The creation time "hh:mm:ss" of the logfile entry.

Element:

Description of logged element, e.g. variable name of record definition or alias name.

Alias:

Alias name of the variable. Only displayed if **UseAlias** flag is used for XML output.

Logged data:

Data of logged element, e.g. variable values or event/job results.

On error (command is not processed):

see default error frame (chapter 2.4.4)

Range Examples:

Get the entries with the IDs 4 – 8.

```
[<ReadLog _="Journal" range="ID_4-ID_8" ver="y" />]
```

Get the entry with the ID 5.

```
[<ReadLog _="Journal" range="ID_5" ver="y" />]
```

Get the entries within a timespan.

```
[<ReadLog _="Journal" range="12:00:00-13:20:00" />]
```

Get the entries within a timespan on a specific day.

```
[<ReadLog _="Journal" range="2004/12/24,12:00:00-2004/12/24,13:20:00" />]
```

Get last 10 entries.

```
[<ReadLog> _="Journal" range="#10-" />
```

Getting Timespans. Assume that the actual time is 12:23

Get entries from last 24h (exact).

```
[<ReadLog> _="Journal" range="last 24 hours" />
```

This will return all entries from 12:23 previous day to 12:22 actual day.

Get entries from last 24h (smooth).

```
[<ReadLog> _="Journal" range="previous 24 hours" />
```

This will return all entries from 12:00 previous day to 11:59 actual day.

Clear – Delete content of logfiles**Syntax:**

```
<Clear Log="Logfiles" />
```

Description:

Deletes the content of one or several logfiles.

Parameters:**Logfiles:**

Logfile or list of logfiles to be deleted. To delete several logfiles with one command, separate the logfile names by comma. Use an asterisk "*" to delete all logfiles.

If no error (command is processed):

```
<Clear/>
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Clear logfiles "JobReport" and "Event".

Client sends: [<Clear Log="JobReport,Event" ver="y" />]

Tixi Device responds: [<Clear />]

2.5 TiXML on SD-Card

Tixi Devices with SD-Card option (Hx400) can be configured and controlled by TiXML commands saved on a SD-Card.

A file with the name "config.txt" must be created, containing following structure:

```
<Batch ResultFile="RESULT.TXT" >
  List of TiXML commands
</Batch>
```

The ResultFile attribute defines the file where the TiXML command results will be written to. The file will automatically be created (if not existing) or overwritten during processing. The file name must be in 8.3 notations. If omitted, RESULT.TXT will be the default name.

The List of TiXML commands may include an unlimited number of commands (see chapter 2.4 for valid commands) and can therefore be used for configuration, controlling or collecting logged data.

A login to the device may be necessary (see chapter 3.6).

The TiXML frame brackets [] must not be included.

Examples:

Config.txt to collect logged data:

```
<Batch ResultFile="datalog.csv">
  <ReadLog _="Datalogging_0" flags="NoID" type="CSV" range="all" ver="v"/>
</Batch>
```

Config.txt to configure address book. The Signal-LED will be switched on/off to indicate the user when the processing of the file is finished. During configuration, the Tixi Device will be set to stop mode:

```
<Batch>
  <Login/>
  <Set _="/Process/Program/Mode" value="Stop" ver="y"/>
  <Set _="/Process/MB/SignalLED" value="1" ver="y"/>

  <SetConfig _="TEMPLATE" ver="y">
    <AddressBook>
      <MySelf>
        <Email _="tixi-modem@tixi.com"/>
      </MySelf>
      <Contact_0>
        <Email _="tixi-support@tixi.com"/>
      </Contact_0>
    </AddressBook>
  </SetConfig>

  <Set _="/Process/MB/SignalLED" value="0" ver="y"/>
  <Set _="/Process/Program/Mode" value="Run" ver="y"/>
</Batch>
```


3 Main XML Databases

This chapter describes the different databases used by a basic project creation.

3.1 Introduction

We recommend the use of "TICO – TiXML Console" to easily create databases out of the included template library.

If you use any terminal or self written program, we recommend stopping the job processing before sending the first SetConfig:

```
[<Set _="/Process/Program/Mode" value="Stop" ver="y"/>]
```

After uploading the project/database you have to start the job processing (this is automatically done by modem reset):

```
[<Set _="/Process/Program/Mode" value="Run" ver="y"/>]
```

3.1.1 References

The great advantage of XML databases is the possibility of linking (cross reference) the content and save configuration time. For example, instead of configuring the same fax number in each of the message job templates, you only have to make a reference to the fax number in the address book.

If you change the number in the address book, it's automatically changed for all related message job templates.

A reference to a value is introduced by the reference symbol ® (written as XML entity ®) followed by the path to the value. The path has to be ended by a semicolon if text is following.

Depending on the database location, you have to use different reference paths.

Some examples:

- Reference to a parameter received by EventState, DoOn or incoming message:
®~/parameter;
- Reference within same database
®/D/Group/entry;

Example:

Reference inside the TEMPLATE database, e.g. from MessageJobTemplate to AddressBook:

```
&#xae;/D/AddressBook/Contact_0;
```

or MessageText to another MessageText:

```
&#xae;/D/UserTemplates/LocationText;
```

- Reference accross databases
®/DATABASE/Group/entry;

Example:


Reference from the TEMPLATE database to USER database:

```
&#xae;/USER/Location/PhoneNumber;
```

- Path to a variable, e.g. from EventHandler Set command or within process variable:
/Process/Bus1/Device_0/Variable_0 (without reference symbol!)
- Project-Structure related Path from EventHandler to a MessageJobTemplate:
MessageJobTemplates/Alarm_0 (without reference symbol!)

Alternative reference:

If a reference can not be resolved by the job processor, the job will be canceled with an error log entry. Therefore it is sometimes usefull to cascade references with alternative values, which are separated by comma, e.g.:



Alternative values are only possible for references with “®” but not for paths (e.g. EventHandler “set” path, EventHandler “sendmail” path) instructions.

3.1.2 Time parameters

Every time value without unit will be interpreted as “milliseconds”.

A unit can be added to every value to use larger time periods:

“s” for seconds, “m” for minutes, “h” for hours, “d” for days.

Example:

```
<Delay _="500"/> 500ms delay
```

```
<Delay _="30s"/> 30s delay
```

3.2 Dialling Properties of the Location

The properties, which describe the telephone connection to which the device is attached, are called "Location". This is because these properties depend on the place where the Tixi Alarm Modem is installed.

Database path: /USER/Location

```
<Location>
  <CountryPrefix _="00"/>
  <CountryCode _="49"/>
  <AreaPrefix _="0"/>
  <AreaCode _="30"/>
  <LocalDialPrefix _="" />
  <LongDialPrefix _="" />
  <PhoneNumber _="12345678"/>
  <InternalDialPrefix _="" />
  <ExtensionNumber _="" />
  <DialRules _="Tone,NoWaitForDialTone"/>
  <NumberFormat _="*" />
</Location>
```

Insert your own data

Name	Description
CountryPrefix	Country prefix for international calls, e.g. 00 inside Germany.
CountryCode	Country code of location without CountryPrefix, e.g. 49 for Germany
AreaPrefix	Area prefix for domestic long distance calls, e.g. 0 for Germany, 1 for the U.S.A.
AreaCode	Area code of location without AreaPrefix, e.g. 30 for Berlin GSM-Note: If you are using a Tixi Alarm Modem GSM please enter the GSM network code of your GSM provider, e.g. German T-Mobile: 171 German Vodafone: 172 German Eplus: 177 etc.
LocalDialPrefix	PBX prefix to get an outside line for local calls (to dial numbers with same area code). May be left blank.
LongDialPrefix	PBX prefix to get an outside line for long distance calls (to dial numbers with different area code). May be left blank.
PhoneNumber	Local phone number of the location without any prefix or area code. If no PBX is used this is the complete phone number (e.g. 123456500). If an PBX is used , this is the phone number of the PBX. In this case, the complete phone number will be created by this field and the <code>ExtensionNumber</code> .
InternalDialPrefix	PBX prefix to receive a dial tone for internal calls. May be left blank.
ExtensionNumber	Last digits of the phone number defined by the PBX extension.
DialRules	Defines the Tixi Alarm Modem dial method. <i>DialMode: DialToneRecognition</i> DialMode (used for PSTN devices only): Tone.... Tone dialling Pulse.... Pulse dialling DialToneRecognition: WaitForDialTone.... Wait for a dial tone. NoWaitForDialTone.... Do not wait for a dial tone. e.g.: Use tone dialling and do not wait for dial tone: <code>Tone, NoWaitForDialTone</code>
NumberFormat	Specifies how the modem will dial the recipients number * Network related (default) If it's a GSM modem, all numbers are dialed canonical. If it's a PSTN/ISDN modem, all numbers are dialed depending on the location settings. n location related (PSTN only) All numbers are dialed depending on the location settings (see chapter 3.2.1). c canonical (GSM only) All numbers are dialed canonical (e.g. +49172123456).

During development define this location for the place where you will test the Tixi Alarm Modem. Later at the place where the Tixi Alarm Modem is installed, change the location settings for this place. Due to the use of international phone numbers you don't need to change the phone numbers in the ISP's data or in the address book to add or remove dial-prefixes etc. Simply change the Location and Tixi Alarm Modem dials the proper number.

From our experience, defining a bad location is a most common error in configuring Tixi Alarm Modem. Please follow the following hints provided.

First check whether you are using a telephone extension or not.

If no PBX is used the configuration is very simple:

1. Select the template corresponding to the country. In this template all settings for the country should be predefined (`CountryCode`, `AreaCode`, `CountryPrefix`, `AreaPrefix`).
2. Set all `DialPrefix` fields as blank entries "".
3. Also leave the `ExtensionNumber` blank.
4. Insert the `PhoneNumber`.
5. Insert the `DialRules`: typically `Tone, NoWaitForDialTone`.

If a PBX is used the configuration depends on the properties of the PBX.

1. Select the template corresponding to the country. In this template all settings for the country should be predefined (`CountryCode`, `AreaCode`, `CountryPrefix`, `AreaPrefix`).
2. The PBX may require some prefixes you have to dial to get an outside line. Furthermore, some PBX require different prefixes for different call types; others require the same or nothing for the call types. Our location defines three call types:
 - a). Internal call (`InternalDialPrefix`): the call resides inside the PBX.
 - b). Local call (`LocalDialPrefix`): the call has the same area code as the location.
 - c). Long distance Call (`LongDialPrefix`): the call goes outside the area code.

When the same prefix is used for different call types, insert the prefix in each prefix field. When no prefix is used for a call type, leave it blank.

3. PBX typically define a range of internal numbers, which can be called to get a person inside the PBX, e.g. from the number 123456-200 you can dial 300 instead of 123456-300. In this example the last three digits are called `Extension Number` and the first five digits are the phone number (the same for all extensions inside the PBX).

If your extension defines internal (short) numbers, fill both fields `PhoneNumber` and `ExtensionNumber` with the right numbers.

4. Insert the `Dial Rules`: typically `Tone, NoWaitForDialTone`.

The value `Pulse` for pulse dialling method is used by old PBX only. But check whether your PBX supports dial tone recognition or not.

3.2.1 How the Modem dials

There are several events where the Tixi Alarm Modem has to dial a phone number, e.g. for internet connections, fax or SMS.

All these recipient numbers have to be inserted in canonical (international) format like `+CountryCode-AreaCode-PhoneNumber`

Referring to the location details, the modem checks if the recipients number is

- in the same country
- in the same area
- within the same PBX

and therefore dials only the necessary part of the number.

Example:**1. The Modem location is set to**

```

<Location>
  <CountryPrefix _="00" />
  <CountryCode _="49" />
  <AreaPrefix _="0" />
  <AreaCode _="30" />
  <LocalDialPrefix _="" />
  <LongDialPrefix _="" />
  <PhoneNumber _="12345678" />
  <InternalDialPrefix _="" />
  <ExtensionNumber _="" />
  <DialRules _="Tone,NoWaitForDialTone" />
</Location>

```

- a) If the recipient is "+49-30-5555555" the modem will only dial "5555555" (phone number) because the CountryCode and AreaCode are the same.
- b) If the recipient is "+49-40-4444444" the modem will dial "0 40 4444444" (area prefix, area code and phone number) because the CountryCode is the same but the AreaCode is different.
- c) If the recipient is "+44-170-3333333" the modem will dial "00 44 170 3333333" (country prefix, country code, area code and phone number) because all settings are different.

2. The Modem location is set to

```

<Location>
  <CountryPrefix _="00" />
  <CountryCode _="49" />
  <AreaPrefix _="0" />
  <AreaCode _="30" />
  <LocalDialPrefix _="9" />
  <LongDialPrefix _="1" />
  <PhoneNumber _="12345678" />
  <InternalDialPrefix _="" />
  <ExtensionNumber _="" />
  <DialRules _="Tone,NoWaitForDialTone" />
</Location>

```

- a) If the recipient is "+49-30-5555555" the modem will only dial "9 5555555" (local dial prefix and phone number) because the CountryCode and AreaCode are the same.
- b) If the recipient is "+49-40-4444444" the modem will dial "1 0 40 4444444" (long dial prefix, area prefix, area code and phone number) because the CountryCode is the same but the AreaCode is different.
- c) If the recipient is "+44-170-3333333" the modem will dial "1 00 44 170 3333333" (long dial prefix, country prefix, country code, area code and phone number) because all settings are different.

3. The Modem location is set to

```
<Location>
  <CountryPrefix _="00"/>
  <CountryCode _="49"/>
  <AreaPrefix _="0"/>
  <AreaCode _="30"/>
  <LocalDialPrefix _=""/>
  <LongDialPrefix _=""/>
  <PhoneNumber _="123456"/>
  <InternalDialPrefix _="!"/>
  <ExtensionNumber _="789"/>
  <DialRules _="Tone,NoWaitForDialTone"/>
</Location>
```

a) If the recipient is "+49-30-123456-111" the modem will only dial "! 111" (internal dial prefix !=FLASH, and extension number) because the CountryCode, AreaCode and phone number are the same.

3.3 Device's User Data

The Tixi Device has a database called "USER" which contains some modem related settings. This includes the settings for GSM, redial and for call acceptance.

Database path: /USER/USER

```
<USER>
  <Handshake _="RTSCTS"/>
  <InitString0 _="ATX3M1L1"/>
  <ModemProtocol _="default"/>
  <IsdnDataChannelID _="*"/>
  <IsdnFaxChannelID _="*"/>
  <DChannelProtocol _="DSS1"/>
  <ModemListenMode _="OFF"/>
  <ModemParams _=""/>
  <BoxName _="Tixi Device-ID"/>
  <BoxNumber _="+49-30-1234567"/>
  <TimeZone _="+0100"/>
  <MaxDialAttempts _="3"/>
  <MemForInMails _="0"/>
  <RedialDelay _="60s"/>
  <RingCounter _="0"/>
  <LogInComCalls _="1"/>
  <AccountQuery _="*100#"/>
  <AccountExpiry _="*101*1#"/>
  <AccountResponse _="amount:Guthaben;;valid:am;format:dd.mm.yyyy"/>
  <Pin1 _="1234"/>
  <GPRS _="Off"/>
</USER>
```

Insert your own data

Name	Description
Handshake	COM-Port Handshake for TiXML communication. RTSCTS Hardware Handshake (default) XONXOFF Software Handshake
BoxName	Name of the Tixi Device when it is used for sending Express-E-Mail and as well in Fax message headlines. The BoxName is also used as the hostname for DHCP entries.
BoxNumber	Canonical phone number of the Tixi Alarm Modem. It identifies the phone network connection of Tixi Alarm Modem when it is used for Express-E-Mail as well in Fax message headlines. Syntax: CountryIDAreaCodeLocalPhoneNumber
TimeZone	Time zone where the Tixi Device is located. The value is the difference in hours and minutes from GMT. Syntax: +/-HHMM
MaxDialAttempts	Maximum number of dial attempts 1...10 . 1 is recommended as redial should rather be configured by the SendMail command. See chapter 3.7.1.
RedialDelay	Time to wait between dial attempts in seconds 30s...255s The timer starts after the failed sendmail.
IsdnDataChannelID	Multiple Subscriber Number (MSN) for ISDN data calls. * answers on all numbers (default). nn MSN of the device (up to 16 digits)
RingCounter	Number of rings until Tixi Alarm Modem answers an incoming call. This doesn't affect SMS receipt. 0 Ignore all incoming calls 1...10 ring counter.
LogInComCalls	Enables the logging of all incoming calls into the "IncomingMessage" Logfile. 0 disable logging calls 1 enable logging calls
AccountQuery	String to query the SIM card credit Germany: e.g. *100# (D1,D2,O2,Eplus) empty: deactivated Outside germany <i>AccountResponse</i> may be required.
AccountExpiry	String to query the SIM card expiration date, not necessary if identical to AccountQuery. Germany: e.g. *100# (D2,Eplus), *101*1# (D1), *102# (O2) empty: deactivated <i>AccountResponse</i> required.
AccountResponse	Response parser for AccountQuery and AccountExpiry. Format: "amount:[word before credit];valid:[word before expiry];format:[expiry format]"
Pin1	The PIN for the GSM – modem phone card.
Pin2	A second PIN for the GSM – modem phone card, if required.
GPRS	Switches between GSM-CSD and GPRS functionality. Off: GPRS deactivated (default) On: GPRS activated Note: If GPRS is activated, only TCP/IP communication is possible (Email, HTTP, TFTP, TiXML). Services for sending SMS, Fax, Express-E-Mail, Pager and dial in for TransMode or remote configuration are inaccessible.

Note: The GSM PIN is not deleted by a factory reset! To delete the GSM PIN it is necessary to overwrite it with an empty value.

3.4 Address Book

Each message created by the Tixi Device must include a sender and one or more recipient addresses. The Tixi Device provides an address book for all recipients and senders of messages. So if you create different messages which are sent to the same recipient you can use the same contact in the message job templates. This is a simple way to manage your addresses and reduce errors on configuration.

We recommend using not more than 100 addressbook entries.

The address book is stored in the 'TEMPLATE' database. Each contact can contain addresses for different transports (SMTP, SMS, TextFax etc).

Database path: /TEMPLATE/AddressBook

```
<AddressBook>
  <MySelf>
    <Email _="user@domain.com" />
    <Express-Email _="TAM+49-30-1234567" />
    <SMS_No _="+49-30-1234567" />
    <Fax _="+49-30-1234567" />
  </MySelf>
  <Contact_0>
    <Email _="office@domain2.com" />
    <Express-Email _="TAM+49-30-7654321" />
    <SMS_No _="+49-174-1234567" />
    <SMS_Provider _="D2" />
    <Fax _="+49-30-7654321" />
    <CityRuf _="3949000" />
    <Pager_Provider _="CityRuf" />
    <URL _="http://www.devicecontrolnet.com/notification/" />
    <URLPort _="80" />
    <User _="WebAccess" />
    <Password _="WebAccessPwd" />
  </Contact_0>
</AddressBook>
```

Contacts

Contact

Syntax:

```
<ContactName>
  List of Address Entries
</ContactName>
```

Description:

Attribute group which defines a symbolic address as a contact. The symbolic address can be used as sender and recipient of messages.

Elements:

ContactName:

Name of the contact. This is the symbolic address inserted in the message job templates. It must be unique in the address book.

List of Address Entries:

List of attributes defining the addresses of the contact for the different transports.

Example:

Contact 'MySelf' used as sender for the messages. 'MySelf' is the symbolic address. An internet address, a SMS address a Fax address are defined.

```
<MySelf>
  <Email _="tam@domain.com" />
  <Express-Email _="TAM+49-30-1234567" />
  <SMS_No _="+49-30-1234567" />
  <Fax _="+49-30-1234567" />
</MySelf>
```

There are several address entries. These entries correspond to a certain message transport type (SMTP, FAX, SMS, Express-E-Mail, CityRuf, HTTP notification). You can insert one set of address entries for each transport type within one contact.

```
<Contact_0>
  <Email _="office@domain.com" />
  <Express-Email _="TAM+49-30-7654321" />
  <SMS_No _="+49-174-1234567" />
  <SMS_Provider _="D2" />
  <Fax _="+49-30-7654321" />
  <URL _="http://www.devicecontrolnet.com/notification/" />
  <URLPort _="80" />
  <User _="WebAccess" />
  <Password _="WebAccessPwd" />
</Contact_0>
```

Address entry

Name	Description
Email	Internet address of the contact (e.g. tam@domain.com). If an AddressBook entry contains more than one email entry, the email will be sent to all receivers.
SMS_No	SMS telephone number of the contact (e.g. +49-161-1234567). May be entered in short number format (e.g. "8888") or canonical format, if the NumberFormat in the SMS-Provider is configured (see chapter 3.10).
SMS_Provider	Name of the SMS provider used when the contact is a SMS recipient. In this case the related SMS dial in number of the provider is used. See chapter 3.10
Fax	Fax number of the contact (for example +49-30-1234567) written in canonical format: <i>+CountryCode-AreaCode-LocalPhoneNumber</i>
Express-Email	Express-E-Mail address of the contact (for example TAM+49-30-1234567). This is inserted into the header of Express-E-Mails. It consists of the Tixi user name and the international phone number of the receiving Tixi Device. The canonical phone number format is: <i>+CountryCode-AreaCode-LocalPhoneNumber</i>
CityRuf	CityRuf number of the contact, for example 3949000.
Pager_Provider	Name of the pager provider used when the contact is a pager recipient. In this case the related pager dial in number of the provider is used. See chapter 3.10
URL	URL of the HTTP server that receives and processes upcoming alarms. A slash "/" must be at the end of the URL, if a folder ist requested.
URLPort	TCP/IP port of the HTTP server.
User	Username to get access to the webserver specified by URL.
Password	Password to get access to the webserver specified by URL.

For each recipient of your messages you have to prepare the addresses of the transports by which you want to send messages to him.

3.5 Internet Access (ISP)

The Tixi Device provides the ability to send emails via the Internet. Tixi Data Gateway does this via its LAN connection and Tixi Alarm Modem calls a dial-in node of an Internet Service Provider (ISP) and establishes a TCP/IP connection to the Internet. This TCP/IP connection is embedded into a Point to Point Protocol (PPP) connection which is established between Tixi Alarm Modem and the dial-in node of the ISP. Tixi Alarm Modem GSM may also use a GPRS connection to communicate with the internet.

When the TCP/IP connection is ready the Tixi Device uses the SMTP server of the provider to send email. The related ISP data has to be configured in the 'ISP' database in the 'ISP' section.

Database path: /ISP/ISP

```

<ISP>
  <PPPCComm>
    <PPPUserName _="user" />
    <PPPPassword _="pass" />
    <AuthentFlags _="3" />
    <FirstDNSAddr _="194.25.2.129" />
    <SecondDNSAddr _="193.158.131.19" />
    <KeepConnected _="24h" />
    <EchoInterval _="1m" />
    <EchoTimeout _="30s" />
    <EchoTarget _="www.google.de" />
    <OnTCPError _="KeepConnected" />
  </PPPCComm>
  <SMTP>
    <Flags _="ESMTP" />
    <mailserver_name _="domain.com" />
    <mailserver_ip _="192.168.0.1" />
    <Port _="25" />
    <Username _="user" />
    <Password _="pass" />
    <ownhost_ip _=" [&#xae; /Ethernet/AssignedIP; ]" />
  </SMTP>
  <POP3>
    <mailserver_name _="domain.com" />
    <Port _="110" />
    <Username _="user" />
    <Password _="pass" />
    <Flags _="DontDelete" />
    <Filter _="string" />
    <Lines _="50" />
  </POP3>
  <Modem>
    <RemotePhoneNumber _="+49-30-1234567" />
    <MediaType _="DATA" />
    <ModemProtocol _="syncPPP" />
  </Modem>
  <GPRS>
    <APN _="web.vodafone.de" />
  </GPRS>
</ISP>

```

Insert your own data

Name	Description
PPPUserName	User name of the PPP log-in (provided by the ISP).
PPPPassword	Password of the PPP log-in (provided by the ISP).
AuthentFlags	PPP authentication method: 1 PAP (plain text) only 2 CHAP (challenge handshake) only 3 auto
FirstDNSAddr	IP of DNS #1 (provided by your ISP, omit if dynamic)
SecondDNSAddr	IP of DNS #2 (provided by your ISP, omit if dynamic)
KeepConnected	Time the Tixi Alarm Modem will stay online after successfully completing the last message job during the connection. Usefull to get a permanent GPRS connection initiated by "Connect" EventHandler (see chapter 3.7.1).
EchoInterval	Interval in which the modem will ping the EchoTarget to check the IP communication.
EchoTimeout	Timeout after which the IP communication check failes.
EchoTarget	ICMP host used by the IP communication check. Can be specified as FQDN or IP address.
OnTCPErrors	Controls the behaviour on TCP errors, if connection is kept online using "KeepConnected". Disconnect: Reestablish connection on TCP errors KeepConnected: Ignore TCP errors
SMTP/Flags	Enter value "POPBeforeSMTP" if you need POP3-before-SMTP authentication. Enter value "ESMTP" if you need SMTP authentication.
mailserver_name	Domain name of senders email address or name or IP address of POP3/SMTP server.
mailserver_ip	Name or IP address of POP3/SMTP server.
Port	TCP port of the SMTP/POP3 server. Defaults: POP3: 110 SMTP: 25
SMTP/Username	Only for ESMTP: User name for the ESMTP server (provided by the ISP)
SMTP/Password	Only for ESMTP: Password of the ESMTP server (provided by the ISP)
ownhost_ip	Hostname or IP of the the Tixi Device, used by HELO command
POP3/Flags	Enter value "DontDelete" to prevent deleting mails at ISP.
POP3/Username	User name for the POP3 server (provided by the ISP)
POP3/Password	Password of the POP3 server (provided by the ISP)
Filter	Filter word to be found within the collected email, otherwise the modem will ignore the email.
Lines	Number of lines the modem will search for the filter word.

RemotePhoneNumber	<p>International phone number to call the ISP's dial-in node or code for GPRS connection.</p> <p>The format of the international phone number is: +CountryCode-AreaCode-LocalPhoneNumber</p> <p>GSM Note: Most ISP offer a different phone number for calls from the GSM network. Please contact your ISP to get the GSM number if you are using a Tixi Alarm Modem GSM.</p> <p>Common GPRS dialup code: *99***1#</p>
ModemProtocol	<p>ISDN/GSM-Protocol used to connect to the ISP.</p> <p>Values:</p> <p>"default" (uses V.32 or X.75-NL)</p> <p>"X.75-NL"</p> <p>"syncPPP"</p> <p>"V.120"</p> <p>"V.110" (for GSM)</p> <p>"X.75-T.70"</p> <p>"ML-PPP"</p> <p>"HDLC-Transp"</p> <p>"BYTE-Transp"</p>
GPRS/APN	Access Point Name of the GPRS backbone.

Note: For Tixi Data Gateway the ISP groups "PPPCom" and "Modem" must be created (may be empty) for historical reasons.

3.6 Access rights

You can protect the access to the Tixi Device against unauthorized access. The factory configuration of the Tixi Device has no protection activated, so if you forget the password, you can always gain access to Tixi Device by using the hardware factory reset.

There are three levels of protection:

- **no protection** (no Login is required, **factory default**)
- **password** protection (a password is required for login, user name is empty)
- **user aware** protection (a user name and a password are required for login)

Login with CallerID verification is only available for remote switching (see chapter 9.5).

Within the AccRights group it is possible to define access groups with different access types (services) and assign users to these groups. The password may be encrypted (Base64+ThreeWay or Keyed-MD5).

The "AccRights" are part of the USER database:

Database path: /USER/AccRights

Access Rights

Syntax:

```
<AccRights>
  <Groups>
    <Groupname>
      <Service AccLevel="Level" />
    </Groupname>
  </Groups>
```

```

<User>
  <Username Plain="PlainPwd" Group="UserGroup" />
  <OA_nnn Plain="PlainPwd" Group="UserGroup" />
  <Username Pwd="Pwd" Group="UserGroup" Callback="number" />
  <Def_Service Pwd="Pwd" Group="UserGroup" />
</User>
<AccRights>

```

Description:

Configuration of access rights. Each user is assigned to an access group. The access group specifies the accessible services and access levels.

As soon as a "username" is defined, all services are locked.

To unlock services for everyone a "Def_" user without password has to be defined for these services.

A user also gets access to all services that are not explicit denied within his group. To prevent this, these services has to be locked by AccLevel="-1".

If a user is member of two groups and a service is disallowed in his first group but allowed or not specified in his second group, he will get access. Disallowed services have to be blocked in all assigned groups.

For TSAdapter access rights at least an user ADMIN has to be configured.

Elements:

Groupname: Name of an access group. Several access groups with different services may be defined.

Service: Service that may be accessed by this group:

LocalLogin	local access via serial port
RemoteLogin	access via dialin
EthernetLogin	access via TCP/IP (TiXML)
CardLogin	access via SD-Card
Message	access via incoming message
WebServer	access to the webserver
TFTP	access via TFTP
TSAdapter	access via TS-Adapter (only Hx71/Hx76)

Level: Access Level of this group for the specified service.

- 1 access protection disabled
- 1 access protection enabled
- >1 group access level

Username: Name of an user with access rights or email alias (see chapter 9.5 for more details).

OA_nnn: CallerID or email address used to secure remote switching (see chapter 9.5 for more details).

PlainPwd: Password assigned to an user (plain text). Maximum 79 characters, for service "message" maximum 25 characters.

Pwd: Password assigned to an user (encrypted, Base64+ThreeWay or Keyed-MD5). Maximum 59 characters.

UserGroup: List of groups (see groupname) the user will have access to

(separate by comma).

Number:	Callback number for TSAdapter service (only devices with MPI interface)
Def_Service:	Default user for each service. Replace "Service" by service name. Default user will be used if login username is unknown or empty.

Example:

Three groups are defined: Group "login" is used for configuration access to the device, group "RemoteControl" is used for processing incoming messages, group "Step7" is used for Siemens S7-300/400 TeleService access.

User Tom is member of group "RemoteControl", therefore he can send messages to the Tixi Device but he cannot login to the device.

Remote switching with the password "TIXI" is only valid from a mobile phone with the number +491721234567.

User Paul is member of group "Login" and "RemoteControl", therefore he has full access to all services.

The technicians "Martin" and "Daniel" are not defined but they may use the passwords "Winter" for remote control and "Summer" for local login (default access).

User ADMIN is able to access a connected S7-300/400 PLC via callback using the Step7 TeleService software.

```
<AccRights>
  <Groups>
    <Login>
      <LocalLogin AccLevel="1"/>
      <RemoteLogin AccLevel="1"/>
      <EthernetLogin AccLevel="1"/>
      <CardLogin AccLevel="1"/>
      <Message AccLevel="-1"/>
      <WebServer AccLevel="-1"/>
      <TFTP AccLevel="-1"/>
      <TSAdapter _="-1"/>
    </Login>
    <RemoteControl>
      <Message AccLevel="1"/>
      <WebServer AccLevel="10"/>
    </RemoteControl>
    <Step7>
      <TSAdapter _="1"/>
    </Step7>
  </ Groups>
  <User>
    <Tom Plain="Spring" Group="RemoteControl" />
    <OA_491721234567 Plain="TIXI" Group="RemoteControl" />
    <Paul Pwd="Agshezg435G73gg723==" Group="Login,RemoteControl" />
    <Def_RemoteLogin Plain="Winter" Group="RemoteControl"/>
    <Def_LocalLogin Plain="Summer" Group="Login"/>
    <Def_CardLogin Plain="Summer" Group="Login"/>
    <ADMIN Plain="Autumn" Group="Step7" Callback="+491721234567"/>
  </User>
</AccRights>
```

3.7 Event Handler

The general instructions are defined in the '**EVENTS**' database. The content of this database configures the event handler of the Tixi Device. The database contains some attribute groups. Each group is named by an event and contains processing instructions as attributes. These instructions are processed by the event handler from top to bottom. We recommend using not more than 100 events.

The following example shows the configuration for two events 'Alarm_0' and 'Alarm_1', each has its own commands:

Database path: EVENTS/EventHandler

```
<EventHandler>
  <Alarm_0>
    <SendMail _="MessageJobTemplates/Alarm_0" />
    <SendMail _="MessageJobTemplates/Alarm_1" />
  </Alarm_0>

  <Alarm_1>
    <SendMail _="MessageJobTemplates/Alarm_1" />
  </Alarm_1>
</EventHandler>
```

Event Handler Group

Event Handler Commands

Event Handler Configuration

Syntax:

```
<EventName>
  CommandList
</EventName>
```

Description:

Attribute group which defines the instructions to be processed each time the event handler is triggered by a DoOn command or an EventState (chapter 6.2).

Elements:

EventName:

Name of the event triggered by the DoOn command or by the process subsystem (see chapter 0) on the event parameters).

CommandList:

List of Attributes describing commands for the event handler which are processed from top to bottom (see next chapter).

Example:

Event handler configuration for the 'Alarm_0' event. It lets the event handler send an alarm message defined by the message job templates 'Alarm_0' and set an output port.

```
<Alarm_0>
  <SendMail _="MessageJobTemplates/Alarm_0" />
  <Set _="/Process/MB/IO/Q/P0" value="1" />
</Alarm_0>
```

3.7.1 Commands

SendMail Command**Syntax:**

```

<SendMail _="Template">
  <OnOK _="OnOKEvent" />
  <OnError _="OnErrorEvent" />
  <MaxRepeat _="MaxRepetitions" />
  <Interval _="IntervalTime" />
  <ConfirmID _="ID" />
  <Timeout _="Timeout" />
  <OnTimeout _="OnTimeoutEvent" />
  <Delay _="DelayTime" />
  <Condition _="Variable" />
  <Priority _="Priority" />
  <KeepConnected _="OnlineTime" />
</SendMail>

```

Description:

Event handler command. It lets the event handler send a message using the given message job template (see chapter 3.9).

Elements:**Template**

Name of the message job template which is used to generate the message job for this event.

OnOKEvent

Name of the event to be triggered when the sending of the **Template** message job didn't fail or a confirmation message was received. If empty or omitted, nothing happens in that case.

OnErrorEvent

Name of the event to be triggered when the sending of the **Template** message job failed. If empty or omitted, nothing happens in that case.

MaxRepetitions

Determines how many attempts are made to execute the **Template** message job before **OnOK**, **OnError** or **OnTimeout** will be triggered.
(Requires **Interval**)

IntervalTime

Determines the delay between the attempts of **MaxRepetitions**. **Default** is 30s. Timer starts after failed sendmail.

ID

The ID (0-65533) is used as identification for the message if a confirmation is requested. See next page for details about message confirmation.

Timeout

Determines after which time the **OnTimeout** event is invoked.
Timer starts with begin of sendmail.

OnTimeoutEvent

Name of the event to be triggered when the message was successfully sent but no confirmation was received after the time determined in **Timeout**. If empty or omitted, nothing happens in that case.

DelayTime

Delays the sending of the message for the given time.
Timer starts with created message.

Variable

Condition for message dispatch. If the bit variable value specified by the path is 1 (TRUE), the message will be sent immediately. If the value is 0 (FALSE) the sending of the message will be delayed according to **DelayTime**.

Supported variable types: External variables, process variables, elements of the "/Process/MB/" tree excluding its subfolders.

Not supported variable types: database entries, Tixi Device I/Os.

The condition can be checked again by using the EventHandler command `CheckJobConditions` (see below).

Priority

Sets a priority for the alarm. If several alarms are activated at the same time, the device will send out the alarm with the highest priority (255 = highest) at first. Possible priorities: 1-255

OnlineTime

Defines how long the modem will keep the PPP connection established, after complete sending of the email. (SMTP only)

Example:

Event handler configuration for the 'Alarm_0' event. It lets the event handler send a message with priority 2 using the template 'Alarm_0'. If sending of the message fails two times, the alarm will be retrigged (loop). If it was sent successful, the Tixi Device will wait 10 minutes for a confirmation message. If the confirmation is missing, the alarm will be retrigged (loop).

```
<Alarm_0>
  <SendMail _="MessageJobTemplates/Alarm_0">
    <OnError _="Alarm_0"/>
    <MaxRepeat _="1"/>
    <Interval _="180s"/>
    <ConfirmID _="1"/>
    <Timeout _="10m"/>
    <OnTimeout _="Alarm_0"/>
    <Priority _="2"/>
  <SendMail/>
</Alarm_0>
```

Alarmlcascading with OnOK, OnError, OnTimeout

The three cascading commands can be used separately or combined.

- OnOK will be triggered if the message was sent successfully.
- OnError will be triggered if the message failed to create or transmit.
- OnTimeout will be triggered if the message was not acknowledged within timeout time.

Note:

- OnOK combined with OnTimeout will be triggered if the message has been acknowledged.
- OnTimeout will not be triggered if the message failed to create or transmit; therefore we recommend combining OnTimeout with OnError.

- If the `OnTimeout` timeout is shorter than the time for all `MaxRepeat` intervals, `OnTimeout` may be triggered even if the message was not sent successfully.

Confirmation of messages

A successfully sent message is not always a guarantee that the message has reached the recipient. To check this it is possible to request a confirmation from the recipient. The confirmation request is activated with the line `<ConfirmID _="ID" />` together with the `OnTimeout` attribute. The `ID` (0-65533) is an identifier for the sent message. The `ConfirmID` has to be included in the message in form of the “`_Fingerprint`” variable.

In this message text template the fingerprint is included in the subject of the message.

Database path: `/TEMPLATE/UserTemplates`

```
<Message_0>
  <Subject>
    <C _="Alarm! Confirmation needed: &#xae;~/_Fingerprint; "/>
  </Subject>
</Message_0>
```

An event handler using this message may have the following form:

Database path: `/EVENTS/EventHandler`

```
<Alarm_0>
  <SendMail _="MessageJobTemplates/Alarm_0">
    <Interval _="120s"/>
    <MaxRepeat _="2"/>
    <Timeout _="180s"/>
    <OnError _="ErrorLog"/>
    <OnTimeout _="TimeoutLog"/>
    <OnOK _="OKLog"/>
    <ConfirmID _="100"/>
  </SendMail>
</Alarm_0>
```

The message would look similar to this:

Alarm! Confirmation needed: CID2VeFhc7SyfaJMT/h

The confirmation is performed by the `Confirm` command of an event handler. There are two ways to invoke this event handler:

1. As a reply/forwarded message with the received subject included. The Tixi Device searches the text of received SMS and the subject lines of Email or Express-E-Mail messages for a fingerprint. In this fingerprint the confirmation ID, the date and the time is encrypted. So it is not possible for an unauthorized person to fake a confirmation. Furthermore, since every fingerprint is unique, it is not possible to use a received fingerprint twice for confirmation. If a fingerprint was received by the Tixi Device, it invokes a special system event `/System/Confirmation` (see chapter 3.7.3) which has to contain the `Confirm` command and may contain additional commands (such as logging or switching via `set` command).

Database path: /EVENTS/EventHandler/System

```

<EventHandler>
  <System>
    <Confirmation>
      <Confirm _="#xae;~/_ConfirmID" />
      <Log _="Event">
        <ConfirmID _="#xae;~/_ConfirmID" />
      </Log>
    </Confirmation>
    ...
  </System>
  ...
</EventHandler>

```

The Confirm command performs the confirmation of the message identified by the confirmation ID

The event parameter `_ConfirmID` is generated from the fingerprint

- The second way to invoke the confirmation event is to invoke it directly, using a `DoOn` command (chapter 0) or as an event in a command message (chapter 8) or via port change or service button (chapter 6).

Example:

The service button has to be pressed by the service personal to confirm the alarm and log the time of arrival.

Database path: /EVENTS/EventHandler/System

```

<EventHandler>
  <System>
    <OnButton>
      <Confirm _="101" />
      <Log _="Event">
        <Service _="Pressed upon alert by message 101" />
      </Log>
    </OnButton>
    ...
  </System>
  ...
</EventHandler>

```

ConfirmID of EventHandler

Set - Set System Property**Syntax:**

```
<Set _="Path" value="Value"/>
```

Description:

Set the *Value* of the system properties referred by the *Path*.

Note: There are many System Properties which are read only!

The System Properties are the set of data describing a Tixi Device. This includes administrative information like version numbers, licenses etc. which are defined at the creation time of the firmware, as well as information on the hardware configuration and the system state. The system state includes the system time, the system mode the states of the I/O ports, PLC variables etc. The configuration settings defined by the `SetConfig` are a part of the system state and therefore a part of the system properties. They can therefore also be accessed by the `Set` command. The difference to the `SetConfig` command is the way the data is addressed and the structure of the data set. Both commands use a slash separated path to address the data but “`Set`” addresses a single value only where “`SetConfig`” addresses complex values, for example a complete attribute group.

A second difference is in the data itself. All System Properties have a unique address defined by their path. Configurations contain parts which have no unique addresses: For example the PLC “`External`” could contain several “`Devices`” on a “`Bus`” which all have the same tag name “`Device`”. In this case an element can’t be addressed uniquely by a path. Therefore, not all elements of the configuration can be addressed by the `Set` command. Use `SetConfig` instead.

Parameters:**Path:**

Path which addresses the system properties. See chapter 12 for details on system properties.

Value:

Value to set. The syntactical format depends on the value to set. See chapter 12 for details on system properties.

The value may be created by references. The value string is limited to 80 characters.

Example:

Set the relais output of a Tixi Device.

```
<Switch_0>
  <Set _="/Process/MB/IO/Q/P2" value="1"/>
</Switch_0>
```

Log Command**Syntax:**

```
<Log _="LogfileName">
  LogData
</Log>
```

Description:

Creates an entry like this in the Journal database:

```
<ID_nnn time="_TimeStamp">
  LogData
</ID_nnn>
```

nnn:

Unique ID to address the log entry.

TimeStamp:

System time when the log entry has been written.

Note: The Log command can only be used for logfiles defined with the content type "XML".

Elements:**LogData:**

XML formatted data to be logged.

LogfileName:

Name of the logfile to be used. Must be defined in the LogDefinition database.

Note: You can insert attributes with references to any system property like.

```
<Input_P4 _="#xae;/Process/MB/IO/I/P4"/>
```

The reference will then be replaced by the corresponding value.

Example: Event handler logging the last power off and last power on time.

```
<SupportLog>
  <Log _="SupportLog">
    <PowerOff _="#xae;/TIMES/PowerOffTime;"/>
    <PowerOn _="#xae;/TIMES/PowerOnTime;"/>
  </Log>
</SupportLog>
```

BinLog Command**Syntax:**

```
<BinLog _="LogfileName">
  <ValueName _="Value"/>
  <ValueName _="Value"/>
  ...
</BinLog>
```

Description:

Creates a binary logfile entry with the structure of a given record.

Note: The BinLog command can only be used for logfiles defined with the content type "binary" and an assigned record.

Elements:**LogfileName:**

Name of the logfile to be used. Must be defined in the LogDefinition database.

ValueName:

Name of value defined in record database (option)

Value:

Value to be written into the structure. (option)

Example: Event handler logging a digital input if the Tixi Device.

```
<Datalogging_1_Log>
  <BinLog _="Datalogging_0">
    <Input4 _="&#xae;/Process/MB/IO/I/P0;" />
  </BinLog>
</Datalogging_1_Log>
```

Process Command**Syntax:**

```
<Process>
  Instruction List
</Process>
or
<Process _="ProcessVariableName" />
```

Description:

Processes the instructions of the given instruction list or calculate the specified process variable.

Elements:***Instruction List:***

List of instructions calculating the value of the process variable (for a description of instructions see Configuring Process Variables chapter 6.2).
Strings are currently not supported.

Note:

To process a variable given by the event parameter you can use the data path (~/) as address parameter of the instruction:

Example:

Assume the event command:

```
<DoOn _="Switch_1">
  <PortValue _="1" />
</DoOn>
```

The following event handler sets the port P1 to the value given by the event command.

```
<Switch_1>
  <Process>
    <LD _="&#xae;~/PortValue" />
    <ST _="/Process/MB/IO/Q/P1" />
  </Process>
</Switch_1>
```

The reference **must not** be ended by a semicolon in this case! Alternative references are not supported in RPN instructions.

ProcessVariableName:

Name of a process variable configured in /PROCCFG/ProcessVars/. The process variable must include the "Process" command (instead of "value") to be calculated on trigger (see chapter 6.3).

Example:

Event handler sets the output port P4, logs this port and sends a message:

```
<Switch_0>
  <Process>
    <LD _="1" />
    <ST _="/Process/MB/IO/Q/P4" />
  </Process>
  <Log _="Datalogging_1_Log">
    <Action _="Port set" />
    <Portstate _="#xae;/Process/MB/IO/Q/P4; " />
  </Log>
  <SendMail _="MessageJobTemplates/Switch_0" />
</Switch_0>
```

Event handler triggers a process variable to increase a counter:

```
<Increase>
  <Process _="Counter" />
</Increase>
```

The referenced process variable may look like this:

```
<CounterValue def="0" />
<Counter>
  <Process>
    <LD _="/Process/PV/CounterValue" />
    <ADD _="1" />
    <ST _="/Process/PV/CounterValue" />
  </Process>
</Counter>
```

Delay Command**Syntax:**

```
Instruction
<Delay _="Xs" />
Instruction
```

Description:

Includes a delay between two instructions.

Elements:**Instruction:**

EventHandler command, e.g. "SendMail" or "Set" etc.

Xs: Time in seconds (1-60)

Example:

Event handler sets the PLC variable 1, waits 5 seconds and processes thereafter the SendMail.

```
<Switch_1>
  <Set _="/Process/Bus1/Device_0/Variable_1" value="1"/>
  <Delay _="5s"/>
  <SendMail _="MessageJobTemplates/Switch_1"/>
</Switch_1>
```

This may be useful if a "Set" of a PLC variable is initiated by an incoming message and the "SendMail" should send a confirmation back to the sender including the value read after 5s to verify the event. Without the delay the answer may include the old value because the PLC-protocol was not fast enough to process the command before creating the confirmation message.

Confirm Command**Syntax:**

```
<Confirm _="ConfirmID" />
```

Description:

Used to confirm a message waiting for acknowledge (see SendMail parameter "OnTimeout").

Elements:**ConfirmID:**

ID given in SendMail command or "*" to confirm all jobs.

Example:

This EventHandler confirms a SendMail command waiting for acknowledge. The requested ConfirmID was 99.

```
<Confirmation_Event>
  <Confirm _="99" />
</Confirmation_Event>
```

The Confirm command is mostly used by the system events "OnButton" and "Confirmation" (see 3.7.3).

SetConfig Command**Syntax:**

```
<SetConfig/>
```

Description:

EventHandler command to change databases via incoming Email or Express-Email. The incoming Email has to be in "plain text" format. Disable any Rich-Text, HTML or quoted printable format option in your email program if you send a message to the Tixi Device.

For further information read chapter 9.4.

Elements:

No elements

Example:

An incoming message with subject "Password LoadDatabase" (Password: see chapter 9.5) and a database included in message body will be processed by this EventHandler:

```
<Switch_0>
  <SetConfig/>
</Switch_0>
```

POP3Query Command

Syntax:

```
<POP3Query/>
```

Description:

Queries a configured POP3 account (see chapter 3.5) for new emails to process incoming messages (see chapter 9.3.5).

There must be a delay of 20s between two POP3 queries. Shorter retries are not processed.

Elements:

No elements

Example:

This EventHandler may be triggered periodically via scheduler to query a POP3 account for new emails to process:

```
<Switch_1>
  <POP3Query/>
</Switch_1>
```

Clear Command**Syntax:**

```
<Clear Log="Logfiles"/>
```

Description:

Deletes the content of one or several logfiles. (see chapter 2.4.6.6).

Elements:**Logfiles:**

Logfile or list of logfiles to be deleted. To delete several Logfiles with one command, separate the logfile names by comma. Use an asterisk "*" to delete all logfiles.

Example:

This EventHandler may be triggered on OnOK cascading after the logfile was sent via email:

```
<Datalogging_0_Clear>
  <Clear Log="Datalogging_0"/>
</Datalogging_0_Clear>
```

Reset Command**Syntax:**

```
<Reset/>
```

Description:

Processes a "Reset keep" of the modem (see chapter 2.4.6.1).
Reset will be executed with a delay of 10s.

Elements:

No elements

Example:

This EventHandler may be triggered periodically via scheduler to reset the modem.

```
<Switch_2>
  <Reset/>
</Switch_2>
```

INetTime Command**Syntax:**

```
<INetTime/>
```

Description:

Queries an Internet TIME-Server to synchronize the RealTimeClock of the device. See chapter 3.12 for more information.

Elements:

No elements

Example:

This EventHandler may be triggered once a month via scheduler to synchronize the Tixi Devices clock with an Internet TIME-Server:

```
<Switch_4>
  <INetTime/>
</Switch_4>
```

SetTime Command**Syntax:**

```
<SetTime _="Time" TimeDiff="Difference"/>
```

Description:

Sets the Tixi Device clock (RTC) to the given value. May be used to synchronize the Tixi Device time with the PLC time.

Elements:**Time:**

Time-String or reference to time string with following format:
 YYYY/MM/DD, hh:mm:ss

Difference:

Difference between the "Time" value and the time to set. The TimeZone of the /USER/USER database will be added to the Difference.
 +/-HHMM

Example:

This EventHandler copies the value of the PLC time variable into the Tixi Device RTC and adds one hour (/USER/USER/Timezone="+0000"):

```
<Switch_5>
  <SetTime _="&#xae;/Process/Bus1/Device_0/Clock;" TimeDiff="+0100"/>
</Switch_5>
```

S0_Sync Command**Syntax:**

```
<S0_Sync/>
```

Description:

This command is only used together with the S0-interface (see chapter 6.7). It generates a synchronization impulse by the modem (e.g. via scheduler) instead of using an external synchronization impulse. The created synchronization impulse copies the counted S0 impulses into the counter variable.

Elements:

No elements

Example:

This EventHandler creates an synchronization impulse:

```
<Switch_6>
  <S0_Sync/>
</Switch_6>
```

Beep Command**Syntax:**

```
<Beep _="melody" duration="length" />
```

Description:

This command activates the speaker.

Elements:

melody: selects the melody 1 – 6

length: selects the tone duration (in “ms”)

Example:

This EventHandler switches the Tixi Device speaker on for 10 minutes:

```
<Switch_8>
  <Beep _="4" duration="600000" />
</Switch_8>
```

This EventHandler switches the Tixi Device speaker off (if active):

```
<Switch_9>
  <Beep _="4" duration="0" />
</Switch_9>
```

GetJobs – Write Joblist to logfile**Syntax:**

```
<GetJobs _="logfile" />
```

Description:

This command writes a list of job groups and currently active jobs into the specified logfile.

Elements:

logfile: Logfile in which the list will be written.

Example:

This EventHandler writes the job list into the Event log:

```
<Switch_10>
  <GetJobs _="Event" />
</Switch_10>
```

The logfile entry will have the same syntax as the GetJob command result. See chapter 0.

DeleteJobs – Write Joblist to logfile**Syntax:**

```
<DeleteJobs _="logfile" />
```

Description:

This command deletes all waiting (not active) jobs and writes a list of them into the specified logfile.

Elements:

logfile: Logfile in which the list will be written.

Example:

This EventHandler deletes all waiting jobs and writes the job list into the Event log:

```
<Switch_11>
  <DeleteJobs _="Event" />
</Switch_11>
```

The logfile entry will have the same syntax as the GetJob command result. See chapter 0.

TransMode – Switch to local transparent mode**Syntax:**

```
<TransMode format="SerialFormat" local="localSerialFormat"
```

```

baud="Baud Rate" com="comport" handshake="Handshake"
wait="timeout" />

```

Description:

Switches the Tixi Device to a local transparent mode.
Data from COM1 will be routed to the selected extension com port (COM2/COM3).

Note:

This kind of transparent mode will not be aborted by a Plug&Play sequence and there is also no idle timeout. Don't forget to create a TransModeClose event, otherwise the device has to be manually switched off/on to leave the transparent mode!

Elements:

See chapter 2.4.6.1 for valid command parameters (except keep!).

Example:

This System EventHandler switches the Tixi Device into transparent mode if service button is pressed and will leave it if pressed again:

```

<System>
  <OnButton>
    <TransMode baud="2400" local="8E1" format="8E1"
      com="COM3" />
    <If _="/Process/MB/TransMode">
      <TransModeClose/>
    </If>
  </OnButton>
</System>

```

TransModeClose – Leave transparent mode**Syntax:**

```
<TransModeClose/>
```

Description:

Tells the modem to leave the transparent mode.

Elements:

none

Example:

This System EventHandler switches the Tixi Device into transparent mode if service button is pressed and will leave it if pressed again:

```

<System>
  <OnButton>
    <TransMode baud="2400" local="8E1" format="8E1"
      com="COM3" />
    <If _="/Process/MB/TransMode">
      <TransModeClose/>
    </If>
  </OnButton>
</System>

```

Connect – Establish ISP connection**Syntax:**

```
<Connect/>
```

Description:

Establishes an ISP connection. The connection will be kept online depending on the KeepConnected ISP database setting (see chapter 3.5).

Elements:

none

Example:

This System EventHandler establishes an internet connection as soon as the GSM modem is registered to the GPRS network.

```
<System>
  <GPRSPrepared>
    <Connect />
  </GPRSPrepared >
</System>
```

WriteFile – Write to SD-Card**Syntax:**

```
<WriteFile _="Template" File="Filename" FileExistsOperation="Mode" />
```

Description:

Writes the content generated by the text template to the SD-Card.

Elements:**Template**

Name of the message job template which is used to generate the job for this event. See chapter 3.9.

Filename:

Name of the file to be created/appended on the SD-Card. Must be in 8.3 notation.

Mode:

Defines what to do if the filename already exists.

keep: The file will not be overwritten, writing aborted. (default)

override: Overwrite file.

append: Append data to the end of the existing file.

Example:

This EventHandler copies the content of a log file to the SD-Card. The unique filename is created by the time in HEX format.

```
<Switch_12>
  <WriteFile _="MessageJobTemplates/Switch_12"
    File="&#xae;/TIMES/HEXDATE.CSV" />
</Switch_12>
```

CheckJobConditions – Checks the condition of delayed SendMail jobs**Syntax:**

```
<CheckJobConditions />
```

Description:

Checks the condition (variable) of a delayed SendMail job. If the condition is TRUE, the message will be sent. If the condition is FALSE, delay will be continued.

Elements:

none

Example:

This EventHandler checks the condition of delayed SendMail jobs:

```

<Switch_13>
  <CheckJobConditions/>
</Switch_13>

```

3.7.2 Conditions

The "IF" instruction is used to prevent the execution of events in special conditions. For example it may be used to deactivate scheduled data logging during transparent mode or external device failure.

If instruction

Syntax:

```

<If _="Condition">
  EventHandler commands
</If>

```

Description:

Processes the enclosed EventHandler commands only if the condition is equals "1".

Elements:

Condition

Path to a bit variable, e.g. ProcessVar

EventHandler commands:

List of EventHandler commands (for a complete list see chapter 3.7.1).

Example:

Data logging is only processed if PLC communication is active.

```

<Datalogging_0_Log>
  <If _="/Process/Bus1/Device_0/DeviceState">
    <Log _="Port" >
      <PortLog1 _="&#xae;/Process/Bus1/Device_0/Word01"/>
      <PortLog2 _="&#xae;/Process/Bus1/Device_0/Word02"/>
    </Log>
  </If>
</Datalogging_0_Log>

```

IfNot instruction

Syntax:

```

<IfNot _="Condition">
  EventHandler commands
</IfNot>

```

Description:

Processes the enclosed EventHandler commands only if the condition is not "1".

Elements:

Condition

Path to a bit variable, e.g. ProcessVar

EventHandler commands:

List of EventHandler commands (for a complete list see chapter 3.7.1).

Example:

Data logging is only processed if ethernet connection is lost.

```
<Datalogging_0_Log>
  <IfNot _="/Ethernet/LinkState">
    <Log _="Port" >
      <PortLog1 _="&#xae;/Process/Bus1/Device_0/Word01"/>
      <PortLog2 _="&#xae;/Process/Bus1/Device_0/Word02"/>
    </Log>
  </IfNot>
</Datalogging_0_Log>
```

3.7.3 System events

Inside EventHandler database a group "System" exists, that holds EventHandler that are not triggered by "DoOn" command or "EventState" but by special system conditions.

System EventHandler**Syntax:**

```
<System>
  <SystemEventName>
    EventHandler commands
  <SystemEventName>
</System>
```

Description:

Processes the enclosed EventHandler commands triggered by special system conditions.

Elements:**SystemEventName**

Type of system event:

GPRSPrepared

Will be triggered as soon as the GSM modem is registered to the GPRS network. Requires GPRS=On in USER database (see chapter 3.3 and 3.5).

OnButton

Will be triggered as soon as the service button is pressed.

Confirmation

Will be triggered as soon as the modem receives a message with valid fingerprint (see chapter 3.7.1)

POPInvalidPassword**TixInvalidPassword****SMSInvalidPassword****CGIInvalidPassword**

Events triggered during processing of received messages or CGI calls, if password was invalid (see chapter 9.3.1).

POPInvalidEvent**TixInvalidEvent****SMSInvalidEvent****CGIInvalidEvent**

Events triggered during processing of received messages or CGI calls, if command was invalid or if failure during processing a valid command (see chapter 9.3.1).

EventHandler commands:

List of EventHandler commands (for a complete list see chapter 3.7.1).

Example:

This System EventHandler establishes an internet connection as soon as the GSM modem is registered to the GPRS network.

```
<System>
  <GPRSPrepared>
    <Connect/>
  </GPRSPrepared>
</System>
```

3.8 Message Text Template

You can define a template for the message text if it is clear what the event message should say. This template can be used for all message types but typically SMS and pager templates will only contain a subject line. The templates contains instructions for the Job Generator which creates a message from the template.

Database path: /TEMPLATE/UserTemplates

Message Text Template**Syntax:**

```
<TemplateName>
  Instruction List
</TemplateName>
```

Description:

Template, creating a message text. The Job Generator processes the instructions of the template from top to bottom. The result is textual output into the message body.

Elements:**TemplateName :**

Name of the template.

Instruction List:

List of instructions to be processed by the template processor. See the following paragraphs for information on these instructions.

Example:

Typical template with subject and body. References will be resolved or lines skipped if they include unresolvable references. A signature will be copied to the end of the message.

```
<UserTemplates>
  <Message_0>
    <Subject>
      <C _="This is the subject line"/>
    </Subject>
    <Body>
      <E _="Beginning of message body"/>
      <E _="enter some more lines"/>
      <L _=" "/>
      <E _="Date: &#xae;/TIMES/Date,?; "/>
      <E _="-----"/>
      <Include _="/D/UserTemplates/LocationText/Email"/>
    </Body>
  </Message_0>
</UserTemplates>
```

Note: For SMS and pager messages a single line or several lines without line break are used. The line is defined by the message job template as subject (see Message Job Templates chapter 3.9).

If you want to include logfiles into the message text, please see chapter 4.3.

The template processor uses the following instructions

Write a text line – abort on error

Syntax:

```
<L _="RefText" />
```

Description:

Writes a text string with a Carriage Return/Line Feed - pair at the end of the line. The text can contain references to other attributes. These references are replaced by the values of the attributes. If the Tixi Device can't resolve the attribute, it will stop processing the event.

Elements:

RefText:

Text to write. The text could include some references to system properties or parameters which are placed into the client event messages. In the output line these references are replaced by the values of the referred attributes. A reference starts with the '®' string and ends with a semi colon or the end of the tag.

Example:

Writes the line 'Temperature of Barn: 10 °C'. The value '10' is inserted from the client message data attribute temperature. The degree "°" is written as an entity.

Client event message:

```
[<DoOn _="Alarm_0">
  <Temperature _="10" />
</DoOn>]
```

Template processor instruction:

```
<L _="Temperature of Barn: &#xae;~/Temperature;&#xb0;C" />
```

Lines in the message:

```
Temperature of Barn: 10°C
```

Write a text line – continue on error

Syntax:

```
<E _="RefText" />
```

Description:

Writes a text string with a Carriage Return/Line Feed - pair at the end of the line. The text can contain references to other attributes. These references are replaced by the values of the attributes. If the Tixi Device can't resolve the attribute, it will skip the complete line and continue processing the next line.

Elements:

RefText:

Text to write. The text could include some references to system properties or parameters which are placed into the client event messages. In the output line these references are replaced by the values of the referred attributes. A reference starts with the '®' string and ends with a semi colon or the end of the tag.

Example:

Writes the line 'Temperature of Barn: 10 °C'. The value '10' is inserted from the client message data attribute temperature. The degree "°" is written as an entity. Due to a missing attribute, the Tixi Device can't resolve all parameters.

Client event message:

```
[<DoOn _="Alarm_0">
  <Temperature _="10"/>
</DoOn>]
```

Template processor instruction:

```
<E _="Temperature of Barn: &#xae;~/Temperature;&#xb0;C"/>
<E _="Barn: &#xae;~/Barn; "/>
```

Lines in the message:

```
Temperature of Barn: 10°C
```

Line two will be skipped, because attribute "Barn" doesn't exist.

Write a text line – no CRLF, abort on error**Syntax:**

```
<S _="RefText" />
```

Description:

Writes a text string without a Carriage Return/Line Feed - pair at the end of the line. The text can contain references to other attributes. These references are replaced by the values of the attributes. If the Tixi Device can't resolve the attribute, it will stop processing the event.

Elements:**RefText:**

Text to write. The text could include some references to system properties or parameters which are placed into the client event messages. In the output line these references are replaced by the values of the referred attributes. A reference starts with the '®' string and ends with a semi colon or the end of the tag.

Example:

Writes the line 'Temperature of Barn: 10°C Barn 12'. The values are inserted from the client message data attribute barn and temperature. The degree "°" is written as an entity.

Client event message:

```
[<DoOn _="Alarm_0">
  <Barn _="12"/>
  <Temperature _="10"/>
</DoOn>]
```

Template processor instruction:

```
<S _="Temperature of Barn: &#xae;~/Temperature;&#xb0;C "/>
<S _="Barn: &#xae;~/Barn; "/>
```

Line in the message:

```
Temperature of Barn: 10°C Barn 12
```

Write a text line – no CRLF, continue on error**Syntax:**

```
<C _="RefText" />
```

Description:

Writes a text string without a Carriage Return/Line Feed - pair at the end of the line. The text can contain references to other attributes. These references are replaced by the values of the attributes. If the Tixi Device can't resolve the attribute, it will skip the complete line and continue processing the next line.

Elements:**RefText:**

Text to write. The text could include some references to system properties or parameters which are placed into the client event messages. In the output line these references are replaced by the values of the referred attributes. A reference starts with the '®' string and ends with a semi colon or the end of the tag.

Example:

Writes the line 'Temperature of Barn: 10°C'. The value '10' is inserted from the client message data attribute temperature. The degree "°" is written as an entity. Due to a missing attribute, the Tixi Device can't resolve all parameters.

Client event message:

```
[<DoOn _="Alarm_0">
  <Temperature _="10"/>
</DoOn>]
```

Template processor instruction:

```
<C _="Temperature of Barn: &#xae;~/Temperature;&#xb0;C" />
<C _="Barn: &#xae;~/Barn;" />
```

Line in the message:

```
Temperature of Barn: 10°C
```

Line two will be skipped, because attribute "Barn" doesn't exist.

Include – Include another text template**Syntax:**

```
<Include _="Path to Text Template" />
```

Description:

Includes another Text Templates into the message. May be used to add a signature to each message.

Elements:**Path to Text Template:**

XML-Path to the template to be included.

Example:

Includes the template "LocationText" into the message text

Signature template:

```
<LocationText>
  <L _="Location:" />
  <L _="Tixi.Com GmbH" />
  <L _="Berlin" />
</LocationText >
```

Text Template with reference to LocationText:

```
<Message_0>
  <L _="Enter your message text here" />
  <Include _="/D/UserTemplates/LocationText" />
</Message_0>
```

IncludeSP – Include system properties**Syntax:**

```
<IncludeSP _="Path to system property" AddInfo="Info"
ViewProperties="Properties" format="Format" />
```

Description:

Includes the system properties tree or parts of it into the message.

Elements:***Path to system property:***

XML-Path to the system properties to be included (see chapter 12).

empty: complete system properties tree

/PATH: system properties branch or single value

Info:

Error: Displays the error state of the variable(s) instead of its value(s).

Properties:

Error: Displays ErrorClass and ErrorValue additionally to the value(s)

Exp: Displays the exponent of the value(s)

Format:

Formats the output value (see chapter 6.5.2 for instructions)

Example:

Includes the complete system property tree (similar to [<Get/>] command) into the message text

```
<Message_0>
  <IncludeSP _=" " />
</Message_0>
```

Includes the process tree with Error codes:

```
<Message_1>
  <IncludeSP _="/Process/" AddInfo="Error" />
</Message_1>
```

Includes the process tree with additional error and exponent information:

```
<Message_2>
  <IncludeSP _="/Process/" ViewProperties="Error,Exp" />
</Message_2>
```

Includes and reformats the first digital input:

```
<Message_3>
  <IncludeSP _="/Process/MB/IO/I/P0" format="?on,off" />
</Message_3>
```

IncludeLog – Include a XML log file**Syntax:**

```
<IncludeLog _="LogFileName" range="entryrange" />
```

Description:

See chapter 4.6 "Data logging" for complete reference and examples.

IncludeLogTXT – Include an reformat a log file**Syntax:**

```
<IncludeLogTXT _="LogFileName" range="entryrange"
fillInterval="interval" maxInterval="tolerance"
fillText="string" Viewset="variables" Formats/>
```

Description:

See chapter 4.6 "Data logging" for complete reference and examples.

CopyDatabase – Include XML databases**Syntax:**

```
<CopyDatabase _="Path to database" flags="Dereferer"
dest="Destination" />
```

Description:

Copies the defined XML database(s) into the message text.

Elements:**Path to database:**

Path to the XML database to be copied into the message text

/	copies the complete TiXML project
/DATABASE/Group	copies the specified database or groups

Dereferer (option):

Defines if references are to be processed

empty:	References are not processed (default)
Deref:	References are processed

Destination (option):

Defines XML tags enclosing the copied database.

Example:

Copies the EventHandler database into the message text:

```
<Message_1>
  <L _="EventHandler Database:" />
  <L _=" " />
  <CopyDatabase _="/EVENTS/D/EventHandler" />
</Message_1>
```

Copies the complete TiXML project into the message text, enclosed by XML-Tags "CONFIG":

```
<Message_2>
  <CopyDatabase _="/" dest="CONFIG" />
</Message_2>
```

Checksum – Create a checksum**Syntax:**

```
<StartChecksum _="CRC32" />
  Instruction List
<StopChecksum _="Format" />
```

Description:

Creates a CRC32 checksum over the text created by the enclosed instructions (including CRLFs).
The checksum can be included into the message text using a reference to the system variable "_Checksum" .

CRC32 calculation:

Width: 32Bit

Polynomial: 04C11DB7

Init Value: FFFFFFFF

Reflection: In/Out deactivated

XOR Out: 00000000

Elements:**Format:**

Checksum format

X: Hexa decimal

D: Decimal

Example:

Creates a CRC32 checksum over the message text "Hello World!":

```
<Message_2>
  <StartChecksum _="CRC32" />
  <E _="Hello World!" />
  <StopChecksum _="X" />
  <E _="CRC32=&#xae;~/_Checksum; " />
</Message_2>
```

Checksum: B43B5AC1

3.9 Message Job Template

A typical reaction to a client event is the sending of one or more messages. Each of these is created by a message job template (MJT) which combines the sender, recipient and message text when the event occurs. This is done by creating a message job which is added to the message queue of a Job Generator - similar to a computers printer queue.

These templates are defined in the 'TEMPLATE' database. Each template is an attribute group which has a unique name which has to be written as parameter of the 'SendMail' command in the event handler configuration. The owned attribute (_=" ") defines the message transport type like email, SMS, Fax, Express-E-Mail etc..

We recommend using not more than 100 message job templates because of system performance.

Templates to create message jobs for a certain client event:

Database path: /TEMPLATE/MessageJobTemplates

```

<MessageJobTemplates>
  <Alarm_0 _="SMTP">
    <Recipient _="/D/AddressBook/Contact_0"/>
    <Sender _="/D/AddressBook/MySelf"/>
    <Body _="/UserTemplates/Message_0/Body"/>
    <Subject _="Barn is out of temperature"/>
  </Alarm_0>

  <Alarm_1 _="SMS">
    <Recipient _="/D/AddressBook/Contact_1"/>
    <Sender _="/D/AddressBook/MySelf"/>
    <Subject _="Barn &#xae;~/Barn; is out of temperature.
    Temp=&#xae;~/Temperature; C. "/>
  </Alarm_1>

  <Alarm_2 _="GSMSMS">
    <Recipient _="/D/AddressBook/Contact_0"/>
    <Sender _="/D/AddressBook/MySelf"/>
    <Subject _="" Path="/UserTemplates/Message_1/Subject"/>
  </Alarm_2>
</MessageJobTemplates>

```

Message Job
Templates

Message Job Template**Syntax:**

```

<TemplateName _="TransportTypeTemplate">
  List of Variables
</TemplateName>

```

Description:

Attribute group which defines the creation of a message job for a certain event.

Elements:**TemplateName:**

Name of the template. This is the parameter of the 'SendMail' command in the event handler configuration and must be unique within the MessageJobTemplate group.

List of Variables:

List of attributes defining some variables depending on the predefined templates.

TransportTypeTemplate:

Transportation method:

SMTP	creating a SMTP message job.
SMS	creating a SMS message job via landline modem.
TextFax	creating a FAX message job.
Express-Email	creating an Express-Mail message job.
GSMSMS	creating a SMS message job via a GSM modem.
CityRuf	creating a pager message.
URLSend	creating a HTTP notification (GET)
CBIS	creating a CBIS notification
WriteFile	creating a job to write to the SD-Card

Example:

This message job template creates a SMTP message job:

```
<Alarm_0 _="SMTP">
  <Recipient _="/D/AddressBook/Contact_0"/>
  <Sender _="/D/AddressBook/MySelf"/>
  <Body _="/UserTemplates/Message_0/Body"/>
  <Subject _="Barn is out of temperature"/>
</Alarm_0>
```

Variables

Note: A SMTP message can be sent to more than one recipient. This can be achieved by more than one 'Email' entry in the referred AddressBook contact instead of adding several "Recipients" to the MJT

The subject line of the message may be written directly into the message job template attribute "Subject", but for software compatibility reasons we recommend to use the "path" attribute to a user template instead (see next note):

```
<Alarm_0 _="SMTP">
  <Recipient _="/D/AddressBook/Contact_0"/>
  <Sender _="/D/AddressBook/MySelf"/>
  <Body _="/UserTemplates/Message_0/Body"/>
  <Subject path="/UserTemplates/Message_0/Subject"/>
</Alarm_0>
```

The variables necessary for a message job template are depending on the transportation type. Typically you have to add the sender and receiver address, the template for the body and the subject but some message types don't need a body or even a text at all.

Note:

The subject can be defined by three different methods:

Direct (only valid for this MJT, limited to 385 characters):

Subject is written directly into the MJT:

```
<Subject _="Barn is out of temperature"/>
```

Reference (useable for different MJTs, limited to 385 characters):

Subject is written into UserTemplates and referenced within MJT by `®`:

```
<Subject _="&#xae;/D/UserTemplates/Message_0/Subject;"/>
```

Referenced UserTemplate:

```
<Message_0>
  <Subject _="Test"/>
</Message_0>
```


Path (useable for different MJTs, no character limitation):

Subject is written into UserTemplate and included via "Path":

```
<Subject _="" path="/D/UserTemplates/Message_0/Subject"/>
```

Referenced UserTemplate:

```
<Message_1>
  <Subject>
    <S _="385 characters text"/>
    <S _="add 385 characters text"/>
    <S _="add 385 characters text"/>
    ...
  </Subject>
</Message_1>
```

If there is additional text within _="" it will be added in front of the UserTemplates text.

SMTP

Name	Description
Recipient	Path to the address book entry including the email address for the receiver of the SMTP message (inserted in the 'To' field of the message).
Sender	Path to the address book entry including the email address for the sender (inserted in the 'From' field of the message).
Subject	The subject text of the message (inserted in the 'Subject' field of the message).
Body	The Body contains the main text of the message. This is what the receiver of the mail will read and it should contain all the necessary information to react to the event. The Body field contains a path to the message text template where the message text is defined. Therefore you can use one of these message text templates for several message job templates.
Attachments	Optional attachment with logged data. See chapter 4.6.2.

TextFax

Name	Description
Recipient	Path to the address book entry including the fax number for the receiver of the fax message
Sender	Path to the address book entry including fax number for the sender (inserted in the header of the fax).
Subject	see SMTP
Body	see SMTP

Express-Email

Name	Description
Recipient	Path to the address book entry including the Express-E-Mail Address for the receiver of the Express-E-Mail message (inserted in the 'To' field of the message).
Sender	Path to the address book entry including Express-E-Mail Address for the sender (inserted in the 'From' field of the message).
Subject	see SMTP
Body	see SMTP

SMS/GSMSMS

Name	Description
Recipient	Path to the address book entry including the SMS number of the receiver of the SMS message.
Sender	Path to the address book entry including the phone number of the sender of the SMS message.
Subject	Defines the SMS message text (max. 160 character).
Body	not used

CityRuf

Name	Description
Recipient	Path to the address book entry including the pager number of the receiver of the pager call.
Sender	not used
Subject	Defines the pager message text.
Body	not used

CBIS

Name	Description
Recipient	Path to the address book entry including the email address for the receiver of the SMTP message (inserted in the 'To' field of the message).
Sender	Path to the address book entry including the email address for the sender (inserted in the 'From' field of the message).
Subject	not used, subject with IP-adress link is automatically created
Body	not used, body will contain content of /USER/SITE_TAG database

URLSend

Name	Description
Recipient	Path to the address book entry including the URL to request.
Sender	not used
Subject	not used
Body	not used

WriteFile

Name	Description
Recipient	not used
Sender	not used
Subject	not used
Body	The Body field contains a path to the text template where the text is defined, which will be written to the file on the SD-Card.

3.10 SMS Provider

The ISP database contains a section SMS_Provider which configures the access to SMS service centers. Tixi Alarm Modems are supporting script gateways using TAP or UCP and gateways according to ETSI ES 201 912 (1TR140).

Database path: /ISP/SMS_Provider

SMS Provider

Syntax:

```
<ProviderName>
  <Dialin _="SMSCNumber" />
  <Type _="ProtocolType" />
  <Script _="ModemScript" />
  <NumberFormat _="Format" />
  <SMS_ISDN _="ISDNProtocol" />
  <Pager_ISDN _="ISDNProtocol" />
  <SMS_Media _="Media" />
</ProviderName>
```

Description:

Attribute group which specifies a gateway to send SMS.

Elements:

ProviderName

Name of the provider. This is the parameter of the 'SMS_Provider' or 'Pager_Provider' attribute in the address book and must be unique within the SMS_provider group.

SMSCNumber

Phone number of the SMS center.

ProtocolType

This can be either

SMS ETSI ES 201 912 (1TR140), only for PSTN modems

Script TAP, UCP or GSM

ModemScript

The protocol for the SMS transmission (only if Type=Script).

Can be either

D1_TAP TAP with format 8N1

Mobilkom_A_TAP TAP with format 7E1

D2_UCP UCP

GSM using the SMSC of the SIM card.

Format

Used to convert an canonical addressbook number into the format expected by the gateway, e.g. addressbook: +49-172-1234567 will be send as:

“national”: 01721234567

“canonical”: +491721234567

ISDNProtocol

ISDN B-channel protocol used by SMS gateway. See chapter 3.5 ModemProtocol for supported values.

Pager_ISDN

ISDN B-channel protocol used by Pager gateway. See chapter 3.5 ModemProtocol for supported values.

Media

Must be 'SMS' for GSM providers.

Example:**Modem Gateways (UCP, TAP):**

The following example configures the access to the SMS modem gateway of the Vodafone Germany via ISDN:

```
<SMS_Provider_0>
  <Dialin _="+49-172-2278025" />
  <Type _="Script" />
  <Script _="D2_UCP" />
  <NumberFormat _="national" />
  <SMS_ISDN _="X.75-T.70" />
</SMS_Provider_0>
```

PSTN-Gateways (ETSI ES 201 912, 1TR140):

This example configures the access to the SMS PSTN gateway of the German provider "AnnyWay":

```
<SMS_Provider_1>
  <Dialin _="+49-900-3266900" />
  <Type _="SMS" />
  <NumberFormat _="canonical" />
</SMS_Provider_1>
```

GSM-SMSCs:

This example configures the access to the SMSC stored on the SIM card of your GSM device.

```
<GSM>
  <Dialin _="0" />
  <Type _="Script" />
  <NumberFormat _="canonical" />
  <Script _="GSM" />
  <SMS_Media _="SMS" />
</GSM>
```

Some german SMS providers are preconfigured in our TiXML-Examples and TILA software. Contact your local telephone company to get access to their SMS gateways (GSM, TAP, UCP, 1TR140).

3.11 Service center for incoming SMS

The ISP database contains a section IncomingSMSCenter which contains the callerIDs of the service center for incoming PSTN SMS. Three entries are possible (SMSC1-3).

Example:

The following example configures the callerIDs for the german Telekom and the AnnyWay service center.

Database path: /ISP/IncomingSMSCenter

```
<SMSC1 _="0193010" />
<SMSC2 _="09003266900" />
```

3.12 Automatic transmode

The Tixi Alarm Modem is able to redirect some (callerID) or all incoming calls to one of its serial interfaces.

This offers transparent mode capability without need to send Login or TransMode commands, therefore it may be possible to use dial routines of the software that needs access to the device.

Database path: /ISP/AutoTransMode

Automatic TransMode

Syntax:

```
<AutoTransMode>
  <NoX _="CID" transmode="comport" format="SerialFormat"
    baud="Baud Rate" handshake="Handshake" wait="timeout" />
</AutoTransMode>
```

Description:

1. Switches the remote Tixi Alarm Modem into transparent mode (like Modem Mode) to routes data to the selected com port.
2. It transforms the baud rate and the serial data format from the phone line to the values required by the connected client device.

Note: This transparent mode of the remote Tixi Alarm Modem becomes ended when the dialup connection drops. After this the remote Tixi Alarm Modem goes back in the TiXMLMode. Look into the manual of the dialing modem on how to disconnect connections (escape sequence).
A transparent mode to the host port COM1 is blocked if a local login session is open (see chapter 0).

Elements:

x:

Entry number. Possible values: 1 or 2

CID:

CallerID used to trigger the automatic transmode

comport:

Specifies the COM port on the remote Tixi Device used for the connection.

- COM1 Programming port (labeled **COM1 RS232**) (**default**)
- COM2 PLC port (labeled **COM2 RS232** or **COM2 R-485/422**) (if available)
- COM3 M-Bus port (labeled **M-Bus**) (if available)
- COM4 PLC port (**COM4 R-485/422**) (if available)

SerialFormat:

String which encodes the serial format that is used between modem and client device. It has the following syntax (**default "8N1"**):

DataBitsParityBitsStopBits

DataBits

8...8 data bits are used.

7...7 data bits are used.

ParityBits

N...No parity bit.

E...Even parity.

O...Odd parity.

StopBits

- 1...one stop bit.
- 2...two stop bits.

Baud Rate:

Used baudrate in bits per second (bps) (**default 9600**).

Handshake:

Used communication handshake.

None	communication without handshake
XONXOFF	software handshake
XONXOFFPASS	software handshake, XONXOFF forwarded to application
RTSCTS	hardware handshake with RTS CTS
DTRDSR	hardware handshake with DTR DSR
HALF	HalfduplexRS 485 communication
FULL	Fullduplex RS 485/422
HALFX	Halfduplex RS 485 communication with XON XOFF
FULLX	Fullduplex RS 485/422 with XON XOFF
noDTR	special DTR mode for Moeller and Mitsubishi PLCs

Note: RS 485/422 communication is only valid on RS 485/422 interfaces.

timeout:

Specifies the time the Tixi Device will try to disable a PLC bus protocol on the remote com port (default: 20s).

Example:

Establish transparent mode to COM2 with 38400bps, data format 8O1 and hardware handshake if call with callerID 0301234567 is detected and (No2) establishes transparent mode to COM1 with 9600bps, data format 8E1 if call with callerID 0307654321 is detected:

```
<AutoTransMode>
  <No1 _="0301234567" transmode="COM2" format="8O1"
    baud="38400" handshake="RTSCTS" wait="60s"/>
  <No2 _="0307654321" transmode="COM1" format="8E1" baud="9600"
    handshake="none" wait="60s"/>
</AutoTransMode>
```

Establish transparent mode to COM1 with 9600bps, data format 8N1 on any call:

```
<AutoTransMode>
  <No1 _="*" transmode="COM1" format="8N1" baud="9600"
    handshake="none" wait="60s"/>
</AutoTransMode>
```

3.13 Internet-Time synchronization

The Tixi Device uses a battery buffered Real Time Clock. Add following configuration to synchronize the Clock with an Internet Time Server via DayTime Protocol (TCP port 13):

Database path: /ISP/ISP/TimeServer

Internet Time synchronization**Syntax:**

```

<TimeServer>
  <ServerName _="address" />
  <Protocol _="protocol" />
  <TimeDiff _="difference" />
  <TimeFormat _="string" />
</TimeServer>

```

Description:

Defines the time server to query, the used protocol, the time difference and the time format.

Elements:**address**

Address of the internet time server.

protocol

Protocol used to query the time server.

DAYTIME: DayTime protocol on TCP port 13

difference

Time difference to GMT in coherence to the USER database TimeZone.

Format: +HHMM (Default: +0000)

Example Germany:

The TimeZone setting in user database has to be +0100 GMT.

To synchronize the time with a local time server, the Time Zone has to be subtracted from the server time, which means TimeDiff: -0100

string

Format string that tells the modem how the DAYTIME server response will look like. Following elements are available:

y year
m month
d day
h hour
n minute
s sec
G month as string german
E month as string english
i ignore

e.g.: Server response: "11 MAY 2004 12:09:15 METDST"

TimeFormat: "d E y h:n:s "

Example:

Time server settings to get GMT:

```

<TimeServer>
  <ServerName _="time.nist.gov" />
  <Protocol _="DAYTIME" />
  <TimeDiff _="+0000" />
  <TimeFormat _="i y-m-d h:n:s i" />
</TimeServer>

```

To start the time synchronization a simple EventHandler will do the job:

```
<SyncTime>
  <INetTime />
</SyncTime>
```

A good solution can be implemented by combining the time query event with the scheduler. This scheduler will synchronize the time every Monday:

```
<SyncTime _="SyncTime">
  <Weekday _="Mo" />
</SyncTime>
```

You can also use this feature to change the clock to winter summer time (requires a local DAYTIME server with daylight saving time). Necessary scheduler:

```
<Summertime _="SyncTime">
  <Month _="3" />
  <Day _="25-31" />
  <Weekday _="Su" />
  <Time _="02:00" />
</Summertime>
<Wintertime _="SyncTime">
  <Month _="10" />
  <Day _="25-31" />
  <Weekday _="Su" />
  <Time _="03:00" />
</Wintertime>
```

3.14 Ethernet

The Tixi Data Gateway has a LAN interface for HTTP- and TiXML-access or email sending. This chapter describes the TCP/IP configuration

Database path: /ISP/Ethernet

Ethernet configuration

Syntax:

```
<Ethernet _="keep">
  <IP _="IP-address" />
  <Mask _="Subnetmask" />
  <Gateway _="GW-address" />
  <FirstDNSAddr _="DNS-address" />
  <SecondDNSAddr _="DNS-address" />
  <HostName _="Host" />
</Ethernet>
```

Description:

Defines the TCP/IP settings of the Tixi Data Gateway.

Elements:

keep

Flag to activate none volatile IP configuration written to EEPROM.

persistent: keep configuration in EEPROM

empty: don't keep configuration

IP-address

Static IP address of the Tixi Data Gateway in "dotted quad format" or string "DHCP" to activate dynamic host configuration protocol.

Subnetmask

Subnetmask according to the IP address of the Tixi Data Gateway. Can be omitted, if DHCP is activated.

GW-address

Gateway IP address of the next router. Can be omitted, if offered by DHCP server.

DNS-address

IP address of the DNS server. Can be omitted, if offered by DHCP server.

Host

DHCP option 12 used for DDNS registration.

Example:

Persistent IP configuration for private CLASS-C /24 network with a WAN router at 192.168.0.1.

```
<Ethernet _="persistent">
  <IP _="192.168.0.20"/>
  <Mask _="255.255.255.0"/>
  <Gateway _="192.168.0.1"/>
  <FirstDNSAddr _="192.168.0.2"/>
</Ethernet>
```

Automatic IP configuration using DHCP server.

```
<Ethernet>
  <IP _="DHCP"/>
  <HostName _="TixiDevice"/>
</Ethernet>
```

3.15 WLAN

The Tixi Data Gateway may have a WLAN module for HTTP- and TiXML-access or email sending. This chapter describes the TCP/IP and WiFi access point configuration

Database path: /ISP/WLAN

WLAN configuration

Syntax:

```
<WLAN>
  <Profile_X SSID="SSID" BSSID="BSSID">
    <Authentication _="encryption"/>
    <Password _="WEP_key"/>
    <Ethernet>
      <IP _="IP-address"/>
      <Mask _="Subnetmask"/>
      <Gateway _="GW-address"/>
      <FirstDNSAddr _="DNS-address"/>
      <SecondDNSAddr _="DNS-address"/>
      <HostName _="Host"/>
    </Ethernet>
  </Profile_X>
</WLAN>
```

Description:

Defines the TCP/IP and access point settings of the Tixi Data Gateway WLAN module.

Elements:**X**

Profile number. A maximum of 10 access point profiles (0-9) is supported.

SSID

Service Set Identifier of access point

BSSID

Basic Service Set Identifier of access point (option). May be used, if SSID is hidden.

encryption

Authentication method, currently only "Shared_WEP" is supported.

WEP_key

WEP key used by access point (max. 128Bit).

IP-address

Static IP address of the Tixi Data Gateway WLAN module in "dotted quad format" or string "DHCP" to activate dynamic host configuration protocol.

Subnetmask

Subnetmask according to the IP address of the Tixi Data Gateway WLAN module. Can be omitted, if DHCP is activated.

GW-address

Gateway IP address of the next router. Can be omitted, if offered by DHCP server.

DNS-address

IP address of the DNS server. Can be omitted, if offered by DHCP server.

Host

DHCP option 12 used for DDNS registration.

Example:

Static IP configuration for access point with SSID "HOME" and second profile with automatic IP configuration for alternative AP with SSID "OFFICE".

```
<WLAN>
  <Profile_0 SSID="HOME">
    <Authentication _="Shared_WEP"/>
    <Password _="11223344556677889900AABBCC"/>
    <Ethernet>
      <IP _="192.168.0.2"/>
      <Mask _="255.255.255.0"/>
      <Gateway _="192.168.0.1"/>
      <FirstDNSAddr _="192.168.0.1"/>
    </Ethernet>
  </Profile_0>
  <Profile_0 SSID="OFFICE">
    <Authentication _="Shared_WEP"/>
    <Password _="11223344556677889900AABBCC"/>
    <Ethernet>
      <IP _="DHCP"/>
    </Ethernet>
  </Profile_0>
</WLAN>
```

ScanWLAN – Scans for available WLAN access points**Syntax:**

```
<ScanWLAN ver="v"/>
```

Description:

This command returns a list of available WLAN access points.

Parameter:

No Parameter.

Return:**If no error (command is processed):**

```
<ScanWLAN>
<APn _="" RSSI="signal strength">
  <BSSID _="MAC" />
  <SSID _="AP name" Id="0" />
  <SUPPORTED_RATES _="82 84 8b 96 24 30 48 6c" Id="1" />
  <DS_PARAM_SET _="channel" Id="3" />
  <CF_PARAM_SET _="00 02 00 00 00 00" Id="4" />
  <TIM _="00 01 00 00" Id="5" />
  <unknown _="04" Id="42" />
  [...]
  <EXTENDED_RATES _="0c 12 18 60" Id="50" />
  <unknown _="0e 18 1a ff ff 00 00 01 00 00 00 00 00" Id="45" />
  [...]
  <VENDOR _="00 10 18 02 01 f0 05 00 00" Id="221" />
  [...]
</APn>
[...]
```

n	access point number (0-15)
signal strength	Signal to noise ratio
MAC	Basic service set identifier (MAC address / BSSID)
AP name	Service set identifier (SSID)
channel	WLAN channel (1-13)

On error (command is not processed):

see default error frame (chapter 2.4.4)

Example:

Get the current system time of the Tixi Device.

Client sends: [<ScanWLAN/>]

Tixi Device responds:

```
[<ScanWLAN>
<AP0 _="" RSSI="83">
  <BSSID _="00:1a:2b:1e:a0:39" />
  <SSID _="WLAN-1EA007" Id="0" />
  <SUPPORTED_RATES _="82 84 8b 96 24 30 48 6c" Id="1" />
  <DS_PARAM_SET _="01" Id="3" />
  <TIM _="00 01 00 00" Id="5" />
  <unknown _="04" Id="42" />
  <unknown _="04" Id="47" />
  <unknown _="01 00 00 0f ac 02 02 00 00 0f ac 04 00" Id="48" />
```

```

<EXTENDED_RATES _="0c 12 18 60" Id="50" />
<unknown _="0e 18 1a ff ff 00 00 01 00 00 00 00 00" Id="45" />
<unknown _="01 05 13 00 00 00 00 00 00 00 00 00" Id="61" />
<VENDOR _="00 10 18 02 01 f0 05 00 00" Id="221" />
<VENDOR _="00 50 f2 01 01 00 00 50 f2 02 02 00 00" Id="221" />
<VENDOR _="00 50 f2 02 01 01 80 00 03 a4 00 00 27" Id="221" />
<VENDOR _="00 90 4c 33 0e 18 1a ff ff 00 00 01 00" Id="221" />
<VENDOR _="00 90 4c 34 01 05 13 00 00 00 00 00" Id="221" />
</AP0>
<AP1 _="" RSSI="49">
  <BSSID _="00:19:5b:08:fb:8e" />
  <SSID _="Tixi-AP" Id="0" />
  <SUPPORTED_RATES _="82 84 8b 96 0c 12 18 24" Id="1" />
  <DS_PARAM_SET _="01" Id="3" />
  <TIM _="00 03 00 00" Id="5" />
  <unknown _="04" Id="42" />
  <EXTENDED_RATES _="30 48 60 6c" Id="50" />
  <VENDOR _="00 e0 4c 01 02 03 00" Id="221" />
</AP1>
</ScanWLAN>]

```

3.16 TiXML/IP

The TiXML protocol can be used via IP protocol. The appropriate TCP port and communication timeout is configured in the ISP database.

Database path: /ISP/TiXML

TiXML/IP configuration

Syntax:

```

<TiXML>
  <Port _="TCP port">
  <Timeout _="delay">
</TiXML>

```

Description:

Defines the TiXML/IP TCP port and communication timeout.

Elements:

TCP port

TCP port used for communication (default 8300).

Timeout

Timeout after which the Tixi device will close the TCP socket.

Example:

TiXML/IP communication via TCP port 8300 with a socket timeout of 15 minutes.

```

<TiXML>
  <Port _="8300">
  <Timeout _="15m">
</TiXML>

```

3.17 Webserver, PPP-Server, TFTP-Server

Information about the Webserver, PPP-Server and TFTP-Server configuration can be found in the "Webserver TiXML manual" (code WEB-EN).

4 Data Logging

Any operation of the Tixi Device may be logged for later review of what actually happened. Besides the system logging a logging of process data, e.g. I/Os or PLC variables, is possible.

A maximum of 12 logfiles can be created in order not to store all data in the same place.

The LOG database therefore features two sections: LogDefinition and EventLogging. The first creates the logfiles and data structures and must contain info on their names, size and type of content. The second assigns event types to logfile names so that info regarding a specified event type will be written into a specific logfile.

The logfiles themselves are organized as ring buffers with a user defined size. If a logfile is full the logging starts overwriting the oldest logfile entries (FIFO).

Two different types of logfiles are supported:

- XML-logfiles for xml-formatted logging (easy to read)
- Binary logfiles (less memory usage)

4.1 LogDefinition

The "LogDefinition" contains the "LogFiles" and the "Records" group inside LOG database. Both groups are described in the following chapters.

Database path: /LOG/LogDefinition

```
<LogDefinition>
  <LogFiles>
    <Event size="10240"/>
    <JobReport size="10240"/>
    <Datalogging_0 size="20480" contenttype="binary"
      record="Datalogging_0"/>
  </LogFiles>
  <Records>
    <Datalogging_0>
      <Variable_0 _="int" size="2"/>
      <Variable_1 _="Uint16"
        path="/Process/Bus1/Device_0/Variable_1"/>
    </Datalogging_0>
  </Records>
</LogDefinition>
```

Note: Projects created by TILA2 still use an older log database format, where the LogFiles and Records are stored within separated groups, but with same content:

```
/LOG/LogFiles
/LOG/Records
```

The Group "LogDefinition" does not exist.

4.1.1 LogFiles Group

LogFiles

Syntax:

```
<LogFileName size="LogFileSize" contenttype="Type"
  record="RecordPath" />
```

Description:

Defines logfiles by their name and size.

Elements:

LogFileName

The identifier of the logfile. Random unique names may be chosen. A maximum of 12 logfiles can be created.

LogFileSize

Specifies the logfile size in bytes. A logfile size bigger than the Tixi Device memory will be rejected with an error message. Because of the file system structure the logfile size will be round up to 512byte sectors.

Type

The content type for logfiles has to be set to "xml" for XML formatted data logging and to "binary" for binary data logging.

RecordPath

The record path refers to a record inside "Records" database which defines the data structure of a binary log entry.

Example:

Create XML-logfile *Log1* with 1KB size and binary logfile *Log2* with 20KB size and 80 bytes maximum for an entry:

```
<LogFiles>
  <Log1 size="1024"/>
  <Log2 size="20480" contenttype="binary" record="Struct"/>
</LogFiles>
```

During upload of logfile definitions the number of currently existing logfiles plus the number of the uploaded logfiles must not exceed twelve, because new logfiles are written before existing logfiles will be deleted. In this case it will be necessary to do a factory reset before uploading the new logfile definition.

4.1.1.1 SupportLog

After a factory reset the Tixi Device is preconfigured with a Logfile "SupportLog" which may also be added to TiXML projects.

This logfile is used to collect information about the incorporated PSTN or GSM modem like country setting, SMSC, own numbers etc. during system startup.

4.1.2 Records Group

Records

Syntax:

```
<RecordName>
  <ValueName _="Type" />
  <ValueName _="Type" size="Length" />
  <ValueName _="Type" size="Length" value="Value" />
  <ValueName _="Type" size="Length" format="FormatString" />
  <ValueName _="Type" path="Source" />
  <ValueName _="Type" path="Source" exp="Exponent" />
  <ValueName _="Type" path="Source" multip="Factor+Offset" />
  <ValueName _="Type" path="Source" Name="Alias" />
</RecordName>
```

Description:

Defines the structure of a binary logfile.

Elements:

RecordName

Name of the data structure the logfile refers to.

ValueName

Name of the value being assigned during logging.

Type

Type of value:

int:	integer
string:	text string
byte:	byte value
word:	word (16bit) value
dword:	dword (32bit) value
float:	float (32bit) value
double:	double (64bit) value
meterbus:	Meterbus RAW data (only usable with "path", not "value" !)

Additional simpleTypes, see 6.5.1

Bit:	bit
Int8:	byte (8bit) signed
UInt8:	byte (8bit) unsigned
Int16:	word (16bit) signed
UInt16:	word (16bit) unsigned
Int32:	dword (32bit) signed
UInt32:	dword (32bit) unsigned

Length

Number of bytes registered for each log entry (max 100). Must be defined for type "string", optional for all other types.

int:	max. 4 bytes, default 4 bytes
string:	max. 100 chars, no default
byte:	default unsigned (1 byte)
word:	default unsigned (2 byte)
dword:	default unsigned (4 byte)
float:	default 4 byte
double:	default 8 byte
meterbus:	size will be calculated during logging
Bit:	bit (1/8 byte)
Int8:	default signed (1 byte)
UInt8:	unsigned (1 byte)
Int16:	signed (2 byte)
UInt16:	unsigned (2 byte)
Int32:	signed (4 byte)
UInt32:	unsigned (4 byte)

Value

Value for the log entry, if not specified in the log command (option). May be given via reference.

Exponent

Exponent of base 10 to specify fix point precision of simpleType = UInt8, UInt16, UInt32, Int8, Int16, Int32 (see 6.5.1).

The logged variable value will be multiplied by 10^{Exp} to get the output value.

Output value = $10^{Exp} * \text{logged variable value}$.

The exponent therefore specifies the position of comma within a fix point value

Following values are possible:

Exp value	Description
-6	Precision = 0,000001
-5	Precision = 0,00001
-4	Precision = 0,0001
-3	Precision = 0,001
-2	Precision = 0,01
-1	Precision = 0,1
0	Precision = 1 (default)
1	Precision = 10
2	Precision = 100
3	Precision = 1000
4	Precision = 10000
5	Precision = 100000
6	Precision = 1000000

Factor+Offset

The logged value will be multiplied by this factor and the offset will be added to get the output value.

Only simpleType = UInt8, UInt16, UInt32, Int8, Int16, Int32 (see 6.5.1).

Output value = Factor * Logged value + Offset

The factor is used as a fraction, e.g.: "1/1000" or "3600/1", the denominator and numerator must not be zero. The offset may be negative or positive.

Source

Source for the log entry value, if not specified in the log command (option). Processed faster than "value" but supports external (PLC) variables only.

FormatString

String that defines the logfile value output format.

For a list of available format option see chapter 6.5.2.

Alias

Replaces the **ValueName** in the header of "none XML" logfile output by the given alias name. If the ReadLog / IncludeLog(TXT) flag "UseAlias" is used, an attribute "Name" with the variable alias will be added on XML output too.

Example:

This example creates a data structure with 7 values:

```
<Records>
  <Datalogging_0>
    <Value1 _="Int16" Name="word variable"/>
    <Value2 _="Int8" value="&#xae;/Process/C40/IB/P0;"
      Name="byte variable"/>
    <Value3 _="Bit" value="&#xae;/Process/C40/I/P8;"
      format="?On,Off;" Name="bit variable"/>
    <Value4 _="word" path="/Process/MB/A/AI/P0" multip="1/10+3"
      Name="word variable 2"/>
  </Datalogging_0>
</Records>
```

Value1 may be a Int16 signed 16bit word value (2 byte) with a value range of -32768 to

32767. The value must be given by the event.

Value2 is an Int8 signed byte value (1 byte) with a value range of -128 to 127. The input ports P0-P7 (via reference) are automatically written as this byte with every log process.

Value3 is a bit value. The input port P8 is automatically written as this bit. Instead of the 0/1 value the string "On" or "Off" will be omitted during reading the logfile.

Value4 is the analog input value divided by 10 with an offset of +3.

The head line of the logfile output will show the variable alias names.

4.2 EventLogging

Database path: /LOG/EventLogging

EventLogging Database

Syntax:

```
<EventSource mode="Mode1Mode2" file="LogFileName" />
```

Description:

Defines what system information to write into which logfile.

Elements:

EventSource

The identifier for the kind of event to log into the given logfile. Possible EventSource Values are as follows:

Event	reports all event handlers that become processed
Login	reports all cases of anyone doing a login into the Tixi Device as well as for logout
IncomingMessage	reports on all incoming messages
FailedIncomingCall	reports on all incoming calls that could not be handled properly
JobReport	reports the result of sending a message, regardless if it was ok or error.

Mode1

Specifies which incidents to report into the logfile. Possible values:

- a report all incidents (errors and ok)
- e report errors only
- o report ok notifications only

Mode2

Specifies the verbosity of the logfile entry. Possible values are as follows:

- v verbose messages telling the possible reason
- [empty] giving a short description only (**default**)

LogFileName

The name identifier of the logfile. Chosse one of the Logfiles of the LogDefinition (see chapter 4.1.1).

Example:

Verbosely report of failed message sending to Log1 and - shorter - all events triggered to Log2:

```
<EventLogging>
  <JobReport mode="ev" file="JobReport"/>
  <Event mode="a" file="Event"/>
</EventLogging>
```

4.3 Logging commands***Log Command*****Syntax:**

```
<Log _="LogfileName">
  LogData
</Log>
```

Description:

Creates an entry with following structure:

```
<ID_nnn time=_ "TimeStamp">
  LogData
</ID_nnn>
```

nnn:

Unique ID to address the log entry.

TimeStamp:

System time when the log entry was written.

Note: The Log command can only be used for logfiles defined with the content type XML.

Elements:***LogfileName:***

Name of the logfile where the data is written to. Must be defined in the LogDefinition database.

LogData:

Data to be logged. May be collected via references.

Example:

Event handler that logs the last power off and the last power on time.

```
<PowerOn >
  <Log _="SupportLog">
    <PowerOff _="&#xae;/TIMES/PowerOffTime;"/>
    <PowerOn _="&#xae;/TIMES/PowerOnTime;"/>
  </Log>
</PowerOn>
```

Result:

```
<ID_1 _="2003/08/13,10:31:55">
  <PowerOff _="2003/08/13,09:10:00" />
  <PowerOn _="2003/08/13,09:16:52" />
</ID_1>
```

BinLog Command**Syntax:**

```

<BinLog _="LogfileName">
  <ValueName _="Value" />
  <ValueName _="Value" />
  ...
</BinLog>

```

Description:

Creates a binary logfile entry with the structure of the given record.

Note: The BinLog command can only be used for logfiles defined with the content type "binary" and an assigned record.

Elements:**LogfileName:**

Name of the logfile where the data is written to. Must be defined in the LogDefinition database.

ValueName:

Name of value defined in record database. Only necessary if no value or path is defined within the record.

Value:

Value to be written into the structure. Only necessary if no value or path is defined within the record.

Example:

Value1 is given as "Parameter" during DoOn. Value2 and Value3 are port values given by the record value definition.

```

<LogValues>
  <BinLog _="Datalogging_1">
    <Value1 _="&#xae;~/Parameter" />
  </BinLog>
</LogValues>

```

The logfile entry with Parameter=12345 may look like this:

```

<ID_1 _="2003/08/21,09:58:59">
  <Value1 _="12345" />
  <Value2 _="32" />
  <Value3 _="On" />
</ID_1>

```

4.4 Logfile memory calculation

This information may be used to calculate the necessary logfile memory depending on the loginterval and amount of data.

Type		size	amount
Logfile Header		56 Byte	per file
Entry Header		12 Byte	per entry
Entry Data	XML	Size of XML text (variable)	per entry
	Binary	Sum of data elements (static)	per entry

Example:

Log periode: 1 week

Log cycle: 10 minutes

Record:

```
<Datalogging_0>
  <Value1 _="int" size="2"/>
  <Value2 _="int" size="2"/>
  <Value3 _="int" size="2"/>
  <Value4 _="int" size="2"/>
  <Value5 _="int" size="2"/>
  <Value6 _="int" size="2"/>
  <Value7 _="int" size="2"/>
  <Value8 _="int" size="4"/>
  <Value9 _="int" size="1"/>
  <Value10 _="int" size="1"/>
</Datalogging_=>
```

Calculation:

$(20 \text{ Byte Data} + 12 \text{ Bytes Header}) * 144 \text{ entries/day} * 7 \text{ days} + 56 \text{ Bytes File Header}$
 $= 32312 \text{ Bytes}$

Logfile size should be 32768 (divideable by sector size 512)

Estimated memory usage with 2MB memory (only 1 MB available during sending!):

Value to log	Log-Sessions	With 1 minute interval overwrite after	With 15 minute interval overwrite after	With 1 hour interval overwrite after
1 Byte	77000	53 days	26 month	9 years
1 DWord	62500	43 days	21 month	7 years
10 Byte	45500	31 days	15 month	5 years
10 DWord	19200	10 days	5 month	2 years

4.5 Reading and clearing logfiles

For information on how to read or clear the content of logfiles read chapter 2.4.6.6.

4.6 Sending and formatting log reports

The Tixi Device is able to include logged data into messages. You can choose two different commands to include logdata into messages:

1. **IncludeLog**. The logged data will be included in XML format.
2. **IncludeLogTXT**: Most applications can't handle XML so we've implemented a feature to format the output of the logged data. You can choose the predefined logfile formats "CSV", "HTML" and "XML" or reformat the data at your own wish.

IncludeLog – include entries from the log files into message text**Syntax:**

```
<IncludeLog _="LogFileName" range="entryrange" />
```

Description:

Template processor instruction which includes logfile entries in the text of a message. The name of the logfile can be specified as well as a range of entries to be inserted. The generated output is similar to the output generated by the ReadLog command. See chapter 2.4.6.6 for details.

Parameter:***LogFileName:***

Name of the logfile to be read.

entryrange:

Range of log data to send. See chapter 2.4.6.6 for details.

Message Example:

Send the entries with the IDs 7 – 8.

```
<UserTemplates>
  <LogfileMsg>
    <IncludeLog _="Datalogging_0" range="ID_7-ID_8" />]
  </LogfileMsg>
</UserTemplates>
```

Message Body result:

```
<ID_7 _="2002/10/10,16:10:51">
  <Data _="Logged Data" />
</ID_7>

<ID_8 _="2002/10/10,16:10:51">
  <Data _="Logged Data" />
</ID_8>
```

IncludeLogTXT – include and reformat entries from the log files into message text**Syntax:**

```
<IncludeLogTXT _="LogFileName" range="entryrange"
  type="templates" flags="header" fillInterval="interval"
  maxInterval="tolerance" fillText="string" Viewset="variables"
  Formats/>
```

Description:

Template processor instruction which includes logfile entries in the text of a message or into an attachment. The name of the logfile can be specified as well as a range of entries to be inserted.

The generated output depends on the specified format parameters.

Parameter:***LogFileName:***

Name of the logfile to be read.

entryrange:

Range of log data to send. See chapter 2.4.6.6 for details.

templates:

Predefined logfile formats:

- CSV:** "character separated values", e.g. for easy Excel import.
- HTML:** Logdata will be formatted as HTML table
- XML:** Logfile will be send as XML file

header

flags="Nold,NoDate,NoTime,NoNames,NoSec,UseAlias,CRC16,CRC32"

- Nold:** removes the ID of each entry (only for none XML structures)
- NoDate:** removes the Date of each entry (only for none XML structures)
- NoTime:** removes the Time of each entry (only for none XML structures)
- NoNames:** removes the first row with variable names (only for none XML structures)
- NoSec:** removes the seconds within the time stamp
- UseAlias:** adds the variable alias names to the XML logfile output
- CRC16:** calculates a CRC16 checksum (decimal) over the logfile output (excluding headers) and writes it under the data (only for CSV).
CRC16 calculation:
Width: 16Bit
Polynomial: 0x1021
Init Value: 0x0000
Reflection: In/Out deactivated
XOR Out: 0x0000

- CRC32:** calculates a CRC32 checksum (decimal) over the logfile output (excluding headers) and writes it under the data (only for CSV).
CRC32 calculation:
Width: 32Bit
Polynomial: 0x04C11DB7
Init Value: 0xFFFFFFFF
Reflection: In/Out deactivated
XOR Out: 0x00000000

interval:

Expected log interval. If the time between two log entries exceeds the **tolerance** interval, an entry with the content of **string** will be added with the timestamp of the last entry + **interval**.

Can be used to create a fixed log content length if the Tixi Device was switched off or the logging was stopped for a while.

tolerance:

Maximum time between two log entries before **string** will be added.

string: String added to the log output if **tolerance** interval was exceeded (only for CSV format).

variables:

List of variables (separated by comma) to be selected for logfile output. The variable names must match the tag names of the record entries.

Formats:

- tabstart** string which will be added at the beginning of the file
maximum length: 30 chars
default: (empty)

<i>tabend</i>	string which will be added to the end of the file maximum length: 30 chars default: (empty)
<i>tagstart</i>	string which will be added in front of each value. maximum length: 30 chars default: “
<i>tagend</i>	string which will be added to the end of each value. maximum length: 30 chars default: “
<i>colsep</i>	string which will be added between the values (between tagend and tagstart). maximum length: 30 chars default: ;
<i>rowstart</i>	string which will be added in front of the first value (in front of tagstart). maximum length: 30 chars default: (empty)
<i>rowend</i>	string which will be added to the end of the last value (after tagend). maximum length: 30 chars default: (CRLF)
<i>rowsep</i>	string which will be added between two rows (in front of rowstart). maximum length: 30 chars default: (empty)
<i>cols</i>	defines the number of columns after which a line break (rowend/rowstart) will be made. Usefull to distribute devices to several lines of a CSV file. auto: number of columns equal number of record entries (default) 0...32768 number of columns
<i>crCText</i>	string added in front of the CRC

Attention: If you enter a rowend character, the default CRLF will be replaced. To get each log entry in a seperate line, you'll have to add the CRLF (
) manually to the end of the rowend character, e.g. if you like to get an exclamation mark as rowend, enter this:

```
rowend="!&#x0d;&#x0a;"
```

Message Examples:**Logged Data:**

```

<ID_7 _="2002/10/10,16:10:00">
  <Data1 _="Logged Data1"/>
  <Data2 _="Logged Data2"/>
  <Data3 _="Logged Data3"/>
</ID_7>

<ID_8 _="2002/10/10,16:20:03">
  <Data1 _="Logged Data1"/>
  <Data2 _="Logged Data2"/>
  <Data3 _="Logged Data3"/>
</ID_8>

```

Example 1:

Send the entries with the IDs 7 – 8, remove ID and use CSV format:

```

<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_" range="ID_7-ID_8"
      flags="NoId" type="CSV"/>
  </Message_0>
</UserTemplates>

```

Message Body result:

```

Date;Time;Data1;Data2;Data3
2002/10/10;16:10:00;Logged Data1;Logged Data2;Logged Data3
2002/10/10;16:20:03;Logged Data1;Logged Data2;Logged Data3

```

Example 2:

Send the entries with the IDs 7 – 8, remove ID, remove date and time stamp seconds and use CSV format with comma as character separator (for english Excel) :

```

<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_0" range="ID_7-ID_8"
      flags="NoId,NoDate,NoSec" type="CSV" colsep=","/>
  </Message_0>
</UserTemplates>

```

Message Body result:

```

Date,Time,Data1,Data2,Data3
16:10,Logged Data1,Logged Data2,Logged Data3
16:20,Logged Data1,Logged Data2,Logged Data3

```

Example 3:

Send the entries with the IDs 7 – 8, remove ID, Date, Time, Names, use HTML format:

```

<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_0" range="ID_7-ID_8"
      flags="NoId,NoDate,NoTime,NoNames" type="HTML"/>
  </Message_0>
</UserTemplates>

```


Message Body result (Web browser view):

Logged Data1	Logged Data2	Logged Data3
Logged Data1	Logged Data2	Logged Data3

HTML-code:

```
<table border=1>
  <tr>
    <td>Logged Data1</td>
    <td>Logged Data2</td>
    <td>Logged Data3</td>
  </tr>
  <tr>
    <td>Logged Data1</td>
    <td>Logged Data2</td>
    <td>Logged Data3</td>
  </tr>
</table>
```

Example 4:

Send the entry with the ID 8, remove ID, Date, Time, Names and use user defined format:

```
<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_0" range="ID_8"
      flags="NoId,NoDate,NoTime,NoNames" tagstart="#"
      tagend="#" colsep="+" rowstart="-" rowend="-&#x0a;&#xod; "/>
  </Message_0>
</UserTemplates>
```

Message Body result:

```
-#Logged Data1#+#Logged Data2#+#Logged Data3#-
```

Example 5:

Send all entries, remove ID and date and create dummy entries if there are entries missing according to the log interval of 5 minutes:

```
<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_0" range="all"
      flags="NoId,NoDate" type="CSV" fillInterval="5m"
      maxInterval="305s" fillText="-;-;- " />
  </Message_0>
</UserTemplates>
```

Message Body result:

```
Date;Time;Data1;Data2;Data3
16:10:00;Logged Data1;Logged Data2;Logged Data3
16:15:00;-;-;-
16:20:03;Logged Data1;Logged Data2;Logged Data3
```

Example 6:

Send all entries in XML format and add variable alias names:

```
<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_0" range="all"
      flags="UseAlias" type="XML"/>
  </Message_0>
</UserTemplates>
```

Message Body result:

```
<ID_7 _="2002/10/10,16:10:00">
  <Data1 _="Logged Data1" Name="Alias name for Data1"/>
  <Data2 _="Logged Data2" Name="Alias name for Data2"/>
  <Data3 _="Logged Data3" Name="Alias name for Data3"/>
</ID_7>

<ID_8 _="2002/10/10,16:20:03">
  <Data1 _="Logged Data1" Name="Alias name for Data1"/>
  <Data2 _="Logged Data2" Name="Alias name for Data2"/>
  <Data3 _="Logged Data3" Name="Alias name for Data3"/>
</ID_8>
```

Example 7:

Send all entries of variables "Data1" and Data3", remove ID and date and calculate a CRC32:

```
<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_0" range="all"
      flags="NoId,NoDate,CRC32" crcText="CRC32=" type="CSV"
      Viewset="Data1,Data3"/>
  </Message_0>
</UserTemplates>
```

Message Body result:

```
Date;Time;Data1;Data3
16:10:00;Logged Data1;Logged Data3
16:20:03;Logged Data1;Logged Data3
CRC32=2481894213
```

Example 8:

Send the entries with the IDs 7 – 8, remove ID and names and use CSV format with one column:

```
<UserTemplates>
  <Message_0>
    <IncludeLogTXT _="Datalogging_" range="ID_7-ID_8"
      flags="NoId,NoNames" type="CSV" cols="1"/>
  </Message_0>
</UserTemplates>
```

Message Body result:

```
2002/10/10;16:10:00;Logged Data1
2002/10/10;16:10:00;Logged Data2
2002/10/10;16:10:00;Logged Data3
2002/10/10;16:20:03;Logged Data1
2002/10/10;16:20:03;Logged Data2
2002/10/10;16:20:03;Logged Data3
```

4.6.1 Predefined format tags

	CSV	XML	HTML
tabstart		<TABLE>\r\n	<table border=1>\r\n
tabend		</TABLE>\r\n	</table>\r\n
tagstart		<T v="	<td>
tagend		"/>\r\n	</td>\r\n
rowstart		<TAG>\r\n	<tr>\r\n
rowend	\r\n	</TAG>\r\n	</tr>\r\n
colsep	;		

(\r = Carriage Return, \n = Line Feed)

4.6.2 Sending logfiles as attachment

You can use the IncludeLogTXT message text template within a special UserTemplates group called "Attachments". This will create an email file attachment of the logged data. The email attachment will be base64 coded.

The Attachments attribute must be added to the MessageJobTemplate:

Database path: /TEMPLATE/MessageJobTemplates

```
<MessageJobTemplates>
  <LogfileMail _="SMTP">
  <Recipient _="/D/AddressBook/TaskForcel"/>
  <Sender _="/D/AddressBook/MySelf"/>
  <Body _="/UserTemplate/LogfileMsg"/>
  <Subject _="Logfile"/>
  <Attachments _="/D/UserTemplates/Attachments/Datalogging_0"/>
</MessageJobTemplates>
```

This Attachment format has to be configured in a special attachments group inside the UserTemplates database:

Database path: /TEMPLATE/UserTemplates

```
<Attachments>
  <Attachment_Set>
    <Attachment filename="file">
      <Content/>
      <Content/>
    </Attachment>
    <Attachment filename="file">
      <Content/>
      <Content/>
    </Attachment>
  ...
</Attachment_Set>
</Attachments>
```

Example:

```
<Attachments>
  <Datalogging_0>
    <Attachment filename="Datalogging_0.csv">
      <IncludeLogTXT _="Datalogging_0" range="previous 1 days"
        flags="NoId" type="CSV"/>
    </Attachment>
  <Datalogging_0>
</Attachments>
```

Some email programs, e.g. newer versions of “Outlook” or “OutlookExpress” are deleting CSV attachments automatically for security reasons. You can disable this function by changing the security settings of these programs (see email program manual).

4.7 Logfile Counter

The Tixi Device automatically creates log counters within system properties path `/LogCounter/Logfilename` (see chapter 12).

- Each logfile entry increases the counter value by 1.
- The current value can be changed (e.g. reset to 0) by “set” command (see chapter 2.4.6.5).
- The log counter will be reset to 0 if a logfile is added/removed to the log configuration
- The log counter will be reset to 0 if the logfile size is changed

5 Remote Control

5.1 Overview

Remote control must be separated in two different connection types.

- Remote control of the Tixi Device
- Remote control of a device attached to a Tixi Alarm Modem
-

The following chapters describe these two cases in detail. Read the chapter 'Remote Control of the Tixi Device' first because the remote control of the attached device is based on this chapter.

5.2 Remote Control of the Tixi Device

The following pictures show the communication ways when controlling Tixi Device by remote.

Remote control (remote configuration) via PSTN/GSM/ISDN:



Remote control (remote configuration) via LAN/Internet:



In these configurations the desktop PC controls the remote Tixi Device by means of the TiXML protocol. To do this the following steps are required:

1. The Desktop PC needs to **establish a connection** to the remote device. This may be a dialup connection via modem (ISDN/PSTN/GSM) using the phone number of the Tixi Alarm Modem or a TCP/IP connection via LAN/WLAN, GPRS or internet using the IP address of the Tixi Device.
2. **Login** to the remote Tixi Device. (see chapter 0)
3. Control the remote Tixi Device by means of **TiXML**. (see chapter 2.4.6ff)
4. The remote connection is terminated by the **Logout** command. (see chapter 0)

5.3 Remote Control of an attached device

The following picture shows the communication ways where the device attached to the remote Alarm Modem is controlled by the desktop PC.



In this case the programming tool of the attached device (PLC, meter, etc.) is used. The connection is established in two main steps.

1. **Establish a remote control connection** to the Tixi Alarm Modem as described in the previous chapter.
2. Send the **TransMode command** to switch the remote Tixi Alarm Modem to the Transparent Mode (see chapter 2.4.6.1).


The attached device can now be controlled by the desktop PC by accessing the COM port of the dialing modem.

Such a connection can only be closed by a modem disconnection. To do this, the desktop PC sends the modem escape sequence ("+++") or the line is interrupted, e.g. by switching of the dialing modem.


6 Process I/O Ports and Variables

6.1 Introduction

The Tixi Device can use its on board or extension I/Os as well as variables of a connected PLC to signal states of connected systems.



To handle the changes of I/Os and PLC variables the 'Process' subsystem is part of the Tixi Device firmware. The following picture shows how it triggers the event processing.



The process detects the changes of variables, e.g. the analog input which is mapped to the process variable path `/Process/MB/A/AI/P0`.

This leads to a processing of the Event States which may refer to the ProcessVariable database with RPN (reverse polish notation) instructions to check event conditions, e.g. to compare the actual temperature with a threshold.

The Event States then triggers an Event Handler to process event commands, e.g. sending a message.

Sending a message starts the Job Generator which creates the jobs in the same way as if the events were received as DoOn commands from a client device (e.g. PC).

The EventStates remember whether an event was already activated or not. Therefore, only the change of the process variable from FALSE to TRUE starts the event. To fire the same event at a later time, the process variable must change from TRUE to FALSE before and then from FALSE to TRUE again.

The following sections describe the configuration of the processing in detail.

6.2 Event States

EventStates are used to trigger EventHandler depending on the flank change of an associated variable. The variable may be bit variable (e.G. I/O) or the bit result of a process variable. Variable values greater than 1 will be interpreted as 1 (TRUE).

The maximum amount of EventStates is 100.

There are two different ways to assign an event to a process variable:

- With use of the ProcessVars database (chapter 6.2), which is slower but more flexible and allows logical operations and comparisons.
- Without use of ProcessVars database, which is much faster but doesn't support logical operations and comparisons.

Database path: /PROCCFG/EventStates

```

<EventStates>
  <Alarm_0>
    <Enabled _="TRUE" />
    <ProcessVar _="/Process/PV/Alarm_0_ProcVar" flank="high" />
    <Event _="Alarm_0">
      <Barn _="12" />
      <Temperature _="10" />
    </Event>
  </Alarm_0>
</EventStates>

```

Diagram labels:

- Event States Group (points to the root <EventStates> tag)
- Event State (points to the <Alarm_0> tag)
- Associated Process Variable (points to the <ProcessVar _="/Process/PV/Alarm_0_ProcVar" flank="high" /> tag)
- EventHandler (points to the <Event _="Alarm_0"> tag)

Event State Configuration

Syntax:

```

<EventStateName>
  <Enabled _="EnableState" />
  <ProcessVar _="ProcessPath" flank="State" />
  <Event _="EventName">
    ParameterList
  </Event>
</EventStateName>

```

Description:

Attribute group which defines an event state.

Elements:

EventStateName:

Name of the event state which must be unique inside this group.

EnableState:

Only checked after SetConfig or system start, no dynamic change possible.

TRUE	The event state is enabled, event will be triggered.
FALSE	The event state is disabled, event will not be triggered.
FAST	The Event is processed immediately after checking it's EventState (with TRUE a list of changed EventStates will be created first).
1	same as TRUE
0	same as FALSE

ProcessPath:

Path to a variable defined in the "/Process/" tree of the system properties (chapter 12).

State:

high	Event is triggered if associated variable changes from 0 to 1
low	Event is triggered if associated variable changes from 1 to 0
both	Event is triggered on every logical change (0 to1 or 1 to 0) of associated variable.

EventName:

Name of the event triggered if condition (process variable flank) is fulfilled.

Note: There must be an Event Handler of the same name defined.

ParameterList:

List of XML encoded parameters. A parameter is written in a single XML- tag with:

```
<ParameterKey _="Value" />
```

where

ParameterKey name of the Parameter (unique in the parameter list)

Value value of the Parameter.

These parameters are passed to the Event and can be referred using

®~/ParameterKey (see chapter 3.1.1).

Example:

Event state configuration that triggers the EventHandler "Alarm_0" if the process variable Alarm_0_ProcVar changes from 0 to 1. Two parameters are passed to the event and can be used within its context e.g. for message text variables.

```
<Alarm_0>
  <Enabled _="TRUE" />
  <ProcessVar _="/Process/PV/Alarm_0_ProcVar" />
  <Event _="Alarm_0">
    <Barn _="12" />
    <Temperature _="10" />
  </Event>
</Alarm_0>
```

6.3 Process Variables

Typically a system like a Tixi Device checks the state of a system. This system is called the 'process'. The process is described by 'Process Variables' representing the state of the process. Each Process Variable should get a meaningful name which must be unique inside the configuration.

The value of the process variable can be a manually set value as well as calculated from the values of the I/O ports or PLC variables on access or on trigger. For example, a signal input can be linked with another input that indicates that the process power is on, so the input signal is only valid if both conditions are met.

The general characteristics are defined in the '**PROCCFG**' database. The database contains some attribute groups inside the group ProcessVars. Each group has the name of the process variable it defines.

You may create an independent variable which may be used as a marker (memory) for integer values or strings (up to 20 characters). Use of 50 independent variables is possible. A default value and output format is optional.

If a value source can not be resolved, an alternative value may be given separated by comma, e.g.:

```
<LD _="/Process/Bus1/Device_0/Variable_0,10"/>
```

The following example shows three different types of process variables:

Database path: /PROCCFG/ProcessVars

```
<ProcessVars>
  <Alarm_0_PV>
    <Value>
      <LD _="/Process/MB/IO/I/P0"/>
    </Value>
  </Alarm_0_PV>
  <Counter>
    <Process>
      <LD _="/Process/PV/CounterValue"/>
      <ADD _="1"/>
      <ST _="/Process/PV/CounterValue"/>
    </Process>
  </Counter>
  <CounterValue def="0"/>
</ProcessVars>
```

Process Variable name

Value calculated on access

Calculation triggered by EventHandler "Process"

Independent variable

Process Variable Configuration

Syntax:

```
<ProcessVariableName exp="Exponent" format="FormatString"
def="Value">
  <Type precision="Precision">
    RPN Instruction List
  </Type>
</ProcessVariableName>
```

Description:

Attribute group which defines a process variable.
The data type of calculated process variables is Int32 (see 6.5.1)

Elements:

ProcessVariableName:

Name of the process variable. Must be unique in this database and must not be an instruction name.

Exponent:

Exponent of base 10 to specify fix point precision of
simpleType = Uint8, Uint16, Uint32, Int8, Int16, Int32 (see 6.5.1).
The stack value will be multiplied by 10^{Exp} to get the process variable value.

$$\text{value process variable} = 10^{Exp} * \text{stack value}$$

The exponent therefore specifies the position of comma within a fix point value.

Following values are possible:

Exp value	Description
-6	Precision = 0,000001
-5	Precision = 0,00001
-4	Precision = 0,0001
-3	Precision = 0,001
-2	Precision = 0,01
-1	Precision = 0,1
0	Precision = 1 (default
1	Precision = 10
2	Precision = 100
3	Precision = 1000
4	Precision = 10000
5	Precision = 100000
6	precision = 1000000

FormatString:

String that defines the value output format.

For a list of available format option see chapter 6.5.

Value:

Default value of process variable. Only available for independent process variables (no type specified).

The decimal places of the default value are defining the exponent.

If no decimal places but a fixed point format are given, the exponent is defined by the decimal places of the fixed point format. Therefore we recommend to always specify an exponent if you use a fixed point format with decimal places.

Type:

Defines the calculation method:

- Value** Calculated during EventStates processing, "Get" command or "LD" in another Process Variable.
Pay attention on the command order inside an instruction list!
- Process** Calculated on EventHandler Process (see chapter 3.7.1)

Precision:

Defines the precision of the RPN instructions (option).

If no precision is specified, the stack result will have the same precision as the first loaded value (exp/precision of source).

Following values are possible:

precision value	Description
-6	Precision = 0,000001
-5	Precision = 0,00001
-4	Precision = 0,0001
-3	Precision = 0,001
-2	Precision = 0,01
-1	Precision = 0,1
0	Precision = 1 (default
1	Precision = 10

2	Precision = 100
3	Precision = 1000
4	Precision = 10000
5	Precision = 100000
6	precision = 1000000

RPN Instruction List

List of RPN instructions calculating the value of the process variable.

Example:

Process variable that negates the status of input P0:

```
<Alarm_0_PV>
  <Value>
    <LDN _="/Process/MB/IO/I/P0" />
  </Value>
</Alarm_0_PV >
```

Process Variable loading a Tixi Device analog value to reformat the displayed value.

```
<Alarm_1_PV format="F2,1;V">
  <Value>
    <LDN _="/Process/MB/A/AI/P0" />
  </Value>
</Alarm_1_PV>
```

Process Variable loading a Tixi Device analog value with exponent.

```
<Alarm_2_PV exp="-2">
  <Value>
    <LDN _="/Process/MB/A/AI/P0" />
  </Value>
</Alarm_2_PV>
```

Independent process variable with default value.

```
<VariableInit def="250">
```

6.3.1 RPN Instruction List

The RPN Instruction List is a FORTH (<http://www.forth.org/>) program that calculates the value of a Process Variable. Its notation is similar to the Instruction List language used by PLCs. The calculation of the value therefore works like that in PLCs using a simple calculation stack.

Database path: /PROCCFG/ProcessVars

```
<ProcessVars>
  <Alarm_0_PV>
    <Value>
      <LD _="/Process/MB/IO/I/P0" />
      <LD _="/Process/MB/IO/I/P1" />
      <LD _="/Process/MB/IO/I/P2" />
      <OR/>
      <AND/>
    </Value>
  </Alarm_0_PV>
</ProcessVars>
```


Instruction List

The instructions are adding, replacing or moving item of the stack.

The following example shows the stack operation:

```
LD A      ; Load Bit A
LD B      ; Load Bit B
LD C      ; Load Bit C
OR        ; C or B
AND       ; (C or B) and A
```

This program reads the three bit variables A, B and C. Then the upper two stack items C and B are combined by an OR operation. Then the residual upper two stack items (result of B+C as well as A) are combined by an AND operation. The result is 1.



The stack has a maximum size of 10 items. If an error occurs (stackoverflow, stackunderflow) the result value is 0.

If there are several values left on the stack after calculation, only the value on the top will be used for processing or during "Get" command.

6.3.1.1 Logical instructions

INPUT	A	0	0	1	1	1234	4321	0
	B	0	1	0	1	4321	0	1234
OUTPUT	LD A	0	0	1	1	1234	4321	0
	NOT A	1	1	0	0	0	0	1
	LDN A	1	1	0	0	0	0	1
	DLDN A	-1	-1	-2	-2	-1235	-4322	-1
	A AND B	0	0	0	1	1	0	0
	A DAND B	0	0	0	1	192	0	0
	A ANDN B	0	0	1	0	0	1	0
	A DANDN B	0	0	1	0	1042	4321	0
	A OR B	0	1	1	1	1	1	1
	A DOR B	0	1	1	1	5363	4321	1234
	A ORN B	1	0	1	1	1	1	0
	A DORN B	-1	-2	-1	-1	-4130	-1	-1235
	A XOR B	0	1	1	0	0	1	1
	A DXOR B	0	1	1	0	5171	4321	1234
	A XORN B	1	0	0	1	1	0	0
	A DXORN B	-1	-2	-2	-1	-5172	-4322	-1235

LD - Load value

Syntax:
`<LD _="SystemProperty" exp="Exponent" />`

Description:
 Loads the value defined by the system property path to the top of the processing stack. If the value type is "float", only the fixed part is loaded.

Elements:

SystemProperty:
 Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Exponent:
 See chapter 6.3. An exponent within LD instruction may be necessary for constants used for operations with variables which already have an exponent (e.g. PLC variables).

Examples:

Load the bit value "1" of the first digital input of a Tixi Device.

```
<LD _="/Process/MB/IO/I/P0"/>
```

Stack result: 1

Load the word value 1234 of a PLC variable.

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

Stack result: 1234

Load several PLC variables with value Variable_0=10, Variable_1=0, Variable_2=3.

```
<LD v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"
v3="/Process/Bus1/Device_0/Variable_2"/>
```

Stack items:

3
0
10

Stack result: 3

Load constant "13" to the top of the stack.

```
<LD _="13"/>
```

Load constant "0.013" to the top of the stack.

```
<LD _="13" exp="-3"/>
```

LDN/NOT - Load value and logically negate**Syntax:**

```
<LDN _="SystemProperty"/>
or
<NOT _="SystemProperty"/>
```

Description:

Reads the value defined by the address and loads its logical negation at the top of the processing stack.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value "0" of the first Tixi Device digital input and loads its logical negation on the top of the stack.

```
<LDN _="/Process/C40/MB/IO/I/P0"/>
```

Stack result: 1

Reads the word value "1234" of a PLC variable and loads its logical negation on the top of the stack.

```
<LDN _="/Process/Bus1/Device_0/Variable_0"/>
```

Stack result: 0

DLDN/NEG - Load value and binary negate**Syntax:**

```
<DLDN _="SystemProperty"/>
```

Or

```
<NEG _="SystemProperty" />
```

Description:

Reads the value defined by the address and loads the result of a 32bit binary negation at the top of the processing stack.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word value "1234" of a PLC variable and loads the result of its 32bit binary negation on the top of the stack.

```
<DLDN _="/Process/Bus1/Device_0/Variable_0" />
```

"1234" as a 32bit binary value: 00000000000000000000000010011010010

Result of binary negation: 111111111111111111111111101100101101

Stack result: -1235

LDS - Load Special**Syntax:**

```
<LDS _="PLCVariable" AddInfo="ErrorCode" />
```

Description:

Loads the additional info of a PLC variable at the top of the processing stack. The result is a 32bit value calculated by the ErrorClass and ErrorValue of the variable. See PLC-TiXML-Manual for further information.

Elements:**PLCVariable:**

Path to a PLC variable on the /Process/BusX/ system property branch. Not all PLCs do support additional error codes.

ErrorCode:

see PLC-TiXML- Manual

Examples:

Load the ErrorClass and ErrorNumber information of the PLC variable "Variable_0" of "Device_0" on PLC-Bus "Bus1" on the top of the stack.

```
<LDS _="/Process/Bus1/Device_0/Variable_0" AddInfo="Error" />
```

AND - Load value and logically AND with value**Syntax:**

```
<AND v1="SystemProperty" v2="SystemProperty" />
```

Description:

Combination of the instructions LD and AND. It reads the values defined by both addresses. Thereafter a logical AND operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value of the first two Tixi Device digital inputs and loads the result of the logically AND operation on the top of the stack.

```
<AND v1="/Process/MB/IO/I/P0" v2="/Process/MB/IO/I/P0" />
```

or

```

<LD _="/Process/MB/IO/I/P0"/>
<AND _="/Process/MB/IO/I/P1"/>
or
<LD _="/Process/MB/IO/I/P0"/>
<LD _="/Process/MB/IO/I/P1"/>
<AND/>

```

See table on the top of this chapter for logic operation results.

DAND - Load value and binary AND with value

Syntax:

```
<DAND v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD and DAND. It reads the values defined by both addresses. Thereafter a binary AND operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the result of the binary AND operation on the top of the stack.

```

<DAND v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_1"/>

```

or

```

<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DAND _="/Process/Bus1/Device_0/Variable_1"/>

```

or

```

<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<DAND/>

```

"1234" as a 32bit binary value: 00000000000000000000000010011010010

"4321" as a 32bit binary value: 0000000000000000000000001000011100001

Result of binary AND: 0000000000000000000000000000011000000

Stack result: 192

ANDN - Load value and logically AND with negated value

Syntax:

```
<ANDN v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD, LDN and AND. It reads the first addressed value by LD and the second is read inverted by LDN. Thereafter a logical AND operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value of the first two Tixi Device digital inputs whereby the second becomes inverted. The result of the logically AND operation is loaded on the top of the stack.

```
<ANDN v1="/Process/MB/IO/I/P0" v2="/Process/MB/IO/I/P0"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
```



```
<ANDN _="/Process/MB/IO/I/P1" />
```

or

```
<LD _="/Process/MB/IO/I/P0" />
<LDN _="/Process/MB/IO/I/P1" />
<AND/>
```

See table on the top of this chapter for logic operation results.

DANDN - Load value and binary AND with negated value

Syntax:

```
<DANDN v1="SystemProperty" v2="SystemProperty" />
```

Description:

Combination of the instructions LD, DLDN and DAND. It reads the first addressed value by LD and the second is read binary inverted by DLDN. Thereafter a binary AND operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the result of the binary AND operation on the top of the stack.

```
<DANDN v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1" />
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<DANDN _="/Process/Bus1/Device_0/Variable_1" />
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<DLDN _="/Process/Bus1/Device_0/Variable_1" />
<DAND/>
```

"1234" as a 32bit binary value: 000000000000000000000000010011010010

32bit binary negated value of "4321": 111111111111111111110111100011110

Result of binary AND: 000000000000000000000000010000010010

Stack result: 1042

OR - Load value and logically OR with value

Syntax:

```
<OR v1="SystemProperty" v2="SystemProperty" />
```

Description:

Combination of the instructions LD and OR. It reads the values defined by both addresses. Thereafter a logical OR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value of the first two Tixi Device digital inputs and loads the result of the logically OR operation on the top of the stack.

```
<OR v1="/Process/MB/IO/I/P0" v2="/Process/MB/IO/I/P0" />
```

or

```
<LD _="/Process/MB/IO/I/P0" />
<OR _="/Process/MB/IO/I/P1" />
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<LD _="/Process/MB/IO/I/P1"/>
<OR/>
```

See table on the top of this chapter for logic operation results.

DOR - Load value and binary OR with value

Syntax:

```
<DOR v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD and DOR. It reads the values defined by both addresses. Thereafter a binary OR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the result of the binary OR operation on the top of the stack.

```
<DOR v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DOR _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<DOR/>
```

"1234" as a 32bit binary value: 00000000000000000000000010011010010

"4321" as a 32bit binary value: 0000000000000000000000001000011100001

Result of binary OR: 0000000000000000000000001010011110011

Stack result: 5363

ORN - Load value and logically OR with negated value

Syntax:

```
<ORN v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD, LDN and OR. It reads the first addressed value by LD and the second is read inverted by LDN. Thereafter a logical OR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value of the first two Tixi Device digital inputs whereby the second becomes inverted. The result of the logically OR operation is loaded on the top of the stack.

```
<ORN v1="/Process/MB/IO/I/P0" v2="/Process/MB/IO/I/P0"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<ORN _="/Process/MB/IO/I/P1"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<LDN _="/Process/MB/IO/I/P1"/>
<OR/>
```

See table on the top of this chapter for logic operation results.

DORN - Load value and binary OR with negated value

Syntax:

```
<DORN v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD, DLDN and DOR. It reads the first addressed value by LD and the second is read binary inverted by DLDN. Thereafter a binary OR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the result of the binary OR operation on the top of the stack.

```
<DORN v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DORN _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DLDN _="/Process/Bus1/Device_0/Variable_1"/>
<DOR/>
```

```
"1234" as a 32bit binary value:      00000000000000000000000010011010010
32bit binary negated value of "4321": 1111111111111111111111110111100011110
Result of binary OR:                  1111111111111111111111110111110111110
Stack result: -4130
```

XOR - Load value and logically XOR with value

Syntax:

```
<OR v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD and XOR. It reads the values defined by both addresses. Thereafter a logical XOR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value of the first two Tixi Device digital inputs and loads the result of the logically XOR operation on the top of the stack.

```
<XOR v1="/Process/MB/IO/I/P0" v2="/Process/MB/IO/I/P0"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<XOR _="/Process/MB/IO/I/P1"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<LD _="/Process/MB/IO/I/P1"/>
<XOR/>
```

See table on the top of this chapter for logic operation results.

DXOR - Load value and binary XOR with value

Syntax:

```
<DOR v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD and DXOR. It reads the values defined by both addresses. Thereafter a binary XOR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the result of the binary XOR operation on the top of the stack.

```
<DXOR v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DXOR _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<DXOR/>
```

"1234" as a 32bit binary value: 00000000000000000000000010011010010

"4321" as a 32bit binary value: 0000000000000000000000001000011100001

Result of binary XOR: 0000000000000000000000001010011110011

Stack result: 5363

XORN - Load value and logically XOR with negated value

Syntax:

```
<XORN v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD, LDN and XOR. It reads the first addressed value by LD and the second is read inverted by LDN. Thereafter a logical XOR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the bit value of the first two Tixi Device digital inputs whereby the second becomes inverted. The result of the logically XOR operation is loaded on the top of the stack.

```
<XORN v1="/Process/MB/IO/I/P0" v2="/Process/MB/IO/I/P0"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<XORN _="/Process/MB/IO/I/P1"/>
```

or

```
<LD _="/Process/MB/IO/I/P0"/>
<LDN _="/Process/MB/IO/I/P1"/>
<XOR/>
```

See table on the top of this chapter for logic operation results.

DXORN - Load value and binary XOR with negated value

Syntax:

```
<DANDN v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Combination of the instructions LD, DLDN and DXOR. It reads the first addressed value by LD and the second is read binary inverted by DLDN. Thereafter a binary XOR operation between these two items is done and the result of the operation is written on the top of the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Reads the word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the result of the binary XOR operation on the top of the stack.

```
<DXORN v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DXORN _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DLDN _="/Process/Bus1/Device_0/Variable_1"/>
<DXOR/>
```

"1234" as a 32bit binary value: 00000000000000000000000010011010010

32bit binary negated value of "4321": 111111111111111111110111100011110

Result of binary XOR: 111111111111111111110101111001100

Stack result: -5172

6.3.1.2 Stack operations

MPS – Multiply stack

Syntax:

```
<MPS/>
```

Description:

Multiplies a stack value to use it for two operations.



Elements:

none

Examples:

Reads the bit value of the first Tixi Device digital input, multiply it and set two output ports.

```
<LD _="/Process/MB/IO/I/P0"/>
<MPS/>
```

```
<ST _="/Process/MB/IO/Q/P0"/>
<ST _="/Process/MB/IO/Q/P1"/>
```


MRD – Copy 2nd stack level to top of stack

Syntax:

```
<MRD/>
```

Description:

Replaces the value on the top of the stack with the value from the second stack level.



Elements:

none

Examples:

Load value 2 and 5 on the stack, MRD the second stack level (value 2) over the first stack level (value 5). The result of the ADD operation is 4 (2+2) because value 5 was replaced by value 2.

```
<LD _=" 2 " />
<LD _=" 5 " />
<MRD/>
<ADD/>
```

MPP – Remove value at the top of stack

Syntax:

```
<MPP/>
```

Description:

Removes the value on the top of the stack.



Elements:

none

Examples:

Reads the bit values of the first two Tixi Device digital inputs. MPP removes the top stack level value (which is input P1). Therefore the value of input P0 will be written to output P0.

```
<LD _="/Process/MB/IO/I/P0"/>
<LD _="/Process/MB/IO/I/P1"/>
<MPP/>
<ST _="/Process/MB/IO/Q/P0"/>
```

CPY – Copy value

Syntax:

```
<CPY _="SystemProperty"/>
```

Description:

Copies the value at the top of the processing stack to the given system property address. The stack remains unchanged.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12).

Examples:

Copy the value of input P0 to output P0 and P1.


```
<LD _="/Process/MB/IO/I/P0"/>
<CPY _="/Process/MB/IO/Q/P0"/>
<CPY _="/Process/MB/IO/Q/P1"/>
```

SWP – swap values**Syntax:**

```
<SWP />
```

Description:

It swaps the two values at the top of the processing stack.

**Elements:**

none

Examples:

Reads the bit values of the first two Tixi Device digital inputs. SWP swaps the upper two stack items. Therefore the value of input P0 will be written to output P0.

```
<LD _="/Process/MB/IO/I/P0"/>
<LD _="/Process/MB/IO/I/P1"/>
<SWP/>
<ST _="/Process/MB/IO/Q/P0"/>
```

ST - Store**Syntax:**

```
<ST _="SystemProperty" />
```

Description:

Stores the value from the top of the processing stack to the given system property address. The stored value becomes removed from the stack.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12).

Examples:

Store the value of input P0 to output P0.

```
<LD _="/Process/MB/IO/I/P0"/>
<ST _="/Process/MB/IO/Q/P0"/>
```

6.3.1.3 Comparison instructions

INPUT	A	0	0	1	-1	1
	B	0	1	0	1	-1
OUTPUT	A GT B	0	0	1	1	0
	A GTI B	0	0	1	0	1
	A LT B	0	1	0	0	1
	A LTI B	0	1	0	1	0
	A EQ B	1	0	0	0	0
	A NE B	0	1	1	1	1
	A GE B	1	0	1	1	0
	A GEI B	1	0	1	0	1
	A LE B	1	1	0	0	1
	A LEI B	1	1	0	1	0
	A MIN B	0	0	0	1	1
	A MINI B	0	0	0	-1	-1
	A MAX B	0	1	1	-1	-1
	A MAXI B	0	1	1	1	1

GT/GTI – greater than (unsigned values) / (signed values)

Syntax:

```
<GT v1="SystemProperty" v2="SystemProperty" />
<GTI v1="SystemProperty" v2="SystemProperty" />
```

Description:

Compares both values. If v1 is greater than v2, a 1 will be written to the top of the processing stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word value Variable_0=1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<GT v1="/Process/Bus1/Device_0/Variable_0" v2="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<GT _="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="100"/>
<GT/>
```

Result: 1 (TRUE)

Compares the signed word value Variable_0=-1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<GTI v1="/Process/Bus1/Device_0/Variable_0" v2="-100"/>
```

Result: 0 (FALSE)

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the logical result (0/1) of the comparison on the top of the stack.

```
<GT v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

Result: 0 (FALSE)

LT/LTI – less than (unsigned values) / (signed values)**Syntax:**

```
<LT v1="SystemProperty" v2="SystemProperty" />
<LTI v1="SystemProperty" v2="SystemProperty" />
```

Description:

Compares both values. If v1 is less than v2, a 1 will be written to the top of the processing stack.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word value Variable_0=1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<LT v1="/Process/Bus1/Device_0/Variable_0" v2="100" />
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<LT _="100" />
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<LD _="100" />
<LT />
```

Result: 0 (FALSE)

Compares the signed word value Variable_0=-1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<LTI v1="/Process/Bus1/Device_0/Variable_0" v2="-100" />
```

Result: 1 (TRUE)

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the logical result (0/1) of the comparison on the top of the stack.

```
<LT v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1" />
```

Result: 1 (TRUE)

EQ – equal**Syntax:**

```
<EQ v1="SystemProperty" v2="SystemProperty" />
```

Description:

Compares both values. If v1 is equal v2, a 1 will be written to the top of the processing stack.

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word value Variable_0=1234 of a PLC with a constant value and

loads the logical result (0/1) of the comparison on the top of the stack.

```
<EQ v1="/Process/Bus1/Device_0/Variable_0" v2="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<EQ _="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<LD _="100"/>
```

```
<EQ/>
```

Result: 0 (FALSE)

Compares the signed word value Variable_0=-1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<EQ v1="/Process/Bus1/Device_0/Variable_0" v2="-1234"/>
```

Result: 1 (TRUE)

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the logical result (0/1) of the comparison on the top of the stack.

```
<EQ v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

Result: 0 (FALSE)

NE – not equal

Syntax:

```
<NE v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Compares both values. If v1 is not equal v2, a 1 will be written to the top of the processing stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word value Variable_0=1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<NE v1="/Process/Bus1/Device_0/Variable_0" v2="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<NE _="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<LD _="100"/>
```

```
<NE/>
```

Result: 1 (TRUE)

Compares the signed word value Variable_0=-1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<NE v1="/Process/Bus1/Device_0/Variable_0" v2="-1234"/>
```

Result: 0 (FALSE)

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the logical result (0/1) of the comparison on the top of the stack.

```
<NE v1="/Process/Bus1/Device_0/Variable_0"
```

```
v2="/Process/Bus1/Device_0/Variable_1"/>
```

Result: 1 (TRUE)

GE/GEI – greater equal (unsigned values) / (signed values)

Syntax:

```
<GE v1="SystemProperty" v2="SystemProperty"/>
```

```
<GEI v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Compares both values. If v1 is greater than or equal v2, a 1 will be written to the top of the processing stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word value Variable_0=1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<GE v1="/Process/Bus1/Device_0/Variable_0" v2="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<GE _="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<LD _="100"/>
```

```
<GE/>
```

Result: 1 (TRUE)

Compares the signed word value Variable_0=-1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<GEI v1="/Process/Bus1/Device_0/Variable_0" v2="-1234"/>
```

Result: 1 (TRUE)

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the logical result (0/1) of the comparison on the top of the stack.

```
<GE v1="/Process/Bus1/Device_0/Variable_0"
```

```
v2="/Process/Bus1/Device_0/Variable_1"/>
```

Result: 0 (FALSE)

LE/LEI – less equal (unsigned values) / (signed values)

Syntax:

```
<LE v1="SystemProperty" v2="SystemProperty"/>
```

```
<LEI v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Compares both values. If v1 is less than or equal v2, a 1 will be written to the top of the

processing stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word value Variable_0=1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<LE v1="/Process/Bus1/Device_0/Variable_0" v2="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<LE _="100"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<LD _="100"/>
```

```
<LE/>
```

Result: 0 (FALSE)

Compares the signed word value Variable_0=-1234 of a PLC with a constant value and loads the logical result (0/1) of the comparison on the top of the stack.

```
<LEI v1="/Process/Bus1/Device_0/Variable_0" v2="-1234"/>
```

Result: 1 (TRUE)

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the logical result (0/1) of the comparison on the top of the stack.

```
<LE v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

Result: 1 (TRUE)

MIN/MINI – minimum (unsigned values) / (signed values)

Syntax:

```
<MIN v1="SystemProperty" v2="SystemProperty"/>
```

```
<MINI v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Compares both values and removes the greater one from the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the lesser value on the top of the stack.

```
<MIN v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<MIN _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
```

```
<LD _="/Process/Bus1/Device_0/Variable_1"/>
```

```
<MIN/>
```

Result: 1234

Compares the signed word values Variable_0=1234 and Variable_2=-4321 of a PLC and loads the lesser value on the top of the stack.

```
<MINI v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_2"/>
```

Result: -4321

MAX/MAXI – maximum (unsigned values) / (signed values)

Syntax:

```
<MAX v1="SystemProperty" v2="SystemProperty"/>
<MAXI v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Compares both values and removes the lesser one from the stack.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Examples:

Compares the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the greater value on the top of the stack.

```
<MAX v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<MAX _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<MAX/>
```

Result: 4321

Compares the signed word values Variable_0=1234 and Variable_2=-4321 of a PLC and loads the lesser value on the top of the stack.

```
<MAXI v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_2"/>
```

Result: 1234

6.3.1.4 Math operations

If the input value is a signed value or the math operation may result in a signed value, a signed value operation (ADDI/SUBI/MULI/DIVI) must be used.

INPUT	A	1234	4321	1234	-1234	-4321
	B	4321	1234	-4321	4321	-1234
OUTPUT	ADD A B	5555	5555			
	ADDI A B	5555	5555	-3087	3087	-5555
	SUB A B		3087			
	SUBI A B	-3087	3087	5555	-5555	-3087
	MUL A B	5332114	5332114			
	MULI A B	5332114	5332114	-5332114	-5332114	5332114
	DIV A B	0	3			

	DIV1 A B	0	3	0	0	3
--	-----------------	----------	----------	----------	----------	----------

ADD/ADDI – addition (unsigned values) / (signed values)**Syntax:**

```
<ADD v1="SystemProperty" v2="SystemProperty" />
<ADDI v1="SystemProperty" v2="SystemProperty" />
```

Description:

Adds the second stack value to the first stack value and replaces them with the result to the operation.

Value = v1 + v2

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

If the system property is a signed value or the operation may result in a signed value, ADDI must be used.

Examples:

Adds the unsigned word value Variable_1=4321 to Variable_0=1234 of a PLC and loads the result on the top of the stack.

```
<ADD v1="/Process/Bus1/Device_0/Variable_0"
v2="/Process/Bus1/Device_0/Variable_1" />
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<ADD _="/Process/Bus1/Device_0/Variable_1" />
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<LD _="/Process/Bus1/Device_0/Variable_1" />
<ADD />
```

Result: 5555

Adds the signed word value Variable_2=-1234 to Variable_1=4321 of a PLC and loads the result on the top of the stack.

```
<ADDI v1="/Process/Bus1/Device_0/Variable_1"
v2="/Process/Bus1/Device_0/Variable_2" />
```

Result: 3087

SUB/SUBI – subtraction (unsigned values) / (signed values)**Syntax:**

```
<SUB v1="SystemProperty" v2="SystemProperty" />
<SUBI v1="SystemProperty" v2="SystemProperty" />
```

Description:

Subtracts the second stack value from the first stack value and replaces them with the result to the operation.

Value = v1 - v2

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

If the system property is a signed value or the operation may result in a signed value, SUBI must be used.

Examples:

Subtracts the unsigned word value Variable_1=1234 from Variable_0=4321 of a PLC and loads the result on the top of the stack.

```
<SUB v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<SUB _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<SUB/>
```

Result: 3087

Subtracts the signed word value Variable_3=-1234 from Variable_2=-4321 of a PLC and loads the Result on the top of the stack.

```
<SUBI v1="/Process/Bus1/Device_0/Variable_2"
       v2="/Process/Bus1/Device_0/Variable_3"/>
```

Result: -5555

MUL/MULI – multiplication (unsigned values) / (signed values)**Syntax:**

```
<MUL v1="SystemProperty" v2="SystemProperty"/>
<MULI v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Multiplicates v1 by v2 and writes the result to the top of the stack.

Value = v1 * v2

Elements:**SystemProperty:**

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

If the system property is a signed value or the operation may result in a signed value, MULI must be used.

Examples:

Multiplicates the unsigned word values Variable_0=1234 and Variable_1=4321 of a PLC and loads the Result on the top of the stack.

```
<MUL v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<MUL _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<MUL/>
```

Result: 5332114

Multiplicates the signed word values Variable_0=1234 and Variable_2=-4321 of a PLC and loads the Result on the top of the stack.

```
<MULTI v1="/Process/Bus1/Device_0/Variable_0"
      v2="/Process/Bus1/Device_0/Variable_2"/>
```

Result: -5332114

DIV/DIVI – division (unsigned values) / (signed values)

Syntax:

```
<DIV v1="SystemProperty" v2="SystemProperty"/>
<DIVI v1="SystemProperty" v2="SystemProperty"/>
```

Description:

Divides v1 by v2 and writes the result to the top of the stack.

Value = $v1 / v2$

If the result is a real number, the value will be displayed as a rounded value, if the origin values do not have a decimal part.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

If the system property is a signed value or the operation may result in a signed value, DIVI must be used.

Examples:

Divides the unsigned word value Variable_0=4321 by Variable_1=1234 of a PLC and loads the Result on the top of the stack.

```
<DIV v1="/Process/Bus1/Device_0/Variable_0"
     v2="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<DIV _="/Process/Bus1/Device_0/Variable_1"/>
```

or

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<LD _="/Process/Bus1/Device_0/Variable_1"/>
<DIV/>
```

Result: 3

Divides the signed word value Variable_2=-4321.0 by Variable_1=1234.0 of a PLC and loads the Result on the top of the stack.

```
<DIVI v1="/Process/Bus1/Device_0/Variable_2"
      v2="/Process/Bus1/Device_0/Variable_1"/>
```

Result: -3.5

6.3.1.5 Time instruction

TIME - Compare Time Span with current Time

Syntax:

```
<TIME _="YYYY/MM/DD,HH:MM:SS-YYYY/MM/DD,HH:MM:SS" />
```

Description:

Compare the current system time with the given time span and loads a 1 on the top of the stack if the current time lies within the given range.

The span may be defined by dates, times or both.

Elements:**YYYY:***year [1970...2038]***MM:***month [01...12]***DD:***day [01...31]***HH:***hour [00..23]***MM:***minute [00..59]***SS:***second [00..59]***Examples:**

System time: 2008/12/19,11:48:30

Check the time span between 11:00 and 12:00.

`<TIME _="11:00:00-12:00:00"/>`

Result: 1 (TRUE)

Check the time span between 10:00 and 12:00 at 2008/12/20 to 2008/12/21.

`<TIME _="2008/12/20,10:00:00-2008/12/21,12:00:00"/>`

Result: 0 (FALSE)

Check the date between 2008/12/18 to 2008/12/21.

`<TIME _="2008/12/18-2008/12/21"/>`

Result: 1 (TRUE)

6.3.1.6 Power-on/off delay instruction***D_ON / D_OFF – Power-on/off delay*****Syntax:**`<D_ON time="X"/>``<D_OFF time="X"/>`**Description:**

Waits the defined time to accept a status as true.

Elements:**X: *Time to wait***

For time parameters, see chapter 3.1.2

Examples:

If the service button is pressed for at least 10s, the result of the process variable becomes 1.

`<LD _="/Process/MB/PollButton"/>``<D_ON time="10s"/>`

If the service button is released, after 10s the result of the process variable becomes 1.

`<LD _="/Process/MB/PollButton"/>``<D_OFF time="10s"/>`

6.3.1.7 IF instructions

IFEQ – IF equal condition

Syntax:

```
<IFEQ _="SystemProperty" />
  Instructions
<ELSE/>
  Instructions
<ENDIF/>
```

Description:

Instructions will only be processed if the stack value is equal the condition value, otherwise the instructions following the ELSE condition become processed.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Instructions:

List of instructions

Examples:

If PLC Variable_0 is equal 33, Tixi Device digital input P0 will be set; otherwise input P1 will be set.

```
<LD _="/Process/Bus1/Device_0/Variable_0" />
<IFEQ _="33" />
  <LD _="1" />
  <ST _="/Process/MB/IO/Q/P0" />
<ELSE/>
  <LD _="1" />
  <ST _="/Process/MB/IO/Q/P1" />
<ENDIF/>
```

IFNE – IF not equal condition

Syntax:

```
<IFNE _="SystemProperty" />
  Instructions
<ELSE/>
  Instructions
<ENDIF/>
```

Description:

Instructions will only be processed if the stack value is not equal the condition value, otherwise the instructions following the ELSE condition become processed.

Elements:

SystemProperty:

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12). May also be a constant.

Instructions:

List of instructions

Examples:

If PLC Variable_0 is not equal 33, Tixi Device digital input P0 will be set; otherwise input P1 will be set.

```
<LD _="/Process/Bus1/Device_0/Variable_0"/>
<IFNE _="33"/>
  <LD _="1"/>
  <ST _="/Process/MB/IO/Q/P0"/>
<ELSE/>
  <LD _="1"/>
  <ST _="/Process/MB/IO/Q/P1"/>
<ENDIF/>
```

6.3.1.8 Text parser instruction**MID – text parser****Syntax:**

```
<MID _="String" start="X" length="Y"/>
```

Description:

Loads part of a string from position start to length.

Note: The result must be a number.

Elements:**String:**

String to parse. If the string is a system property, the reference must be made using the reference string: `®` (see chapter 3.1.1)

X: Start position

0 first character

If X is larger then length of string, parser starts at end of string.

Y: text length**Examples:**

Extract the “hour” out of the Tixi Device “Time” string:

```
<MID _="&#xae;/TIMES/Time" start="0" length="2"/>
```

or

```
<LD start="0"/>
```

```
<LD length="2"/>
```

```
<MID _="&#xae;/TIMES/Time"/>
```

6.3.1.9 Bit mask instruction

MSK – bit mask with logical result

Syntax:

```
<MSK v1="SystemProperty" v2="mask" />
```

Description:

MSK is used to mask one or several bits of a given byte, word or dword variable. If at least one masked bit is set, the result is 1, otherwise 0.

Elements:

SystemProperty

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12).

mask: (decimal value)

value of the mask.

- 1 mask for bit 1
- 2 mask for bit 2
- 3 mask for bit 1 OR 2
- 4 mask for bit 3
- 5 mask for bit 1 OR 3
- etc...

Examples

Masks the unsigned word value Variable_1=1234 of a PLC by mask 7 and loads the logical result on the top of the stack.

```
<MSK v1="/Process/Bus1/Device_0/Variable_1" v2="7" />
```

```
1234 = 00000000000000000000000010011010010
```

```
7 = 000000000000000000000000000000000111
```

```
Result = 1
```

DMSK – bit mask with binary result

Syntax:

```
<DMSK v1="SystemProperty" v2="mask" />
```

Description:

DMSK is used to mask one or several bits of a given byte, word or dword variable. The result of the operation is the sum of all bits set within the mask (same as DAND).

Elements:

SystemProperty

Path to a system property, e.g. I/O, PLC variable, database entry or system variable (see chapter 12).

mask: (decimal value)

value of the mask.

- 1 mask for bit 1
- 2 mask for bit 2
- 3 mask for bit 1 OR 2
- 4 mask for bit 3
- 5 mask for bit 1 OR 3
- etc...

Before you call the " Find_Bit_Address" instruction, the specified number of variables must be loaded on the stack, otherwise the instruction results in an error.

CountMask:

Masks the bits to count in a stack value.

value of the mask.

- 1 mask for bit 1
- 2 mask for bit 2
- 3 mask for bit 1 OR 2
- 4 mask for bit 3
- 5 mask for bit 1 OR 3
- etc...

Examples:

Define two process variables.

Load Variable_0=1234 and Variable_1=4321 from a PLC and find the first bit set (according to the mask) in the first process variable and the second bit set in the second process variable.

```

<Alarm_0_ProcVar>
  <Value>
    <LD _="/Process/Bus1/Device_0/Variable_1"/>
    <LD _="/Process/Bus1/Device_0/Variable_0"/>
    <FIND_BIT_ADDRESS _="1" range="2" mask="64302"/>
  </Value>
</Alarm_0_ProcVar>

<Alarm_1_ProcVar>
  <Value>
    <LD _="/Process/Bus1/Device_0/Variable_1"/>
    <LD _="/Process/Bus1/Device_0/Variable_0"/>
    <FIND_BIT_ADDRESS _="2" range="2" mask="64302" />
  </Value>
</Alarm_1_ProcVar>

```

Variable_0 is the variable on the top of the stack, because it is loaded after Variable_1.

Using the mask 64302 we get following bit addresses:

Mask 64302:	1 1 1 1 1	0	1 1	0 0	1	0	1 1 1	0
Variable_0:	11 10 09 08 07	-	06 05	- -	04	-	03 02 01	-
Variable_1:	22 21 20 19 18	-	17 16	- -	15	-	14 13 12	-
Variable Values:								
Variable_0 =	0 0 0 0 0	1	0 0	1 1	0	1	0 0 1	0
Variable_1 =	0 0 0 1 0	0	0 0	1 1	1	0	0 0 0	1

Result:

Alarm_0_ProcVar = 1 (first set bit within mask)

Alarm_1_ProcVar = 15 (second set bit within mask)

6.3.1.11 FORTH instruction

FORTH – FORTH instruction

Syntax:

```
<FORTH _="Instruction" />
```

Description:

Offers the possibility to use FORTH instructions. See <http://www.forth.org/> for information about the FORTH language.

Elements:

Instruction:

FORTH source code

Examples:

Conversion of the GPS NMEA longitude "1316114.990234" into WGS84 format:

```
<Alarm_0_ProcVar format="F9.5">
  <Value>
    <LD _="/Process/Bus1/Device_0/Variable_0"/>
    <FORTH _="drop 1 100000 */mod 100000 * swap 100 * 60 / + 0"/>
  </Value>
</Alarm_0_ProcVar >
```

Result: 13.26856

6.3.2 RPN Error Codes

The "Get" command together with the `AddInfo="Error"` attribute can be used to read the error state of a process variable (see chapter 2.4.6.5).

Following error codes may occur:

Code	Description
-217	the interpreter encountered a syntax error
-218	error - stack underflow
-219	error converting number (maybe undefined)
-220	error reading value (group/key not found)
-221	error writing value (group/key not found, ReadOnly)
-222	stack overflow
-223	variable exists, but is undefined

6.4 Access I/Os and Variables

Most variables of the system properties `"/Process/"` tree can be read and even set by the Get and Set commands. You can also refer to variables in the message text or any other part of the TiXML project code.

6.4.1 Refer to variable values

You can refer to the current state of the I/Os or the value of a ProcessVariable in a message text or most other project code elements by inserting an appropriate reference. Because these variables are part of the system state, they are also part of the system properties.

See chapter 3.1.1 and 3.8 for further information.

You can also use variables to change connections between configuration elements, e.g. a variable may be used to change a MessageJobTemplate recipient path to select different recipients (Contact_0 or Contact_1) depending on the variable value:

```

<Alarm_0 _="SMTP">
  <Recipient _="/D/AddressBook/Contact_&#xae;/Process/MB/IO/I/P0;" />
  <Sender _="/D/AddressBook/MySelf" />
  <Body _="/UserTemplates/Message_0/Body" />
  <Subject path="/UserTemplates/Message_0/Subject" />
</Alarm_0>

```

This may also be used to select alarm messages in different languages, different websites and much more.

6.4.2 Read variable values

Using TiXML you can read the current state of an I/O or variable by the Get command. See chapter 2.4.6.5 for further information.

Chapter 11 contains an overview of the correct I/O addresses according to the different Tixi Devices.

Note: An open Tixi Device input is indicated by a "1", a closed input port by a "0".

6.4.3 Set outputs, Process- and PLC Variables

Output ports and independent ProcessVariables can be set by the Set command. See chapter 2.4.6.5 for further information.

Set Output Port

Syntax:

```
<Set _="/Process/Address/PortType/Port" value="Value" />
```

Description:

Set the status of the output port addressed by the PortAddress to the given value. See chapter 11 for supported addresses.

Elements:

Address:

Address to the output hardware

MB/IO	mainboard
C40...C4E	extension modules

PortType:

Addressing scheme (bit / byte / word / dword):

Port Type	Range
Q	0,1
QB	0...255
QW	0... 65.535
QD	0... 4.294.967.295

Port:

Address of the port
P0...P12

Value:

Value to set. (0=open or 1=closed contacts)

Examples:

Close the contacts of relay P2 of the Tixi Device mainboard.

```
<Set _="/Process/MB/IO/Q/P2" value="1" />
```

Open the contacts of output P2 of the extension module with address C42.

```
<Set _="/Process/C42/Q/P2" value="0" />
```


Close the contacts of the first and the second part of the module with the address C40 and open the ports with the index P2-P7.

```
<Set _="/Process/C40/QB/P0" value="3" />
```

Set ProcessVariable

Syntax:

```
<Set _="Address" value="Value" />
```

Description:

Set the value of the ProcessVariable addressed by "Address".

Elements:

Address:

Path to a process variable within the /Process/PV/ tree of the system properties.

Value:

Value to set. (string or number)

Examples:

Set the ProcessVariable "Alarm_0_ProcVar" to value "23":

```
<Set _="/Process/PV/Alarm_0_ProcVar" value="23" />
```

Set the ProcessVariable "Shiftworker" to value "Contact_0":

```
<Set _="/Process/PV/Shiftworker" value="Contact_0" />
```

Set PLC Variable

Syntax:

```
<Set _="Address" value="Value" />
```

Description:

Set the value of the PLC Variable addressed by "Address".

Elements:

Address:

Path to a PLC variable within the /Process/ tree of the system properties.

Value:

Value to set. (string or number)

Examples:

Set the PLC Variable "Variable_0" from "Device_0" at "Bus1" to value "23":

```
<Set _="/Process/Bus1/Device_0/Variable_0" value="23" />
```

6.5 Variable data types and formats

6.5.1 Variable data types

Following data types (attribute "simpleType") are used within the Tixi Device variable processing:

simpleType	Description
UInt8	unsigned 8 Bit value (0...255)
UInt16	unsigned 16 Bit value (0...65535)
UInt32	unsigned 32 Bit value (0...4294967295)

Int8	signed 8 Bit value (-128...+127)
Int16	signed 16 Bit value (-32768...32767)
Int32	signed 32 Bit value (-2147483648...2147483647)
String	text (0...n characters)
Bit	digital value (0...1)
Float	Floating point single precision ($\pm 3.402823466 \cdot 10^{38}$)
Double	Floating point double precision ($\pm 1.7976931348623158 \cdot 10^{308}$)

6.5.2 Variable data formats

Without any formatting the value of I/Os, Process-, System- and PLC variables will be shown natively. The Tixi Device is able to reformat the displayed value into a number format, to replace the status of a Boolean variable with a string and much more. The reformatted value will be used within the text processing (chapter 3.8) and for "Get" commands. Datalogging and Webserver have their own format attributes; the format of the External and ProcessVars database has no function there.

Example:

```
<Variable_0 _="I" ind="1" acc="R" format="R10F+4,2;&#xb0;C"/>
```

Variable_0 is an integer value "1234", but with the format string the displayed value will look like this:

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
<Get _="+12,34°C"/>
```

Formatting display value of variables

Syntax:

On PLC variable definition:

```
<Variable ... simpleType="Uint8" exp="2" format="Elements;Text"/>
```

On process variable definition:

```
<ProcessVariable format="Elements;Text"/>
```

On Datalogging Record:

```
<ValueName _="Type" size="Length" format="Elements;Text"/>
```

On query of variable value:

```
<Get _="/Process/PV/Alarm_0_ProcVar" format="Elements;Text"/>
```

Description:

The parameter `format` persists of two parts separated by **semicolon**:

1.part "Elements":

Contains **Format-Elements** to describe the in- and output of values. Except thousand limiter „T“ and number format „F“ the format elements can not be combined. The position of the thousand delimiter within format instruction can be chosen at will. The format depends on the type of variable. Not every format is available for all types of variables. The availability of a format element depends on the attribute „simpleType“ of the variablen definition. Therefore the valid basic types are given within this discription. The first part may be left empty to show the native values.

2.part "Text" (option):

Contains a **Text** to be displayed together with the value. Within this text the value may be displayed using its given format of part 1. The position of the value is defined by `%%`, or will be displayed at the beginning, if `%%` is left. For some variables additional values (e.g. physical medium and unit) may be included. The second part may be left empty too. In this case no semicolon is necessary.

Example:

```
Element and Text:  "T'F+9,2 ;Radius %% cm"
Only Element:     "R16"
Only Text:        "; Text with:%% as value"
```

A Conditional format allows several sets of both parts "Elements;Text " depending on the variable value:

Syntax:

```
{=Condition1}Format1{=Condition2}Format2...{=ConditionN}FormatN{ }DefaultFormat
```

The curly brackets enclose the condition value to be compared with the variable value. If the variable value is equal the first condition value, the subsequent format instruction will be used. Otherwise the next condition value will be compared. If no condition matches the variable value, the default format (empty condition "{}") will be used.

Note:

The `Text` part of the condition format requires `%%` to define the position of the value. If `%%` is not specified, the value will not be displayed.

Example:

```
"{=1.28}F.1;%%kW{=2.00};-.-{ }F"
with variable value 1.28: 1.2kW
with variable value 2.00: -.-
with variable value 1.18: 1.18
```

Format elements (Part 1):

? - logical alternative `?string1,string2`

This command is used to replace value by two predefined strings.

If the variable is not zero string1 is displayed, otherwise string2 (boolean format).

Available for following simpleType values:

Bit, UInt8, UInt16, UInt32, Int8, Int16, Int32

Example:

```
<Variable_0 simpleType="Uint8" [...] format="?open,closed"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable"/>
```

Tixi Device answers:

```
<Get _="open"/> on value 1
```

*** - case alternative *Value1:Text1*Value2:Text2** :Text3**

This command is used to replace a value by several predefined strings.

If the variable value is equal "Value1", "Text1" is displayed, if the variable value is equals "Value2", "Text2" is displayed etc; on every other value Text3 is displayed.

***** separator for values to detect (The number of values is not limited.)

****** separator for all other values

Available for following simpleType values:

Uint8, Uint16, Uint32, Int8, Int16, Int32 (with exp="0" only)

Example:

```
<Variable_0 simpleType="Uint8" exp="0" [...]
format="*0:low*1:medium*2:high** :faulty" />
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers:

```
<Get _="low" /> on value 0
```

```
<Get _="medium" /> on value 1
```

```
<Get _="high" /> on value 2
```

```
<Get _="faulty" /> on value 7
```

R/r - Basis Rn/rn

This command defines the basis n of the value.

n = 2 binary output (e.g. 01101010)

n = 8 octal output (e.g. 21057)

n = 10 decimal output (default, e.g. 1234)

n = 16 hexadecimal output (e.g. AE03)

The upper/lower case display of hex letters (A-F) can be specified:

R Only upper case letters (e.g. AE03)

r Only lower case letters (e.g. ae03)

Available for following simpleType values:

Uint8, Uint16, Uint32, Int8, Int16, Int32 (with exp="0" only)

Example:**HEX:**

```
<Variable_0 simpleType="Uint8" exp="0" [...] format="R16"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (variable value=90):

```
<Get _="5A"/>
```

Binary:

```
<Variable_0 simpleType="Uint8" exp="0" [...] format="R2"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (variable value=90):

```
<Get _="1011010"/>
```

T – thousand delimiter **T_n**

Defines the thousand delimiter.

n= , comma (e.g. 12,345,678)

n= . dor (e.g. 12.345.678)

n= ` apostrophe (e.g. 12`345`678)

n= empty no thousand delimiter (default)

Note:

Can be used in combination with number format element „F“.

Available for following simpleType values:

Uint8, Uint16, Uint32, Int8, Int16, Int32, Float, Double

Example:

```
<Variable_0 simpleType="Uint32" [...] format="T."/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (variable value=98765):

```
<Get _="98.765"/>
```

F - number format

This command defines the format of the number value.

It includes several subitems, which have to be in the given order:

F "sign" "padding" "field width" "decimal point" "fixed point numbers"

sign:

Defines, if a sign should be displayed

+ the sign is displayed, even if the value is positive (e.g. „+12.3“ , „-12.3“)

- the sign is only displayed, if the value is negative (e.g. „12.3“ , „-12.3“)

empty the value is unsigned

padding:

Defines, how empty positions have to be filled (requires "field width")

0 empty positions are filled with zeros (e.g. 0066.3)

empty empty positions are cut off (e.g. 66.3)

field width:

Maximum size of the number value output, **including** sign, thousand delimiter, decimal point and the value itself. If omitted, the field width is not limited (and no insertion of padding characters takes place). **Always define enough characters, otherwise the value will be cut off on the left side!**

decimal point:

Character used as decimal separator (option)

- , a comma is used as decimal separator
- . a dot is used as decimal separator (default)

fixed point numbers:

Number of digits behind the decimal separator. Can be omitted, if no decimal point separator is given.

Note:

Can be used in combination with thousand delimiter format element „T“.

Available for following simpleType values:

UInt8, UInt16, UInt32, Int8, Int16, Int32, Float, Double

Examples:**sign:**

```
<Variable_0 simpleType="Int16" [...] format="F+"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (Value = 12345):

```
<Get _="+12345"/>
```

Padding, field width:

```
<Variable_0 simpleType="UInt32" exp="-3" [...] format="F09"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (Value = 123456):

```
<Get _="00123.456"/>
```

Thousand delimiter, sign, field width, decimal point, fixed point numbers:

```
<Variable_0 simpleType="Int32" [...] format="T'F+9,2"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (Value = 123456):

```
<Get _="+1'234,56"/>
```

S – string format S_n

Defines the length of a string value.

n number of character to display

Available for following simpleType values:

String

Example:

```
<Variable_0 simpleType="String" [...] format="S3"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (variable value=ABCDEFGF):

```
<Get _="ABC" />
```

Text (part 2):

%%

Defines the position of the value within the output string.

This part is available for all types of data. It is the only format option for data type „String“.

Example:

```
<Variable_0 simpleType="Int32" exp="-2" [...]
    format="F+;Temp: %%K" />
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (Value = 12345):

```
<Get _="Temp: +123.45K"/>
```

%M% – M-Bus Medium (VIF)

%U% – M-Bus Unit (VIF)

Adds the M-Bus (Meterbus) Value Information Field data to the displayed value.

Example:

```
<Variable_0 simpleType="meterbus" exp="-2" [...]
    format=";Medium:%M% value=%% %U%"/>
```

```
<Get _="/Process/Bus1/Device_0/Variable_0"/>
```

Tixi Device answers (Variable value=2530, Heat volume flow):

```
<Get _="Medium:Heat value=25.30 Volume Flow [l/h]"/>
```

6.6 Analog input

Some Tixi Devices offer an analog input 0-10V (12bit).

To convert the value (0-4095, 10V=3798) corresponding to the measured voltage, the “periphery” configuration can be used, which is part of the PROCCFG database. Without this configuration the modem automatically converts the values from 0-10000 (10V=10000).

Database path: /PROCCFG/Periphery

Periphery – Analog input

Syntax:

```
<Periphery>
  <Module Name="ADC 1*12bit" Address="Module">
    <Numerator _="Numerator" />
    <Denominator _="Denominator" />
    <Tolerance _="Tolerance" />
    <Rate _="Rate" />
  </Module>
</Periphery>
```

Description:

Configuration of the analog input to convert the measured value.

Elements:**Module:**

Interface address, e.g. analog input on mainboard: "C9a"

Numerator:

Number on top of the fraction to be multiplied by the measured value.

Denominator:

Number on bottom of the fraction to be multiplied by the measured value (must be >0).

Tolerance:

Changes to be ignored by the analog input relative to converted value. (Default 50)

Rate:

Sample rate to refresh the analog input value. (Default 1000)

Examples:**a) Display 10 at 10V**

If you want to get a range 0-10 (10V=10), there are two solutions:

Periphery

Use the periphery to adjust the range:

$$10V = 3798 * (10/3798)$$

```
[<SetConfig _="PROCCFG" ver="v">
<Periphery>
  <Module Name="ADC 1*12bit" Address="C9a">
    <Numerator _="10"/>
    <Denominator _="3798"/>
    <Tolerance _="1"/>
    <Rate _="1000"/>
  </Module>
</Periphery>
</SetConfig>]
```

ProcessVar (see chapter 6.3)

OR load the AI into a process variable to define decimal places using the „format“ option (10V = 10,000):

```
[<SetConfig _="PROCCFG" ver="v">
<ProcessVars>
  <AI format="F,3">
    <Value>
      <LD _="/Process/MB/A/AI/P0"/>
    </Value>
  </AI>
</ProcessVars>
</SetConfig>]
```

b) Display 30 at 10V

If you want to get a range 0-30 (10V=30), there are two solutions:

Periphery

Use the periphery to adjust the range:

$$10V = 3798 * (30/3798)$$

```
[<SetConfig _="PROCCFG" ver="v">
```



```

<Periphery>
  <Module Name="ADC 1*12bit" Address="C9a">
    <Numerator _="30"/>
    <Denominator _="3798"/>
    <Tolerance _="1"/>
    <Rate _="1000"/>
  </Module>
</Periphery>
</SetConfig>]

```

ProcessVar (see chapter 6.3)

OR load the AI into a process variable and use math operations for the calculation

$$10V = 10000/1000*3$$

```

[<SetConfig _="PROCCFG" ver="v">
<ProcessVars>
  <AI>
    <Value>
      <LD _="/Process/MB/A/AI/P0"/>
      <DIV _="1000"/>
      <MUL _="3"/>
    </Value>
  </AI>
</ProcessVars>
</SetConfig>]

```

c) Display 500 at 3V

If you want to get a range 0-500 (3V=500), there are two solutions:

Periphery

Use the periphery to adjust the range:

$$3V = 3798*(3/10)*(500/(3798*(3/10))) = 1139,4*(500/1139,4) = 11394*(5000/11394)$$

```

[<SetConfig _="PROCCFG" ver="v">
<Periphery>
  <Module Name="ADC 1*12bit" Address="C9a">
    <Numerator _="5000"/>
    <Denominator _="11394"/>
    <Tolerance _="1"/>
    <Rate _="1000"/>
  </Module>
</Periphery>
</SetConfig>]

```

ProcessVar (see chapter 6.3)

OR load the AI into a process variable and use math operations for the calculation

$$3V = 500 = 3000/6$$

```

[<SetConfig _="PROCCFG" ver="v">
<ProcessVars>
  <AI>
    <Value>
      <LD _="/Process/MB/A/AI/P0"/>
      <DIV _="6"/>
    </Value>
  </AI>
</ProcessVars>
</SetConfig>]

```

6.7 S0-Interface

Some Tixi Devices offer two S0-interfaces which are used to count impulses as defined in the S0-interface standard.

Active S0 devices (power supplied interface) has to be connected to "P+/P-", passive S0 devices has to be connected to "A+/A-" (supplied by modem power).

Impulse length specification:

Minimum: 250µs up to 250µs*255

Maximum: unlimited

The Tixi Device counts these impulses into temporary memory. With a special synchronization event this value will be written into a readable variable which may be used for data logging or event creation.

The S0 counters and related variables are not written into flash memory. To keep the counted values during power lost, they have to be written into ProcessVars (see chapter 6.3).

The Tixi Device offers different S0-interface modes and value conversions which are configured in the periphery group of PROCCFG database.

Database path: /PROCCFG/Periphery

Periphery – S0 interface

Syntax:

```
<Periphery>
  <Module Name="S0 (PIC)" Address="Module">
    <Numerator _="Numerator" />
    <Denominator _="Denominator" />
    <Mode _="0xMode" />
    <Channel0 _="S0-0-length" />
    <Channel1 _="S0-1-length" />
    <TimeScale _="Time" />
  </Module>
</Periphery>
```

Description:

Configuration of the S0-interface mode and value conversion.

Elements:

Module:

Interface address, e.g. S0 interface on mainboard: "C3e" or "I3e"

Numerator:

Number on top of the fraction to be multiplied by the counted impulses.

Denominator:

Number on bottom of the fraction to be multiplied by the counted impulses (must be >0).

Mode:

Defines the S0-interface mode using 3 bits: 0xCBA

Bit C: Defines the synchronization mode (option)

0: synchronization via TimeScale

1: synchronisation via "S0_Sync" event handler command

Bit B: Defines operation mode of S0 channel 1

0: relative counter: on synchronization the counted value will be copied into readable variable and channel counter is reset to 0.

- 1: absolute counter: on synchronization the counted value will be copied into readable variable (no counter reset to 0).

Bit A: Defines operation mode of S0 channel 0

Modes see Bit B.

Valid mode combinations: 000,100,010,110,001,101,011,111

S0-0-length:

Impulse length (ms) on S0-interface S0-0.

S0-1-length:

Impulse length (ms) on S0-interface S0-1.

Time:

Time between two synchronization events (in seconds).

The TimeScale function depends on synchronisation mode:

1. If Bit C is set to 0 the Tixi Device will generate the synchronization by itself in the given TimeScale beginning from system start.
2. If bit C is set to 1, the TimeScale may be ignored (useless).

S0-interface variables:

These variables are created by the system in the process tree under the module address of the S0-interface:

- P0: counted impulses on channel 0 (only if Bit A is <2)
- P1: counted impulses on channel 1 (only if Bit B is <2)
- P2: currently not used
- P3: currently not used
- P4: measured time of last synchronization periode
- P5: event trigger, set to 1 on synchronization (power off delayed)

P0-P1 are always converted using numerator/denominator.

Examples:

1. Channel0 used for counting (absolute), Channel 1 used for counting (relative). No value conversion. Impulse length 30ms (channel0) and 40ms (channel1). Synchronization event created by scheduler every 5 minutes (300s):

```
<Periphery>
  <Module Name="S0 (PIC)" Address="I3e">
    <Numerator _="1"/>
    <Denominator _="1"/>
    <Mode _="0x100"/>
    <Channel0 _="30"/>
    <Channel1 _="40"/>
    <TimeScale _="300"/>
  </Module>
</Periphery>
```

Values on first cycle, after 300 impulses on both interfaces:

P0: 300
P1: 300

P2: ignore
 P3: ignore
 P4: 300 (fixed, because of scheduler)
 P5: 0 (1, if read directly after synchronization)

Values on second cycle, after additional 300 impulses on both interfaces:

P0: 600
 P1: 300
 P2: ignore
 P3: ignore
 P4: 300 (fixed, because of scheduler)
 P5: 0 (1, if read directly after synchronization)

2. Channel0 used for counting (relative), Channel 1 used for counting (relative). Value conversion (impulse * 11.25). Impulse length 30ms. Synchronization event created by TimeScale every 500s after system start:

```
<Periphery>
  <Module Name="S0 (PIC)" Address="I3e">
    <Numerator _="450"/>
    <Denominator _="40"/>
    <Mode _="0x000"/>
    <Channel0 _="30"/>
    <Channel1 _="30"/>
    <TimeScale _="500"/>
  </Module>
</Periphery>
```

Values if 300 impulses counted on channel 0 and 400 impulses on channel 1:

P0: 3375
 P1: 4500
 P2: ignore
 P3: ignore
 P4: 500 (fixed, because of TimeScale synchronization mode)
 P5: 0 (1, if read directly after synchronization)

6.8 Signal LED

On the front of the Hx4xx Tixi Devices a "Signal" LED can be found. This LED can be set to different colors and/or flash cycles manually or by event.

Variable path: /Process/MB/SignalLED

Color	Value	Status
Cyclic		
None	0	off
Red	1	on
	2	blinking (200 ms on, 200 ms off)
	3	blinking (50 ms on, 50 ms off)
	4	blinking (200 ms on, 600 ms off)
	5	blinking (200 ms off, 600 ms on)
	6	blinking 2 time (50ms on, 50ms off) and 600ms off
	7	Flash once every 3 sec
	8	DoubleFlash every 3 sec

Green	9	on
	10	blinking (200 ms on, 200 ms off)
	11	blinking (50 ms on, 50 ms off)
	12	blinking (200 ms on, 600 ms off)
	13	blinking (200 ms off, 600 ms on)
	14	blinking 2 time (50ms on, 50ms off) and 600ms off
	15	Flash once every 3 sec
	16	DoubleFlash every 3 sec
Red/Green	17	blinking 2 time (50ms green, 50ms off, 50ms red, 50ms off) and 600ms off
	18	blinking (200 ms green, 600 ms red)
	19	blinking (200 ms red, 600 ms green)
	20	blinking (200 ms green, 200 ms off, 200 ms red, 200 ms off)
Once		
Red	21	blinking 1 time
	22	blinking for 4 sek (200 ms on, 200 ms off)
	23	blinking 2 time (50ms on, 50ms off)
Green	24	blinking 1 time
	25	blinking for 4 sek (200 ms on, 200 ms off)
	26	blinking 2 time (50ms on, 50ms off)
Red/Green	27	blinking 1 time

Cyclic LED status (0-20) are kept after reset.

Example:

Command to set the signal LED to fast green flashing:

```
[<Set _="/Process/MB/SignalLED" value="14"/>]
```

7 Scheduler

The scheduler can be used to create events at predefined times. These events may be sending status messages or live signals, changing variables or changing database entries e.g. address book entries for shift plans.

7.1 Configuration

Database path: /SCHEDULE/Schedule

```
<Schedule>
```

```
  <Time1 _="Event">
    <Weekday _="Mo,Th"/>
    <Time _="19:00"/>
    <Month not="Jan"/>
  </Time1>
```

```
  <Timer4 _="Event30Min">
    <Minute _="0,30"/>
  </Timer4>
```

```
</Schedule>
```

Scheduler
configuration

Scheduler Configuration**Syntax:**

```
<ScheduleName _="Event" >
  <ScheduleTimes/>
  ...
</ScheduleName>
```

Description:

Attribute group which defines the times of the scheduled event.

If several schedulers are using the same point of time, the EventHandler are triggered in the order of the schedulers (from top to bottom).

Elements:**ScheduleName:**

Name of the schedule.

Event:

Name of the event, triggered when the schedule time is reached.

ScheduleTimes

List of Attributes describing the times when the event is triggered.
(see *times configuration*)

Example:

Scheduler configuration for the "Alarm_0" and "Datalogging_0_Log" event.
The alarm message will be sent each Monday and Thursday at 19:00 but not in January.
The Datalogging_0_Log writes the current port status every 30 minutes into a logfile.

```
<Schedule>
  <Time1 _="Alarm_0">
    <Weekday _="Mo,Th" />
    <Time _="19:00" />
    <Month not="Jan" />
  </Time1>
  <Timer4 _="Datalogging_0_Log">
    <Minute _="0,30" />
  </Timer4>
</Schedule>
```

7.2 Time parameters

Times may be configured as periods e.g. "start-end" or as enumeration e.g. "time1,time2,time3". It is possible to exclude times using "not=" instead of "_=".

Minute**Description:**

Minute inside an hour.

Valid attributes: "0,1,2,3,...,59"

Example:

Every quarter of an hour
<Minute _="0,15,30,45"/>

Every minute

<Minute _="0-59"/>

Hour**Description:**

Hour inside a day.

Valid attributes: "0,1,2,3,...,23"

Example:

Working hours
 <Hour _="9-17" />

Time**Description:**

Exact times in format "h:mm".

Valid attributes:

h: "0,1,2,3...,23"

mm:"00,01,02,....,59"

Example:

at 8:55 and 13:00
 <Time _="8:55,13:00" />

Data**Description:**

Exact Date in format "d.m. [yyyy]". Year is option.

Valid attributes:

d: "1,2,3,....,31"

m: "1,2,3,....,12"

yyyy: "1970,1971,1972,....,2038"

Example:

no german holidays
 <Data not="1.1.,1.5.,3.10.,24.12.-26.12.,31.12." />

Day**Description:**

Day valid for all month.

Valid attributes: "1,2,3,....,31"

Example

First five days of each month
 <Day _="1-5" />

Month**Description:**

Month valid for all years.

Valid attributes: "Jan, Feb, Mar, Apr, May, Jun, Jul, Aug, Sep, Oct, Nov, Dec"
 or "1"- "12".

Example:

February, June and October
 <Month _="Feb,6,Oct" />

Weekday**Description:**

Weekday valid for all weeks.

Valid attributes: "Mo, Tu, We, Th, Fr, Sa, Su"
 or "0" (=Su) – "6" (=Sa).

Example:

Workdays only
 <Weekday _="Mo-Fr" />

Condition**Description:**

Condition is used to refer to other times within /SCHEDULE/condition database.

Example:

<Condition _="Condition/FiveMinutes" />

Example

```
[<SetConfig _="SCHEDULE" ver="y">
<Condition>
  <FiveMinutes>
    <Minute _="0,5,10,15,20,25,30,35,40,45,50,55"/>
  </FiveMinutes>
  <Holidays>
    <Data _="1.1.,1.5.,3.10.,25.12.,26.12."/>
  </Holidays>
  <NoHoliday>
    <Data not="1.1.,1.5.,3.10.,25.12.,26.12."/>
  </NoHoliday>
</Condition>
</SetConfig>]

[<SetConfig _="SCHEDULE" ver="y">
<Schedule>
  <!-- every Monday and Thursday at 19:00, but not in January -->
  <Time1 _="Event">
    <Weekday _="Mo,Th"/>
    <Time _="19:00"/>
    <Month not="Jan"/>
  </Time1>
  <!--Monday to Friday at 8:00-20:00 all 5 minutes but not at holidays -->
  <Time2 _="Event">
    <Weekday not="Sa,Su"/>
    <Hour _="8-20"/>
    <Condition _="Condition/Fiveminutes"/>
    <Condition not="Condition/Holidays"/>
  </Time2>
  <!--Monday to Friday 7:40 to 16:40 all 20 minutes but not at holidays-->
  <Time3 _="Event">
    <Weekday _="Mo-Fr"/>
    <Time _="7:40-16:40"/>
    <Minute _="0,20,40"/>
    <Condition _="Condition/NoHoliday"/>
  </Time3>

  <!-- all 30 minutes -->
  <Timer4 _="Event30Min">
    <Minute _="0,30"/>
  </Timer4>
</Schedule>
</SetConfig>]
```

7.3 ScheduleDefinition

To prevent upload problems of the SCHEDULE database groups (conditions for schedulers missing - vice versa) Tixi.Com has made the decision to redesign the SCHEDULE database. We recommend to use the new structure even if the old format is still supported and used by TILA (Note: don't mix old and new structure!).

The "Schedule" and the "Condition" group are now both part of the "ScheduleDefinition" group inside SCHEDULE database. The structure inside both groups didn't change. Refer to chapters 7.1 and 7.2 for more information.

Database path: /SCHEDULE/ScheduleDefinition

Example:


```
[<SetConfig _="SCHEDULE" ver="y">
<ScheduleDefinition>
  <Schedule>
    <Time2 _="Event">
      <Weekday not="Sa,Su"/>
      <Hour _="8-20"/>
      <Condition _="Condition/Fiveminutes"/>
    </Time2>
  </Schedule>
  <Condition>
    <FiveMinutes>
      <Minute _="0,5,10,15,20,25,30,35,40,45,50,55"/>
    </FiveMinutes>
  </Condition>
</ScheduleDefinition>
</SetConfig>]
```

7.4 Testing

ScheduleTest - Calculates a list of scheduler event times

Syntax:

```
<ScheduleTest _="range" max="maxcount" />
```

Description:

This command returns a list of calculated scheduler event times in a given time range.

Parameter:

range:

"Timestamp1-Timestamp2": scheduled event times between both timestamps
 "Timestamp": scheduled event times from now until timestamp
 "-Timestamp": scheduled event times from now until timestamp
 "Timestamp-": scheduled event times from timestamp to maxcount

Timestamp format: "DD.MM.YYYY[,hh:mm]" or "YYYY/MM/DD[,hh:mm]"

"next N unit" scheduled event times from now until next N units

Units format: "Hours", "Days", "Months", "Years")

maxcount:

Number of scheduler event times to calculate (default: 100).

Return:

If no error (command is processed):

```
<ScheduleTest>
  <SE_1 _="2004/03/04,16:10:00">
    <Event _="Eventname"/>
  </SE_1>
  <SE_2 _="2004/03/04,16:10:00">
    <Event _="Eventname"/>
  </SE_2>

  ...

  <SE_100 _="2004/03/06,09:20:00">
    <Event _="Eventname"/>
  </SE_100>
</ScheduleTest>
```

On error (command is not processed):
see default error frame (chapter 2.4.4)

Examples:

All scheduled event times of the next 14 days, max 100 entries:

```
<ScheduleTest _="next 14 Days"/>
```

All scheduled event times from now until 31.12.2003, max 25 entries:

```
<ScheduleTest _="-31.12.2003" max="25"/>
```

All scheduled event times between 22.8.2003 09:00 and 31.10.2003 22:00, max 100 entries

```
<ScheduleTest _="22.8.2003,9:00-2003/10/31,22:00"/>
```

All scheduled event times starting from 1.1.2004, max 50 entries:

```
<ScheduleTest _="1.1.2004-" max="50"/>
```

8 Sequencer

The scheduler (previous chapter) enables the modem to change values on a point of time. The values have to be part of the set command inside the event handler. To change values more dynamically, a special feature called “sequencer” was implemented.

The sequencer uses different profiles of value lists with points of time to change the values. Each list may have a special priority. The lowest priority (0) will be active always, higher priorities will deactivate the the lower priorities at the given point of time.

The Tixi Device will process these lists sequentially to change the associated variables.

8.1 Configuration

The configuration of the sequencer is part of the SCHEDULE database, group “Sequencer”.

Database path: /SCHEDULE/Sequencer

Sequencer – Profiles

Syntax:

```
<Sequencer>
  <Profilename event="Eventname" logfile="Logfilename" />
</Sequencer>
```

Description:

This configuration enables a sequencer profile and associates an event and logfile to it.

Parameter:

Profilename:

The sequencer may have several profiles for different events. Random names are possible but have to be unique throughout the configuration.

Eventname:

Name of the event handler which will process the sequentially changed values. The event handler has to exist inside EventHandler group (database EVENTS).

Logfilename:

Name of the logfile in which a copy of the profile will be stored during “SetSequence” command. The logfile has to exist inside LogDefinition group (database LOG)

Example:

Sequencer profile which will call the event “Switch_0”. The Profiles will be copied into “Profiles” logfile:

```
<Sequencer>
  <Sequence_0 event="Switch_0" logfile="Profiles" />
</Sequencer>
```

8.2 Changing sequences

The sequencer profiles configured in the previous chapter are empty by default. To define sequencer times and values, the SetSequence command is used:

SetSequence – Defines sequencer event times and values

Syntax:

```
<SetSequence _="Profile" priority="n" mode="format"
  mask="Mask"
  <T date="Date" time="Time" P1="p1" P2="p2" ... P6="p6" />
  ...
</SetSequence>
```

Description:

This command defines the sequencer event times and values. The values will be processed by the associated event handler at the given point of time.

Parameter:

Profile:

Name of profile to be changed. Has to exist inside Sequencer group.

n:

Priority of the sequencer profile. Priority range: 0(low)-255 (high). Only three different priorities per profile are possible. Priority 0 has to be the basic profile. See next chapter to learn more about profile priorities.

format:

The sequencer profiles may be transferred in two different formats:

XML: Data will be transferred in TiXML syntax (default)
 TEXT: Data will be transferred in TEXT format (for profiles with CSV format)

In TEXT format the raw data has to be enclosed by a XML frame:

```
<!CDATA[
  ****Data****
]>
```

Mask:

Defines the data format in TEXT mode (not necessary for XML-mode)

d: Date
 t: Time
 1: Value P1
 ...
 6: Value P6

e.g.

```
mask="d;t;1;2;3;4;5;6"
```

for data in this format:

```
DD.MM.YYYY;hh:mm;P1;P2;P3;P4;P5;P6
01.01.2004;09:15;200;300;400;500;600
```

Date:

Date for the sequenced time of event.

Valid formats:

```
DD.MM
DD.MM.YY
DD.MM.YYYY
YY/MM/DD
YYYY/MM/DD
```

An asterisk "*" or "0" may be used to replace each unit.
E.g. "00.03.00" is same as "*.03.*" which means every day in march every year.

Time:

Point of time for the sequenced event. Format: hh:mm
An asterisk "*" may be used to replace each unit.

p1...p6:

List of values to be processed by sequenced event handler (max 6).
The event handler has to refer to these values via process reference ®~/Px;
(see chapter 3.1.1)

Return:**If no error (command is processed):**

```
<SetSequence />
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Examples:

1. Every day at 09:00 a "minimum" variable (P1) has to be 20, a maximum variable (P2) has to be 80. Every day at 18:00 a "minimum" variable (P1) has to be 30, a maximum variable (P2) has to be 70.

```
[<SetSequence _="LevelProfile" priority="0">
  <T date="*.*.*" time="09:00" P1="20" P2="80"/>
  <T date="*.*.*" time="18:00" P1="30" P2="70"/>
</SetSequence>]
```

Date "*.*.*" will be processed on each day, every month, every year.

Same Example in TEXT format:

```
<SetSequence _="LevelProfile" priority="0" mode="TEXT" mask="d;t;1;2">
  <![CDATA[
    *.*.*;09:00;20;80
    *.*.*;18:00;30;70
  ]]>
</SetSequence>
```

2. Additional to the previous example, both variables should have following values on each day in april:

```
[<SetSequence _="LevelProfile" priority="1">
  <T date="*.04.*" time="09:00" P1="15" P2="85"/>
  <T date="*.04.*" time="18:00" P1="25" P2="75"/>
</SetSequence>]
```

Date "*.04.*" will be processed on each day, in april, every year. Due to the higher priority, the profile of example 1 will be inactive at the given time.

3. Values changes every 15 minutes:

```
[<SetSequence _="PowerProfile" priority="0">
  <T date="*.*.*" time="*:00" P1="10" P2="80"/>
  <T date="*.*.*" time="*:15" P1="20" P2="90"/>
  <T date="*.*.*" time="*:30" P1="30" P2="100"/>
  <T date="*.*.*" time="*:45" P1="20" P2="90"/>
</SetSequence>]
```

To delete a sequence, the sequence definition inside sequencer configuration has to be deleted.

A sequence may also be transferred to the modem via email or Express-Email. See chapter 9 for more information.

8.2.1 Profile priorities

For each sequencer profile a maximum of 3 priorities is allowed:

The sequencer handles the profiles in different ways, related to their priority:

Priority 0:

A sequence with priority 0 will be **replaced** by a sequence with priority 0.


Priority >0

A sequence with priority >0 will be **supplemented** by new data with same priority. All expired entries will be deleted.


If several sequencer events inside a single profile are configured with the same point of time, the sequence with the highest priority will be processed only.

Examples:

A) Between two points of time with higer priority, no lower priorities will be processed:



B) If a sequence with same priority >0 was configured several times, all lower priorities between both sequences will be processed:



8.3 Testing

SequenceTest - Calculates a list sequencer event times

Syntax:

```
<SequenceTest _="Profilename" range="Range" max="maxcount" />
```

Description:

This command returns a list of calculated sequencer event times in a given time range.

Parameter:

Profilename:

Name of profile to be tested. Has to exist inside Sequencer group.

Range:

"Timestamp1-Timestamp2": sequencer event times between both timestamps

"Timestamp": sequencer event times from now until timestamp

"-Timestamp": sequencer event times from now until timestamp

"Timestamp-": sequencer event times from timestamp to maxcount

Timestamp format: "DD.MM.YYYY[,hh:mm]" or "YYYY/MM/DD[,hh:mm]"

"next N unit" scheduled event times from now until next N units

Units format: "Hours", "Days", "Months", "Years")

maxcount:

Number of sequencer event times to calculate (default: 100).

Return:

If no error (command is processed):

```
<SequenceTest>
  <SEQ_1 _="2004/02/04,08:01:00">
    <Event _="Eventname" P1="4" P2="14" P3="" P4=""
      P5="" P6="" />
  </SEQ_1>
  <SEQ_2 _="2004/02/04,08:02:00">
    <Event _="Eventname" P1="5" P2="13" P3="" P4=""
      P5="" P6="" />
  </SEQ_2>
  ...
  <SEQ_100 _="2004/02/04,09:40:00">
    <Event _="Eventname" P1="9" P2="7" P3="" P4=""
      P5="" P6="" />
  </SEQ_100>
</SequenceTest>
```

On error (command is not processed):

see default error frame (chapter 2.4.4)

Examples:

All sequencer event times of the next 14 days, max 100 entries:

```
<SequenceTest _="Sequence_0" range="next 14 Days" />
```

All sequencer event times from now until 31.12.2003, max 25 entries:

```
<SequenceTest _="Sequence_0" range="-31.12.2003" max="25" />
```

All sequencer event times between 22.8.2003 09:00 and 31.10.2003 22:00, max 100 entries

```
<SequenceTest _="Sequence_0" range="22.8.2003,9:00-2003/10/31,22:00"/>
```

All sequencer event times starting from 1.1.2004, max 50 entries:

```
<SequenceTest _="Sequence_0" range="1.1.2004-" max="50"/>
```

8.4 Example

Sequencer logfile definition:

```
[<SetConfig _="LOG">
  <LogFiles>
    <Profiles size="125000"/>
  </LogFiles>
</SetConfig>]
```

Sequencer profile definition:

```
[<SetConfig _="SCHEDULE">
  <Sequencer>
    <Sequence_0 event="Switch_0" logfile="Profiles"/>
  </Sequencer>
</SetConfig>]
```

Event Handler to be triggered by sequencer:

```
<Switch_0>
  <Set _="/Process/Bus1/Device_0/Variable_0" value="&#xae;~/P1;"/>
  <Set _="/Process/Bus1/Device_0/Variable_1" value="&#xae;~/P2;"/>
</Switch_0>
```

Sequencer times and values:

```
[<SetSequence _="Sequence_0" priority="0">
  <T date="*.*.*" time="*:00" P1="10" P2="80"/>
  <T date="*.*.*" time="*:15" P1="20" P2="90"/>
  <T date="*.*.*" time="*:30" P1="30" P2="100"/>
  <T date="*.*.*" time="*:45" P1="20" P2="90"/>
</SetSequence>]
```



9 Processing incoming messages

9.1 Introduction

A Tixi Device can be controlled by received Express-Emails, emails and SMS or by a simple phone call (callerID).

Scenario:

The Tixi Alarm Modem is connected to a PLC with output ports. At the output ports, some actuators are connected by an electrical signal line (for example a fan).



The remote control user sends a SMS including a password (*SECRET*) and a command word (*HEATER_ON*):

```
SECRET FAN_ON
```

The Tixi Device receives the message and triggers an event with the same name as the command word (in the example 'FAN_ON'). This is handled as if received from a client as an event message (DoOn via Command).

Please note that the command name of the incoming SMS message will be converted into upper case, therefore the EventHandler names must be upper case too.

The event is processed according to the commands defined by the corresponding event handler configuration:

Database path: /EVENTS/EventHandler

```
<EventHandler>
  <FAN_ON>
    <Set _="/Process/Bus1/Device_0/Variable_0" value="1"/>
    <SendMail _="MessageJobTemplates/Switch_0"/>
  </FAN_ON>
</EventHandler>
```

The event sets output 'Variable_0' of the connected PLC which starts the connected fan.

Additionally, a message job is started which sends an answer back to the sender of the command, e.g.:

```
OK: FAN_ON
```

9.2 Event via incoming call (callerID)

All Tixi Alarm Modems are able to detect incoming callerIDs using the CLIP service. If a callerID matches an entry in the callerID database, the call will not be answered by the Alarm Modem. Instead it will start processing the event assigned to the callerID.

This may be used to open a garage door just by a simple phone call without any costs for instance.

The callerID database is inside the ISP database.

Database path: /ISP/IncomingCallTrigger

Incoming Call Trigger

Syntax:

```
<IncomingCallTrigger>
  <NoX _="callerID" event="EventName" />
</IncomingCallTrigger>
```

Description:

A list of callerIDs (max. 5) with events which will be processed after this callerID was detected by the Tixi Alarm Modem.

Elements:

x: Entry number. Value 1 - 5

CallerID:

CallerID to be detected by the Tixi Alarm Modem.

Use wildcards "*" to replace a part of the callerID or "?" to replace a single digit.

EventName:

Name of the event to be processed if the callerID was detected.

Example:


Mobile phone number +491721234567 will trigger the event "Switch_0", mobile phone numbers +491727654321 and +491727654355 will trigger the event "Switch_1":

```
[ <SetConfig _="ISP">
  <IncomingCallTrigger>
    <No1 _="+491721234567" event="Switch_0"/>
    <No2 _="+4917276543*" event="Switch_1"/>
  </IncomingCallTrigger>
</SetConfig>]
```

Note: The format of the caller ID depends on the telephone provider. Sometimes the area code is left or "+" is transmitted as "00". Use the Tixi CLIP tool to detect the caller ID format required by the connection of your Alarm Modem.

9.3 Event via incoming message (Express-E-Mail, SMS, Email)

To map an incoming message to an event, the message (subject) must have a special syntax. Example:



An event handler must be configured accordingly to the submitted Event Name (for SMS always upper case!). Like for DoOn command, additional parameters can be used which can be processed in the event handler, the message job template or the message text template.

The following message format is required.

<i>Incoming Message</i>
<u>Syntax:</u>
<i>Password SPACE EventName SPACE Parameter1 SPACE Parameter2...</i>
<u>Description:</u>
Format of the subject line (email, Express-E-Mail) or content (SMS) of an incoming message to trigger an event.
<u>Elements:</u>
<i>Password:</i>
Password to access the device. 1...20 characters (not empty), no SPACE character allowed.
<i>EventName:</i>
Name of the event to be triggered (for SMS upper case!). There must be an event handler configured for this event. 1...20 characters (not empty), XML tag characters only.
<i>Parameter1...Parameter10:</i>
Value of the n'th parameter (no SPACE character, only 29 characters per parameter if using SMS).
<u>Examples:</u>
User password SECRET, trigger the HEATER_ON event and submit the parameter 1.
SECRET HEATER_ON 1

9.3.1 Event parameter generated by an incoming message

Unlike the default events, the event created by incoming messages contains predefined parameters. These parameters can be used to control the Tixi Device or to create an answer message.

The event handling can be tested independently. Therefore, the event messages created by an incoming message can be "simulated" by sending a DoOn message with the events described below. When this test is finished ok, the message to event map could be tested by sending the corresponding incoming messages.

Each message type has its own specific parameter list:

The event generated by incoming message has the following format:

Event created by an incoming message

Syntax:

```
<DoOn _="EventName" >
  <Event _="EventName" />
  <Password _="Password" />
  <Alpha _="SenderAlias" />
  <OA _="OA" />
  <Time _="ReceiveTime" />
  <RemoteSerialNo _="RemoteSerialNo" />
  <RemoteBoxnumber _="RemoteBoxnumber" />
  <RemoteBoxname _="RemoteBoxname" />
  <Text _="MessageText" />
  <P1 _="ValuesOfParameter1" />
  <P2 _="ValuesOfParameter2" />
  <P3 _="ValuesOfParameter3" />
  <P4 _="ValuesOfParameter4" />
  <P5 _="ValuesOfParameter5" />
  <P6 _="ValuesOfParameter6" />
  <P7 _="ValuesOfParameter7" />
  <P8 _="ValuesOfParameter8" />
  <P9 _="ValuesOfParameter9" />
  <P10 _="ValuesOfParameter10" />
</DoOn>
```

Description:

Structure of the event created by an incoming message.

Elements:

EventName:

Event name parsed from received message text.

Password:

Password parsed from received message text.

SenderAlias:

Address of the sender (Express-E-Mail) or alphanumeric representation of the originating address if any stored in the chip card (SMS) or alias name of sender (email).

.OA:

Originating address (callerID) received from telephone network (Express-E-Mail, SMS) or sender address (from field) parsed from received message header (email).

ReceiveTime:

Time stamp received from GSM network (SMS) or Time stamp indicating when the message was received (Express-E-Mail, email).

RemoteSerialNo:

The serial number of the Tixi Device, which sends the message. (Express-E-Mail only)

RemoteBoxnumber:

The phone number of the sending Tixi Device, as defined in the USER database (see chapter 3.2). (Express-E-Mail only)

RemoteBoxname:

The name of the sending Tixi Device, as defined in the USER database (see chapter 3.2). (Express-E-Mail only)

MessageText:

The text from the 'Subject' line of the received message (email, Express-E-Mail) or content of the message (SMS).

P1...P10(optional)

Value of the parameter delivered by the message if any.

Examples:

Event message generated from an incoming Express-E-Mail of this format: SECRET HEATER_ON 1

```
<DoOn ="HEATER_ON">
  <Event _="HEATER_ON"/>
  <Password _="SECRET"/>
  <RemoteSerialNo _="12345"/>
  <RemoteBoxnumber _="+49-30-40608582"/>
  <RemoteBoxname _="Test Tixi Alarm Modem"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="SECRET HEATER_ON 1"/>
  <Alpha _=" TEST+49-30-40608582"/>
  <OA _="03040608582"
  <P1 _="1"/>
</DoOn>
```

Event message generated from an incoming SMS of this format: SECRET HEATER_ON 1

```
<DoOn ="HEATER_ON">
  <Event _="HEATER_ON"/>
  <Password _="SECRET"/>
  <OA _="+491717959463"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="SECRET HEATER_ON 1"/>
  <Alpha _="CON"/>
  <P1 _="1"/>
</DoOn>
```

Event message generated from a received POP3 email with this subject:
SECRET HEATER_ON 1

```
<DoOn _="HEATER_ON">
  <Event _="HEATER_ON" />
  <Password _="SECRET" />
  <OA _="support@tixi.com" />
  <Time _="01/07/20,08:56:33+08" />
  <Text _="SECRET HEATER_ON 1" />
  <Alpha _="support@tixi.com" />
  <P1 _="1" />
</DoOn>
```

9.3.2 System events for invalid incoming messages

In case the message cannot be processed properly, a predefined event is triggered that allows notification of the fault to be given and enables the tracking of intrusion attempts.

Event created on event processing error

Syntax:

```
<DoOn _="System/TixiInvalidEvent">
  ...
  or
<DoOn _="System/SMSInvalidEvent">
  ...
  or
<DoOn _="System/POPInvalidEvent">
  <Event _="EventName" />
  <Password _="Password" />
  <Alpha _="SenderAlias" />
  <OA _="OA" />
  <Time _="ReceiveTime" />
  <RemoteSerialNo _="RemoteSerialNo" />
  <RemoteBoxnumber _="RemoteBoxnumber" />
  <RemoteBoxname _="RemoteBoxname" />
  <Text _="MessageText" />
  <P1 _="ValuesOfParameter1" />
  <P2 _="ValuesOfParameter2" />
  <P3 _="ValuesOfParameter3" />
  <P4 _="ValuesOfParameter4" />
  <P5 _="ValuesOfParameter5" />
  <P6 _="ValuesOfParameter6" />
  <P7 _="ValuesOfParameter7" />
  <P8 _="ValuesOfParameter8" />
  <P9 _="ValuesOfParameter9" />
  <P10 _="ValuesOfParameter10" />
  <ErrNo _="ErrNo" />
  <ErrText _="ErrorText" />
</DoOn>
```

Description:

Structure of the event created by an incoming message which could not be processed. This event corresponds to a DoOn event message. Note that an event handler of that name must exist. The event parameters depend on the type of message.

Elements:***EventName:***

Event name parsed from received message text.

Password:

Password parsed from received message text.

SenderAlias:

Address of the sender (Express-E-Mail) or alphanumerical representation of the originating address if any stored in the chip card (SMS) or alias name of sender (email).

.OA:

Originating address (callerID) received from telephone network (Express-E-Mail, SMS) or sender address (from field) parsed from received message header (email).

ReceiveTime:

Time stamp received from GSM network (SMS) or Time stamp indicating when the message was received (Express-E-Mail, email).

RemoteSerialNo:

The serial number of the Tixi Device, which sends the message. (Express-E-Mail only)

RemoteBoxnumber:

The phone number of the sending Tixi Device, as defined in the USER database (see chapter 3.2). (Express-E-Mail only)

RemoteBoxname:

The name of the sending Tixi Device, as defined in the USER database (see chapter 3.2). (Express-E-Mail only)

MessageText:

The text from the 'Subject' line of the received message (email, Express-E-Mail) or content of the message (SMS).

P1...P10(optional)

Value of the parameter delivered by the message if any.

ErrNo:

Numerical representation of the processing error.

ErrorText:

Textual representation of the processing error.

Examples:

Error event message generated from an incoming Express-E-Mail of this format: SECRET HEATERON 1

```
<DoOn _="System/TixiInvalidEvent ">
  <Event _="HEATERON"/>
  <Password _="SECRET"/>
  <RemoteSerialNo _="12345"/>
  <RemoteBoxnumber _="+49-30-40608582"/>
  <RemoteBoxname _="Test Tixi Alarm Modem"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="SECRET HEATERON 1"/>
  <Alpha _="TEST+49-30-40608582"/>
  <OA _="03040608582"/>
  <ErrNo _="-300"/>
  <ErrText _="Invalid event name"/>
  <P1 _="1"/>
</DoOn>
```

Error event message generated from an incoming SMS of this format: SECRET HEATERON 1

```
<DoOn _="System/SMSInvalidEvent ">
  <Event _="HEATERON"/>
  <Password _="SECRET"/>
  <OA _="+491717959463"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="SECRET HEATERON 1"/>
  <Alpha _="CON"/>
  <ErrNo _="-300"/>
  <ErrText _="Invalid event name"/>
  <P1 _="1"/>
</DoOn>
```

Error event message generated from a received POP3 email with this subject: SECRET HEATERON 1

```
<DoOn _="System/POPInvalidEvent ">
  <Event _="HEATERON"/>
  <Password _="SECRET"/>
  <OA _="support@tixi.com"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="SECRET HEATERON 1"/>
  <Alpha _="Tixi Support"/>
  <ErrNo _="-300"/>
  <ErrText _="Invalid event name"/>
  <P1 _="1"/>
</DoOn>
```


In case the message password is wrong, a predefined event is triggered that allows notification of the fault to be given and enables the tracking of intrusion attempts.

Event created on invalid password

Syntax:

```

<DoOn _="System/TixiInvalidPassword">
...
or
<DoOn _="System/SMSInvalidPassword">
...
or
<DoOn _="System/SMSInvalidPassword">
  <Event _="EventName" />
  <Password _="Password" />
  <Alpha _="SenderAlias" />
  <OA _="OA" />
  <Time _="ReceiveTime" />
  <RemoteSerialNo _="RemoteSerialNo" />
  <RemoteBoxnumber _="RemoteBoxnumber" />
  <RemoteBoxname _="RemoteBoxname" />
  <Text _="MessageText" />
  <P1 _="ValuesOfParameter1" />
  <P2 _="ValuesOfParameter2" />
  <P3 _="ValuesOfParameter3" />
  <P4 _="ValuesOfParameter4" />
  <P5 _="ValuesOfParameter5" />
  <P6 _="ValuesOfParameter6" />
  <P7 _="ValuesOfParameter7" />
  <P8 _="ValuesOfParameter8" />
  <P9 _="ValuesOfParameter9" />
  <P10 _="ValuesOfParameter10" />
  <ErrNo _="ErrNo" />
  <ErrText _="ErrorText" />
</DoOn>

```

Description:

Structure of the event created by an incoming message which contains an invalid password. This event corresponds to a DoOn event message. Note that an event handler of that name must exist.

Note: If no Def_Message user is configured in the AccRights database this system event will always be processed!

Elements:

EventName:

Event name parsed from received message text.

Password:

Password parsed from received message text.

SenderAlias:

Address of the sender (Express-E-Mail) or alphanumerical representation of the originating address if any stored in the chip card (SMS) or alias name of sender (email).

.OA:

Originating address (callerID) received from telephone network (Express-E-Mail, SMS) or sender address (from field) parsed from received message header (email).

ReceiveTime:

Time stamp received from GSM network (SMS) or Time stamp indicating when the message was received (Express-E-Mail, email).

RemoteSerialNo:

The serial number of the Tixi Device, which sends the message. (Express-E-Mail only)

RemoteBoxnumber:

The phone number of the sending Tixi Device, as defined in the USER database (see chapter 3.2). (Express-E-Mail only)

RemoteBoxname:

The name of the sending Tixi Device, as defined in the USER database (see chapter 3.2). (Express-E-Mail only)

MessageText:

The text from the 'Subject' line of the received message (email, Express-E-Mail) or content of the message (SMS).

P1...P10(optional)

Value of the parameter delivered by the message if any.

ErrNo:

Numerical representation of the processing error.

ErrorText:

Textual representation of the processing error.

Example:

Event message created by an incoming Express-E-Mail of this format: TRY HEATER_ON 1 in case TRY is not the correct password:

```
<DoOn _="System/TixiInvalidPassword">
  <Event _="HEATER_ON"/>
  <Password _="TRY"/>
  <RemoteSerialNo _="12345"/>
  <RemoteBoxnumber _="+49-30-40608582"/>
  <RemoteBoxname _="Test Tixi Alarm Modem"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="TRY HEATER_ON 1"/>
  <Alpha _="TEST+49-30-40608582"/>
  <OA _="03040608582"/>
  <P1 _="1"/>
</DoOn>
```

Event message created by an incoming SMS of this format: TRY HEATER_ON 1 in case TRY is not the correct password:

```
<DoOn _="System/SMSInvalidPassword">
  <Event _="HEATER_ON"/>
  <Password _="TRY"/>
  <OA _="+491717959463"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="TRY HEATER_ON 1"/>
  <Alpha _="CON"/>
  <P1 _="1"/>
</DoOn>
```

Event message created by a received POP3 email with this subject:
TRY HEATER_ON 1 in case TRY is not the correct password:

```
<DoOn _="System/POPInvalidPassword">
  <Event _="HEATER_ON"/>
  <Password _="TRY"/>
  <OA _="support@tixi.com"/>
  <Time _="01/07/20,08:56:33+08"/>
  <Text _="TRY HEATER_ON 1"/>
  <Alpha _="Tixi Support"/>
  <P1 _="1"/>
</DoOn>
```

9.3.3 Receiving Express-E-Mail

Tixi Alarm Modem can only process **uncompressed** Express-E-Mails. If you use a Tixi-Mail Box with "Tixi Server" Application to send an Express-E-Mail to the Tixi Alarm Modem, you have to disable the compression manually:

The compression can be disabled in the tixisvr.ini file (located: c:\TixiMail\Tixisvr\tixisvr.ini). Use a text editor (e.g. "Notepad") to edit the file (close Tixi Server first).

Change the line `CompressTixiMail=CompressOn` in the [TixiMailBox] section of the file to `CompressTixiMail=CompressOff`.

Tixi Alarm Modems are sending uncompressed Express-E-Mail by default.

9.3.4 Receiving SMS (GSM and PSTN)

To process incoming SMS with a Tixi Alarm Modem GSM the SIM card of the modem must not contain any read or unread SMS.

Several SMS-providers are using different character sets and special characters are converted unexpected. Therefore we recommend using EventHandler names without special characters.

Receiving SMS on PSTN is not supported with all telephone providers.

9.3.5 Collecting Internet emails (POP3)

To process incoming POP3 emails, the Tixi Device has to collect them first.

Make sure that the POP3 details are configured in the ISP database (Chapter 4.7)

This simple EventHandler will do the job:

Database path: /EVENTS/EventHandler

```
<POP3>
  <POP3Query/>
</POP3>
```

The Tixi Device will only receive messages with matching password.

A good solution can be implemented by combining the POP3 query event with the scheduler. Following example will collect emails every 15 minutes.

Database path: /SCHEDULE/Scheduler

```
<POP3 _="POP3">
  <Minute _="0,15,30,45"/>
</POP3>
```

9.3.5.1 Email filter

The Tixi Device is able to filter email messages to shorten online time, skip spam messages and to share a single POP3 account with other Tixi Devices.

Therefore a user defined filter word can be included at the end of the email subject or (if "Lines" are specified) within the message body. See chapter 3.5 for details.

If a filter is specified, the modem will ignore all messages without this filter word, and even leave them on the server.

9.3.6 Example

9.3.6.1 Event Handler

The typical application for the use of incoming message is assumed to be the following:

1. Log the message.
2. Set a variable.
3. Send a reply.

As described above, there are a number of events created automatically by an incoming message. Each must be handled by an event handler.

For the error cases, the following actions are assumed to be done:

Invalid Password:

Log the incoming message along with sender address.

Invalid event:

1. Log the incoming message.
2. Send a notification on the problem.

To process the error events, insert a section as follows into the EventHandler group of the EVENT database. The example assumes that the `Switch_0` as well as the `AnswerOnXXXError` message jobs have been configured.

Note: The `InvalidPassword` and the `InvalidEvent` sections are contained in a special sub-section `SYSTEM` of the `EVENT` database.

Database path: `/EVENTS/EventHandler`

```

<EventHandler>
  <HEATER_ON>
    <Log _="IncomingMessage">
      <Annotation _="Incoming message" />
      <Sender _="#xae;~/Alpha" />
      <OA _="#xae;~/OA" />
      <Time _="#xae;~/Time" />
    </Log>
    <Set _="/Process/C42/Q/P4" value="1" />
    <SendMail _="MessageJobTemplates/Switch_0" />
  </HEATER_ON>
  <System>
    <TixiInvalidPassword>
      <Log _="FailedIncomingCall" />
      <Annotation _="ExpressEMail with invalid password
received" />
      <Sender _="#xae;~/Alpha" />
      <Time _="#xae;~/Time" />
      <Text _="#xae;~/Text" />
    </Log>
    </TixiInvalidPassword>
    <TixiInvalidEvent>
      <Log _="FailedIncomingCall" />
      <Annotation _="Express-E-Mail with invalid event
received" />
      <Sender _="#xae;~/Alpha" />
      <Time _="#xae;~/Time" />
      <Text _="#xae;~/Text" />
    </Log>
    <SendMail _="MessageJobTemplates/AnswerOnTixiError" />
    </TixiInvalidEvent>
    <SMSInvalidPassword>
      <Log _="FailedIncomingCall" />
      <Annotation _="SMS with invalid password received" />
      <Sender _="#xae;~/OA" />
      <Time _="#xae;~/Time" />
      <Text _="#xae;~/Text" />
    </Log>
    </SMSInvalidPassword>
    <SMSInvalidEvent>
      <Log _="FailedIncomingCall" />
      <Annotation _="SMS with invalid event received" />
      <Sender _="#xae;~/OA" />
      <Time _="#xae;~/Time" />
      <Text _="#xae;~/Text" />
    </Log>
    <SendMail _="MessageJobTemplates/AnswerOnSMSError" />
    </SMSInvalidEvent>
    <POPInvalidPassword>
      <Log _="FailedIncomingCall">
      <Annotation _="POP3 email with invalid password
received" />
      <Sender _="#xae;~/OA" />
      <Time _="#xae;~/Time" />
      <Text _="#xae;~/Text" />
    </Log>
    </POPInvalidPassword>

```

Event handler for the Express-E-Mail error cases

Event handler for the SMS error cases

Event handler for the POP3 error cases

```

<POPInvalidEvent>
  <Log _="FailedIncomingCall">
    <Annotation _="POP3 email with invalid event
received"/>
    <Sender _="#xae;~/OA"/>
    <Time _="#xae;~/Time"/>
    <Text _="#xae;~/Text"/>
  </Log>
  <SendMail _="MessageJobTemplates/AnswerOnPOP3Error"/>
</POPInvalidEvent>

</System>
</EventHandler>

```

Note: If the message(s) created by this event handler should be sent to the sender of the triggering message, the sender parameter (Alpha for Express-E-Mail or OA for SMS/POP3) is only valid for messages which are sent by this specific event handler.

9.3.6.2 Message Job Templates for the answer messages

For the answer messages, separate message job templates must be created. If the address of the sender is not known at the time of configuration, the sender number can be read from the event message generated by the messages.

Database path: /TEMPLATE/MessageJobTemplate

Express-E-Mail:

```

<MessageJobTemplates>
  <AnswerOnHeaterOn _="Express-Email">
    <Recipient _="#xae;~/Alpha"/>
    <Body _="Heater is On"/>
  </AnswerOnHeaterOn>
  <AnswerOnError _="Express-Email">
    <Recipient _="#xae;~/Alpha"/>
    <Body _="Command &#xae;~/Event; could not be processed"/>
  </AnswerOnError>
</MessageJobTemplates>

```

SMS:

```

<MessageJobTemplates>
  <AnswerOnHeaterOn _="GSMSMS">
    <Recipient _="#xae;~/OA"/>
    <Body _="Heater is On"/>
  </AnswerOnHeaterOn>
  <AnswerOnError _="GSMSMS">
    <Recipient _="#xae;~/OA"/>
    <Body _="Command &#xae;~/Event; could not be processed"/>
  </AnswerOnError>
</MessageJobTemplates>

```

POP3:

```

<MessageJobTemplates>
  <AnswerOnHeaterOn _="SMTP">
    <Recipient _="#xae;~/OA"/>
    <Body _="Heater is On"/>
  </AnswerOnHeaterOn>
  <AnswerOnError _="SMTP">
    <Recipient _="#xae;~/OA"/>
    <Body _="Command &#xae;~/Event; could not be processed"/>
  </AnswerOnError>
</MessageJobTemplates>

```


Note: The sender address is read from the created event. In the Message Job Template, it is represented by the ®~/Alpha characters (Express-E-Mail) or the ®~/OA characters (SMS, POP3) which are a reference to the parameter provided by the event message.

9.4 Configuration via email

Additional to changing variables via incoming messages (chapters above) it is possible to replace complete databases e.g. the AddressBook via incoming email or Express-E-mail. The necessary event handler command "SetConfig" is explained in chapter 3.7.1.

The Tixi Device requires special message syntax, to detect and process the new database content.

At first the subject line of the message has to contain the password (chapter 9.5) and the event handler name with SetConfig command, e.g.:



The message body has to contain the databases in following syntax:

Message body syntax – edit databases**Syntax:**

```

<D>
  <SetConfig _="DATABASE">
    <Group>
      Data...
    </Group>
  </SetConfig>
</D>

```

Description:

Message body structure to change databases via incoming email or Express-Email.

Elements:**DATABASE:**

Name of database to edit, e.g. USER, ISP, PROCCFG. See chapter 12 for database names.

Group:

Groups inside the database, e.g. database TEMPLATE may contain groups "AddressBook", "MessageJobTemplates" and "UserTemplates"

Example:

Email message body to change the location settings:

```
<D>
  <SetConfig _="USER">
    <Location>
      <CountryPrefix _="00"/>
      <CountryCode _="49"/>
      <AreaPrefix _="0"/>
      <AreaCode _="30"/>
      <LocalDialPrefix _=""/>
      <LongDialPrefix _=""/>
      <PhoneNumber _="0304019008"/>
      <InternalDialPrefix _=""/>
      <ExtensionNumber _=""/>
      <DialRules _="Tone,NoWaitForDialTone"/>
    </Location>
  </SetConfig>
</D>
```

Email message body to change the AddressBook:

```
<D>
  <SetConfig _="TEMPLATE">
    <AddressBook>
      <MySelf>
        <Email _="user@domain.com"/>
      </MySelf>
      <Receiver>
        <Email _="demo@tixi.com"/>
      </Receiver>
    </AddressBook>
  </SetConfig>
</D>
```

9.5 Authentication

To protect the message access to the device, one or more passwords must be defined. There are two ways to configure a password protection:

- Simple password.
- Sender data (CallerID, email alias) depending.

The simple method defines a password for all senders independently of the sender device. When using the other variant, the password is valid in conjunction with a specific originating address (callerID, email alias) only. For originating address protection (callerID check) with SMS or Express-E-Mail the telephone provider and/or PBX has to support callerID presentation (CLIP). Ask your local telephone company for details.

The AccRights have to be configured in the USER database.

Database path: /USER/AccRights

Remote Control access protection**Syntax:**

```

<User>
  <Def_Message Plain="PlainPwd" Group="UserGroup" />
  <OA_nnn Plain="PlainPwd" Group="UserGroup" />
  <Alias Plain="PlainPwd" Group="UserGroup" />
</User>

```

Description:

Enables incoming message access to the Tixi Device by setting up a password protection. Either a sender-independent password can be used or one that is valid in conjunction with a specific originating address only. See chapter 3.6 for more details.

Elements:**PlainPwd:**

The password required for message access. Maximum 25 characters.

UserGroup:

Name of a group with service "Message" (see chapter 3.6).

OA_nnn:

Originating address (callerID, email address) that should be authorized to access the Tixi Device, where *nnn* consists of numbers only (SMS, Express-E-Mail) or letters (email), thus any hyphens and other characters than numbers (or letters), must be removed.

Alias:

Email alias name that should be authorized to access the Tixi Device. Space characters will be removed.

Example:

Configure a non-sender aware password protection with the password SECRET:

```

[<SetConfig _="USER" ver="y">
  <AccRights>
    <Groups>
      <MessageGroup>
        <Message AccLevel="1" />
      </MessageGroup>
    </Groups>
    <User>
      <Def_Message Plain="SECRET" Group="MessageGroup" />
    </User>
  </AccRights>
</SetConfig>]

```

Configure protection for a sender "+49172123456789" and the password SECRET:

```

[<SetConfig _="USER" ver="y">
  <AccRights>
    <Groups>
      <MessageGroup>
        <Message AccLevel="1" />
      </MessageGroup>
    </Groups>
    <User>
      <OA_49172123456789 Plain="SECRET" Group="MessageGroup" />
    </User>
  </AccRights>
</SetConfig>]

```

Configure Protection for an email sender with the alias name 'Tixi Support' and the password SECRET:

```
[<SetConfig _="USER" ver="y">
  <AccRights>
    <Groups>
      <MessageGroup>
        <Message AccLevel="1"/>
      </MessageGroup>
    </Groups>
    <User>
      <TixiSupport Plain="SECRET" Group="MessageGroup"/>
    </User>
  </AccRights>
</SetConfig>]
```

If alias name can not be found within user list, email address will be checked too:
Protection for an email sender without alias but with email address Support@tixi.com and the password SECRET:

```
[<SetConfig _="USER" ver="y">
  <AccRights>
    <Groups>
      <MessageGroup>
        <Message AccLevel="1"/>
      </MessageGroup>
    </Groups>
    <User>
      <OA_Supporttixicom Plain="SECRET" Group="MessageGroup"/>
    </User>
  </AccRights>
</SetConfig>]
```

10 Tixi Device and PLC / Meter / Fieldbus Operation

The Tixi Device is not only to be used on its own, but even in conjunction with PLC devices, meters and other kinds of controllers. As the Tixi Device got most common protocols already implemented, connecting it to a PLC or meter is very simple.

Once the connection is established physically via RS232, RS422/485, MPI or M-Bus interface, the Tixi Device system properties may be enhanced by any variable of the external device. The Tixi Device will then be able to read the variable values, use them to trigger events, log the values and send the logfiles. Based on logical instructions or incoming messages, the Tixi Device may even write into devices.

There's a variety of systems to be supported by the Tixi Device, which got the respective protocols already implemented. These PLCs or meters may be connected to the Tixi Device without any change in programming or configuration, just by means of their communication interface:

- Mitsubishi ALPHA2, MELSEC FX
- Siemens Simatic S7-200, S7-300/400 (MPI)
- VIPA (GreenCable)
- Moeller Easy 400/500/600/700/800/MFD, Easy Control, XC/XVC
- SAIA S-Bus
- Carel Macroplus
- Modbus RTU
- Tixibus
- M-BUS
- and much more...

Detailed information on configuration and usage of Tixi along with PLCs and other devices can be found within the Tixi PLC Manual, which is available on our website.

11 Addresses of serial interfaces and I/Os

Tixi Alarm Modems					
Device Description	Tixi Alarm Modem				
	GSM	GSM	GSM	GSM	V.90 / GSM / ISDN
Product Code	HG121 / HG421	HG127 / HG427	HG141 / HG441	HG147 / HG447	HG425-2S0
Serial interfaces	1xRS232-F, 1xRS232-M	1xRS232-F, 1xRS232-M	1xRS232-F, 1xRS422/485	1xRS232-F, 1xRS422/485	1xRS232-F, 1xRS232-M
I/Os	-	2/3 + 10V AI	-	2/3 + 10V AI	2/1 + 10V AI + 2 S0
Systempath:					
RS232-1	COM1	COM1	COM1	COM1	COM1
RS232-2	COM2	-	-	-	COM2
RS422/485	-	COM2	COM2	COM2	-
Inputs	-	/Process/MB/IO/I/Px	-	/Process/MB/IO/I/Px	/Process/MB/IO/I/Px
Outputs	-	/Process/MB/IO/Q/Px	-	/Process/MB/IO/Q/Px	/Process/MB/IO/Q/Px
Analog input	-	/Process/MB/A/AI/P0	-	/Process/MB/A/AI/P0	/Process/MB/A/AI/P0
S0-interface	-	-	-	-	/Process/I3e/AI/Px

Tixi Alarm Modems					
Device Description	Tixi Alarm Modem				
	GSM	GSM	GSM	GSM	
Product Code	HG423-M25/60/100	HG443-M25/60/100	HG171 / HG471	HG176 / HG476	
Serial interfaces	1xRS232-F, 1xRS232-M	1xRS232-F, 1xRS422/485	1xRS232-F, 1xMPI	1xRS232-F, 1xMPI	
I/Os	2/1 + 10V AI	2/1 + 10V AI	-	2/2 + 10V AI	
Systempath:					
RS232-1	COM1	COM1	COM1	COM1	
RS232-2	COM2	-	COM2	COM2	
RS422/485	-	COM2	-	-	
M-Bus	COM3	COM3	-	-	
Inputs	/Process/MB/IO/I/Px	/Process/MB/IO/I/Px	-	/Process/MB/IO/I/Px	
Outputs	/Process/MB/IO/Q/Px	/Process/MB/IO/Q/Px	-	/Process/MB/IO/Q/Px	
Analog input	/Process/MB/A/AI/P0	/Process/MB/A/AI/P0	-	/Process/MB/A/AI/P0	

Tixi Data Gateways					
Device Description	Tixi Data Gateway				
	LAN / WLAN	LAN / WLAN	LAN / WLAN	LAN / WLAN	LAN / WLAN
Product Code	HE121 / HE421 / HW 121 / HW421	HE127 / HE427 / HW127 / HW427	HE141 / HE441 / HW141 / HW441	HE147 / HE447 / HW147 / HW447	HE425-2S0, HW425-2S0
Serial interfaces	1xRS232-F, 1xRS232-M	1xRS232-F, 1xRS232-M	1xRS232-F, 1xRS422/485	1xRS232-F, 1xRS422/485	1xRS232-F, 1xRS232-M
I/Os	-	2/3 + 10V AI	-	2/3 + 10V AI	2/1 + 10V AI + 2 S0
Systempath:					
RS232-1	COM1	COM1	COM1	COM1	COM1
RS232-2	COM2	-	-	-	COM2
RS422/485	-	COM2	COM2	COM2	-
Inputs	-	/Process/MB/IO/I/Px	-	/Process/MB/IO/I/Px	/Process/MB/IO/I/Px
Outputs	-	/Process/MB/IO/Q/Px	-	/Process/MB/IO/Q/Px	/Process/MB/IO/Q/Px
Analog input	-	/Process/MB/A/AI/P0	-	/Process/MB/A/AI/P0	/Process/MB/A/AI/P0
S0-interface	-	-	-	-	/Process/I3e/AI/Px

Tixi Data Gateways					
Device Description	Tixi Data Gateway				
	LAN / WLAN	LAN / WLAN	LAN / WLAN	LAN / WLAN	
Product Code	HE423-M25/60/100 / HW423-M25/60/100	HE443-M25/60/100 / HW443-M25/60/100	HE171 / HE471 / HW171 / HW471	HE176 / HE476 / HW176 / HW476	
Serial interfaces	1xRS232-F, 1xRS232-M	1xRS232-F, 1xRS422/485	1xRS232-F, 1xMPI	1xRS232-F, 1xMPI	
I/Os	2/1 + 10V AI	2/1 + 10V AI	-	2/2 + 10V AI	
Systempath:					
RS232-1	COM1	COM1	COM1	COM1	
RS232-2	COM2	-	COM2	COM2	
RS422/485	-	COM2	-	-	
M-Bus	COM3	COM3	-	-	
Inputs	/Process/MB/IO/I/Px	/Process/MB/IO/I/Px	-	/Process/MB/IO/I/Px	
Outputs	/Process/MB/IO/Q/Px	/Process/MB/IO/Q/Px	-	/Process/MB/IO/Q/Px	
Analog input	/Process/MB/A/AI/P0	/Process/MB/A/AI/P0	-	/Process/MB/A/AI/P0	

IO-Extensions			
Device Description	Tixi Alarm Modem IO-Extension, Tixi Data Gateway IO-Extension		
Product Code	XP84D	XP84DR	XP88AD
I/Os	8/4	8/4	8/0 + 8x10V AI
Systempath:			
Cx addresses	C40, C42, C44, C46, C48, C4A, C4C, C4E	C40, C42, C44, C46, C48, C4A, C4C, C4E	C40, C42, C44, C46, C48, C4A, C4C, C4E
Inputs	/Process/C4x/I/Px	/Process/C4x/I/Px	/Process/C4x/I/Px
Outputs	/Process/C4x/Q/Px	/Process/C4x/Q/Px	-
Analog input	-	-	/Process/C4x/AI/P0

11.1 Bit / Byte / Word / Dword addressing of I/Os

The bit values of the Tixi Device I/Os can also be addresses as bytes, words and dwords.

Bit / Byte / Word / Dword Addressing

Syntax:
/Process/[ModuleAddress]/[PortGroup]/[PortType][Range]P[PortIndex]

Description:
 Addressing the input and output ports of a Tixi Device. Port bits can be addressed in different ways. It is possible to address a single port or sequences of ports. Assuming a 32-bit port, the bits can be addressed in the following ways:

00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

Single Bit Access: example: /Process/MB/I/IO/P4

00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31

Byte Access: example: /Process/MB/IO/IB/P2

0	1	2	3
---	---	---	---

Word Access: example: /Process/MB/IO/IW/P1

0	1
---	---

Double Word Access: example /Process/MB/IO/ID/P0

0

Elements:
 The port is addressed by a slash divided path notation:

Process: Process sub system path

ModuleAddress:

- MB** Tixi Device mainboard
- C40...C4E** HEX number corresponds to the setting of the address jumper of the extension modules.

PortGroup (only on ModuleAddress "MB"):

- IO** Group of digital in- and outputs

PortType:

PortType	Data Type	Value Range
I	Input Bitfield	0,1
IB	Input Byte	0..255
IW	Input Word	0...65.535
ID	Input DWord	0...4.294.967.295
Q	Output Bitfield	0,1
QB	Output Byte	0..255
QW	Output Word	0...65.535

QD Output DWord 0...4.294.967.295

PortIndex:

0...n Zero based index number of the item in the port.

Examples:

5. bit of the input bit field of the module with the address 40.
 /Process/C40/I/P4

12 System Properties

This appendix lists the available system properties of the Tixi Device which can be read or written by the Get and Set commands. The tables contain the single system properties. The complete path to address a system property must be combined by the headline of the table and the name of the system property separated by a slash character.

For Example:

To address the serial number simply write:
/SerialNo (table has no headline).

To address the version number of the firmware write:

/OEM/Firmware/Version

Headline

Name from
Table

It's possible to include the system properties into message text:

e.g.:

```
<L _="Firmware-Version: &#xae;/OEM/Firmware/Version" />
```

Name	Type	Read only	Description
BoxMode	String	yes	Current system mode Modem TiXML
HardwareID	String	yes	Device hardware code
PNP_String	String	yes	Plug and Play string of the device. for example: TIX2027\02582501\MODEM\AMB3100\Tixi Data Gateway LAN
FeatureList	String	yes	List of the features (services) of the product. for example: Modem Mode Express-E-Mail Send Remote Modem-Mode Script Send Job Result Processor
Components	String	yes	List of components of the device. for example: RTC Modem0 FlashOnboard C8
SerialNo	String	yes	Serial Number of the device. for example: 00238801
FreeFileSize	Uint32	yes	Free memory in file system (Bytes)
LocalIPAddr	String	yes	IP address of the modem (assigned during PPP connection)

/EEProm

Name	Type	Read only	Description
GM	String	yes	Interface address of GSM modem, copied from configuration
Pin1	String	Yes	PIN1 for GSM SIM card, copied from configuration
Pin2	String	yes	PIN2 for GSM SIM card, copied from configuration

/Ethernet

Name	Type	Read only	Description
AssignedIP	String	yes	IP address assigned via DHCP or configuration
SubnetMask	String	yes	SubnetMask assigned via DHCP or configuration
Gateway	String	yes	Gateway assigned via DHCP or configuration
DNS_1	String	yes	First DNS server assigned via DHCP or configuration
DNS_2	String	yes	Second DNS server assigned via DHCP or configuration
Link	Uint16	yes	Active link speed of ethernet interface. "0", "10" or "100" (MBit/s)
LinkState	Bit	yes	Status of ethernet link. 0=disconnected, 1=connected
MAC	String	yes	Network interface MAC address

/Firmware

Name	Type	Read only	Description
Version	String	yes	Version number of the firmware. for example: 3.06.60.000
Date	String	Yes	Date of build

/GSM

Name	Type	Read only	Description
Reg	Uint16	yes	Shows network registration state
Reg_Text	String	yes	Verbose network registration state
Operator	String	yes	Name of active GSM operator
Quality	Uint16	yes	GSM signal strength, see ETSI GSM 05.08 0: -113dBm or less 1: -111 dBm 2-30: -109 to -53 dBm 32: -51dBm or greater 99: not known or not detectable
BitErrorRate	Uint16	yes	as RXQUAL values, see ETSI GSM 05.08
Account	Uint16	yes	Credit left on SIM card (Germany: €€c)
DaysLeft	Uint16	yes	Days until SIM card expiration
State	String	Yes	GSM error state, e.g. "missing SIM Card"

/GSM/FD

GSM SIM provider phonebook entries in syntax <Contact_name _="phone_number"/>. Special characters in contact names will be replaced by underscore.

/GSM/SM

GSM SIM phonebook entries in syntax <Contact_name _="phone_number"/>. Special characters in contact names will be replaced by underscore.

/Hardware/Modules

Name	Type	Read only	Description
RTC	String	yes	RTC type, not defined if no RTC is present. for example: RTC4513
Jumper	String	yes	Jumper to prevent firmware upload, not defined if not present.
Modem0	String	yes	Type of Modem #0, not defined if not present.

			for example: HG421
Modem1	String	yes	Type of Modem #1, not defined if not present.
GsmModule	String	yes	Type of GSM modem, if present
FlashOnboard	String	yes	Flag indicating whether flash is on the main board or not, undefined if no flash is present, 'x' else.
FlashExtension	String	yes	Flag indicating whether a flash extension board is present, undefined if no flash extension board is present, 'x' else.
PowerSupply	String	yes	Hardware version of the Tixi Device (1 or 2Ampere) for example: 2.0A
COMx	String	yes	Interface type of COMx
MBAIO	String	yes	Type of analog I/O module
MBDIO	String	yes	Type of digital I/O module
Ethernet	String	yes	Network controller chip type
C4x	String	yes	extension module (C42,C44,C44,C46,C48,C4a,C4c,C4e)

/Hardware/RAM

Name	Type	Read only	Description
Attributes	String	yes	Code describing the attributes of the system RAM, not defined if no information is present. for example: 14680064
Type	String	yes	Code describing the Type of the system RAM, not defined if no information is present.
Size	String	yes	Detected size of the system RAM in bytes, not defined if no information is present. for example: 524288-> 512 KByte

/Hardware/ROM

Name	Type	Read only	Description
Attributes	String	yes	Code describing the attributes of the system ROM, not defined if no information is present. for example: 0
Type	String	yes	Code describing the type of the system ROM, not defined if no information is present.
Size	String	yes	Detected size of the system ROM in bytes, not defined if no information is present.

/Hardware/FileSystem

Name	Type	Read only	Description
Attributes	String	yes	Code describing the attributes of the system RAM, not defined if no information is present. for example: 0
Type	String	yes	Code describing the type of the system RAM, not defined if no information is present.
Size	String	yes	Detected size of the system RAM in bytes, not defined if no information is present. for example: 262144 -> 2 MByte

/LogCounter (dynamic)

Name	Type	Read only	Description
Logfilename	Uint16	no	Number of entries in the specified Logfile. Value can be changed by "set" command, new entries will be added.

/OEM

This sub-tree depends on the product declaration defined by the vendor of the device.

/Process/Program

Name	Type	Read only	Description
Mode	String	no	Processing Mode of the program: Run...Processing is running Stop..Processing is stopped.

/Process/MB

Name	Type	Read only	Description
FirstCycle	Uint16	no	Predefined process variable (used to detect power on situation): 1...The first processing cycle runs. 0...The first processing cycle is done.
PollButton	Uint16	yes	Status of the Service Button. 1=pressed, 0=not pressed
SignalLED	Uint16	no	Status of the "Signal" LED. Range 0 – 27 (see chapter 6.8)
ModemOffHook	Uint16	yes	State of the modem 0: On hook 1: Off hook (outgoing call) 2: Off hook (incoming call)
TransMode	Uint16	yes	TransMode state: 0: no TransMode established 1: TransMode to COM1 established 2: TransMode to COM2 established
MaxCycleTime	Uint16	yes	Longest cycle time
CycleTime	Uint16	yes	Actual cycle time

/Process/PV (dynamic properties)

Values of the process variables defined by the PROCCFG/ProcessVars

/Process/MB (dynamic properties)

Values of the unnamed process variables defined by the main board (HM,HG,HD,HF).

/Process/Cn (dynamic properties)

Values of the unnamed process variables defined by the installed extension module

/Process/Auxn (dynamic properties)

Values of the process variables defined in PROCCFG/External (without name or BusId).

/Process/Busn (dynamic properties)

Values of the process variables defined in PROCCFG/External with BusId.

/TIMES

Name	Type	Read	Description
------	------	------	-------------

		only	
TIME	String	yes	Current system time of the day:hour:minutes:seconds
DATE	String	yes	Current system date year/month/day
RFC822Date	String	yes	Current system date and time in the email format according to RFC 822. for example: Fri,13 Jul 01 13:56:00 +0100
PowerOffTime	String	yes	System time of the last power off event with (resolution of 1 minute.) year/month/day/hours/minutes/seconds
PowerOnTime	String	yes	System time of the last power on event with year/month/day/hours/minutes/seconds
DAYOFWEEK	String	yes	Sunday,Monday, ...Saturday
DAYOFWEEKNO	String	yes	0-6
YYYY_MM_DD	String	yes	Current system date year_month_day.
HH_MM_SS	String	yes	Current system time of the day hour_minutes_seconds.
HEXDATE	String	yes	Current system time in seconds since 1.1.1970 as hex value.

/WLAN

Name	Type	Read only	Description
AssignedIP	String	yes	IP address assigned via DHCP or configuration
SubnetMask	String	yes	SubnetMask assigned via DHCP or configuration
Gateway	String	yes	Gateway assigned via DHCP or configuration
DNS_1	String	yes	First DNS server assigned via DHCP or configuration
DNS_2	String	yes	Second DNS server assigned via DHCP or configuration
Rate	String	yes	Active link speed of WLAN interface., e.g.“54 Mbps”
Link	Uint16	yes	Active link speed of WLAN interface (MBit/s).
LinkState	Uint16	yes	Status of WLAN link. 0=disconnected, 1=connected
TxPower	String	yes	WLAN transmission power
MAC	String	yes	WLAN interface MAC address
SSID	String	yes	Service Set Identifier of connected access point
BSSID	String	yes	Basic Service Set Identifier of connected access point
SNR	String	yes	WLAN signal to noise ratio, e.g. “48/96”
Reason	String	yes	WLAN error reason

/EVENT (Data Base)

See 'EVENT' database description.

/ISP (Data Base)

See 'ISP' database description.

/LOG (Data Base)

See 'LOG' database description.

/PROCCFG (Data Base)

See 'PROCCFG' database description.

/SCHEDULE (Data Base)

See 'SCHEDULE' database description.

/TEMPLATE (Data Base)


See 'TEMPLATE' database description.

/USER (Data Base)


See 'USER' database description.

13 Project structure and connections


13.1 Event Handler, Scheduler




13.2 Event States, External, ProcessVars, System-IOs



13.3 MessageJobTemplates, UserTemplates, AddressBook



13.4 Logfiles, Records, EventLogging



14 Firmware

14.1 Remote Firmware Update

Remote Firmware Update is only supported on Tixi Devices with SD-Card (Hx4xx). A SD-Card with FAT16 file system must be mounted to upload the new firmware using TFTP. The firmware file must be registered in the TFTP configuration (see Webserver TiXML manual for more information on TFTP configuration).

```
[<SetConfig _="ISP" ver="y">
  <TFTP>
    <Port _="69"/>
    <Files>
      <Upload _="0:TAM_FW.BIN" acc="RW" size="1000"/>
    </Files>
  </TFTP>
</SetConfig>]
```

Upload the "TAM_FW.BIN" binary firmware file via TFTP using remote file name "0:tam_fw.bin" ("0:" addresses the SD-Card).

After uploading, a [`<Reset _="Update"/>`] is necessary to flash the firmware.

14.2 Compatibility

The Tixi Device firmware will be updated periodically to implement new features, support more PLCs or for bug fixing. In most cases it's not necessary to update your projects after updating the firmware.

In the past some changes have been made to the system structure to make it easier to understand. In most cases a new firmware supports both: the old and the new structure. Due to these changes a project written for a new firmware may not work with an older firmware.

The following list helps you to determine if project changes are necessary:

Firmware	Description
1.52.0.0	New External Format, protocol type (see PLC TiXML manual) A new bus attribute "protocol" now contains the manufacturer and the protocol, the attribute "type" contains just the Master/Slave mode. Old syntax, e.g.: type="sucom,Master" New syntax, e.g.: protocol="Moeller,Easy 400/600" type="Master"
1.60.0.184	TIMES-Group (chapter 12) The Tixi Device time variables (Date, Time etc.) are moved into a new group called /TIMES. Example: Old path: /Date New path: /TIMES/Date AddressBook INet->Email (chapter 3.4) The addressbook parameter for email addresses was renamed. Old name: INet, New name: Email
1.64.0.172	GSMPorts activation in USER-Database (chapter 3.3) The operating mode of the GSM module IOs can be set via USER-Database entry.
1.63.0.65	MessageJobTemplate Tixi-> Express-Email (chapter 3.9) The MessageJobTemplate type for Exptess-Emails was renamed. Old name: Tixi New name: Express-Email Addressbook: TixiMail-> Express-Email (chapter 3.4) The addressbook parameter for Express-Email addresses was renamed. Old name: TixiMail New name: Express-Email
1.63.0.59	Dial Rules T/P:N/Y -> Tone/Pulse,No/WaitForDialTone (chapter 3.2): The dial rule parameters were renamed. Old syntax: T:N, P:N, T:Y, P:Y

	New syntax: Tone,NoWaitForDialTone, Pulse,NoWaitForDialTone, Tone,WaitForDialTone, Pulse,WaitForDialTone.
1.63.0.51	POP3 Flag: PbS -> POPBeforeSMTP (chapter 3.5) The value name of the POP before SMTP parameter was changed: Old syntax: PbS New syntax: POPBeforeSMTP
	SMTP Flag: d -> DontDelete (chapter 3.5) The value name of the delete message parameter was changed: Old syntax: d New syntax: DontDelete
	AddressBook: SMS_Nr -> SMS_No (chapter 3.4) The addressbook parameter for SMS numbers was renamed. Old name: SMS_Nr New name: SMS_No
1.72.0.0	Handshake SUCOM -> noDTR The handshake parameter on Bus configuration and TransMode for Moeller Easy and Mitsubishi Alpha XL was renamed. Old name: SUCOM New name: noDTR
1.80.86.0	Time-Server moved from database ISP to ISP/ISP PPP-Server moved from database ISP/ISP to ISP CBIS moved from database ISP/ISP to ISP
1.81.0.0	HG GSM modem definition in USER-DB: old <GSMModem _="MB"/> (no longer allowed) new <GSMModem _="MB"/>
2.00.0.0	New AccRights database. Database USER/Login, USER/SMS_Login no longer supported. New LogDefinition database. Database LOG/Logfiles, LOG/Records no longer supported.
2.1.25.0	Incoming SMS command names will be transformed to upper case, therefore all EventHandler for SMS remote switching have to be upper case.
2.01.36.0	S0-Interface changed from "C3e" to "I3e"
2.1.39.0	External Bus parameter "mem" now specified in "bytes" (previously KB)
2.02.1.0	New ScheduleDefinition database. Database SCHEDULE/Schedule, SCHEDULE/Condition no longer supported.
2.2.8.0	Logfile template CSV now without quotes
2.2.21.0	Tixi bus variable "S" (String) now requires "size" instead of "length"
2.2.74.0	MPI callback no longer supported
3.0	Old login database no longer supported (/USER/Login, /USER/SMS_Login) TiXML baudrate on COM1 is fix 115200bps MPI baudrate 19200bps no longer supported MPI activation requires restart
3.0.1.329	CHAP Login ID without conversion (see chapter 0)

14.3 Feature History

Firmware	Description
3.0.1.243	MIN/MINI/MAX/MAXI RPN instruction (see chapter 6.3.1.3)
3.0.1.264	Free process variables increased to 30 (see chapter 6)
3.0.1.272	M-Bus variables: manufacturer, primary- secondary address
3.0.1.274	Ethernet DHCP (see chapter 3.14)
3..0.1.290	Format condition (see chapter 6.5.2)
3.0.1.303	Signal-LED (see chapter 6.8)
3.0.1.308	SD-Card batch configuration (see chapter 2.5)
3.0.1.310	External variable offset
3.0.1.328	Remote firmware update (see chapter 14.1) DoOn.exe CGI
3.0.1.336	Persistent Ethernet configuration (see chapter 3.14) TransMode EventHandler commands (see chapter 3.7.1)
3.0.1.342	Increased performance with large external or logdefinition databases Webserver MIME type configuration
3.0.1.362	M-Bus reset (application code)
3.0.1.366	RPN to FORTH conversion
3.0.1.370	GPS NMEA HTTP POST

3.0.1.402	M-Bus auto reset
3.0.1.408	SMTP HELO Hostname configurable (see chapter 3.5)
3.0.2.2	External offset attribute
3.0.2.4	EventHandler command IfNot (see chapter 3.7.2)
3.0.2.6	Siemens Simatic S7-400 support
3.0.2.14	Beep EventHandler command (see chapter 3.7.1)
3.0.3.2	DIN 61107 / DIN EN 62056-21
3.0.4.0	WLAN support (see chapter 3.15)
3.0.6.0	GetJobs / DeleteJobs EventHandler command (see chapter 3.7.1)
3.0.6.22	GPRS CLASS C EventHandler command "Connect" (see chapter 3.7.1)
3.0.6.32	HEXDATE system property (see chapter 12) WriteFile EventHandler command (see chapter 3.7.1)
3.0.6.52	New default webseite
3.0.6.56	SIM phone book variables (see chapter 12)
3.0.6.60	New MPI implementation
3.0.6.62	DHCP hostname (see chapter 3.14)
3.0.6.70	Logfile options: NoSec, fillInterval, maxInterval, fillText (see chapter 4.6) Sendmail condition (see chapter 3.7.1) Free process variables increased to 50 (see chapter 6)
3.0.6.72	M-Bus scan
3.0.6.74	URLSend / DynDNS (see chapter 3.4 and 3.9) SendMail/PPPCOM KeepConnected (see chapter 3.7.1)
3.0.6.78	SMTP HELO hostname (see chapter 3.5) ReadLog/IncludeLog(TXT) "rowend" parameter (see chapter 4.6) CGI ".exe" renamed to ".cgi" serialPPP
3.0.6.82	TFTP access to SD-Card Viewset for reading logfiles (see chapter 2.4.6.6)
3.2.0.0	WLAN with WPA (see chapter 3.15)
3.2.0.26	CopyDatabase for complete project (see chapter 3.8) IncludeSP for system properties tree (see chapter 3.8)
3.2.0.30	TiXML/IP Timeout adjustable
3.2.0.34	ReadLog/IncludeLog(TXT) "cols" parameter (see chapter 4.6)
3.2.0.36	MAJOR RELEASE for HE series
3.2.0.52	MAJOR RELEASE for HG/HE series Mitsubishi MELSEC FX3U support

Index

- ® 41
- 1TR140 84
- Access Rights 52
- Account 193
- AccountExpiry 46
- AccountQuery 46
- AccountResponse 46
- Acknowledgement 58
- ADD instruction 135
- ADDI instruction 135
- AddInfo 30, 76, 119
- Addition 135
- Address 190
- Address Book 48
- Addresses 189
- Addressing Of Bits 190
- Alarm Processing 5
- Alpha 186
- Alternative Value 42
- Analog Input 152
- AND instruction 120
- ANDN instruction 121
- Answer Message 183
- APN 50
- Area Code 42
- Area Prefix 42
- ASCII 9
- AssignedIP 196
- Attachment 107
- Authentication 20
- Automatic Reply 183
- Automatic TransMode 85
- Base64 93
- BASE64 Attachment 107
- Basis 149
- Batch 39
- Baudrate 85
- Beep Command 67
- Binary 93
- Binary Log Data 61
- Binary Logging 94
- BinLog Command 61, 99
- Bit 95, 146
- Bit Address 190
- Bitmask 142
- Blob 146
- Body 78
- BOOLEAN Processing 116
- Box Name 46
- Box Number 46
- BSSID 196
- byte 95
- C instruction 75
- Calculating Variable Values 116
- Calculation 134
- Call Acceptance 46
- Caller ID 85
- CallerID Event 171
- CardLogin 52
- CareL 188
- case alternative 149
- Casing 189
- CBIS 79
- Channel 155
- CHAP 21
- Character set 9
- CheckJobConditions 69
- Checksum 77
- CityRuf 79
- CityRuf Number 48
- Clear Command 65
- Clear Logfiles 39
- Collecting POP3 E-Mail 180
- cols 101
- colsep 101
- Command 10
- Command Encoding 8
- Command Parameters 10
- Comparison Instructions 128
- Compatibility 201
- Condition 70, 159
- config.txt 39
- Confirm Command 64
- Confirmation 56, 58
- ConfirmID 56
- Connect 69
- Contacts 48
- contenttype 93
- Copy Value 127
- CopyDatabase 77
- Country Code 42
- Country Prefix 42
- CPY instruction 127
- CRC16 35, 101
- CRC32 35, 77, 101
- crcText 101
- CSV 35, 101
- CycleTime 195
- D_OFF instruction 138
- D_ON instruction 138
- DAND instruction 120
- DANDN instruction 121
- Data 159
- data format 147
- Data Logging 93
- data type 146

Database Email 184
 Databases 5
 Day 159
 Daylight Saving Time 86
 DaysLeft 193
 DayTime 86
 Default Settings 15
 Define Process Variables 113
 Defining Events 55
 Delay 56
 Delay Command 63
 DeleteJobs Command 67
 Denominator 152, 155
 DHCP 88, 89
 Dial Rules 42
 Dialing 44
 Dialling Properties 42
 DialRules 42
 Dialup 50
 Digital I/O Ports 111
 Disable Alarm 112
 DIV instruction 137
 DIVI instruction 137
 Division 137
 DLDN instruction 119
 DMSK instruction 141
 DNS 88, 89
 DNS Address 50
 DNS_X 196
 DOR instruction 122
 DORN instruction 123
 double 95
 Double 146
 dword 95
 DXOR instruction 124
 DXORN instruction 125
 E instruction 73
 EchoInterval 50
 EchoTarget 50
 EchoTimeout 50
 ELSE 139
 E-mail Address 48
 E-mail Attachment 107
 E-Mail Filter 181
 Empty Logfiles 39
 Enable Alarm 112
 EQ instruction 130
 equal 130
 Error Class 30
 Error Code 119
 Error Codes 14
 Error Frame 11
 Error State 30
 Error Value 30
 EthernetLogin 52
 Event 112
 Event Condition 70
 Event Handler 55
 Event Log 97
 Event Processing 111
 Event States 112
 EventLogging Database 97
 exp 95, 113, 117
 Exponent 95, 113, 117
 Express-Email 79
 Express-E-Mail (Incoming) 173
 Express-E-Mail Address 48
 ExtensionNumber 42
 Factory Reset 15
 FailedIncomingCall Log 97
 Fax Number 48
 Feature History 202
 file 97
 File System 194
 Filename 69
 fillInterval 35, 101
 fillText 35, 101
 Filter 50, 181
 FIND_BIT_ADDRESS 142
 Firmware 201
 FirstCycle 195
 Flash memory formating 15
 float 95
 Float 146
 format 94, 147
 Format 76
 Formatting Logfiles 101
 FORTH instruction 144
 Framing 8
 Frequent Event Triggering 158
 FULL 18
 Fullduplex 18, 85
 Gain 152
 Gateway 88, 89, 196
 GE instruction 132
 GEI instruction 132
 Get Command 30
 GetJobs Command 67
 GPRS 46, 50, 69
 GPRSPrepared 71
 greater equal 132
 greater than 129
 GSM Credit 46
 GSM Signal Strength 193
 GSMModem 46
 GSMSMS 79
 GT instruction 129
 GTI instruction 129
 HALF 18
 Halfduplex 18, 85
 Handshake 85
 Hardware 189

HEX format 149
 Hostname 50
 Hour 159
 Housing 189
 HTML 35, 101
 HTTP Notification 82
 I/O Port Processing 112
 I/O Ports 111
 ID 35
 IF equal 139
 IF instruction 70
 IF not equal 139
 IFEQ instruction 139
 IFNE instruction 139
 IfNot instruction 70
 Impulse Counter 155
 Include 75
 IncludeLog 100
 IncludeLogTXT 101
 IncludeSP 76
 Including Databases 77
 Including Logfiles 76, 100, 101
 Including system properties 76
 Including Templates 75
 Incoming Call 171
 Incoming Message Format 172
 Incoming Messages 170
 IncomingCallTrigger 171
 IncomingMessage Log 97
 InetTime Command 66
 Input Ports 144
 Insertion Of Values 144
 int 95
 Int16 95, 146
 Int32 95, 146
 Int8 95, 146
 InternalDialPrefix 42
 Internet Access 50
 Internet Time 86
 Interval 56
 IOs 189
 IP Address 88, 89
 IsdnDataChannelID 46
 ISO-8859-1 9
 Jacks 189
 Job Generator 5, 111
 Job Processing 111
 JobReport Log 97
 Keep Reset 15
 KeepConnected 50, 56
 L instruction 73
 last 35
 LD instruction 117
 LDN instruction 118
 LDS instruction 119
 LE instruction 132
 LEDs 189
 LEI instruction 132
 less equal 132
 less than 129
 Link 196
 LinkState 196
 LocalDialPrefix 42
 LocalLogin 52
 Location 42
 Log Command 61, 98
 LogCounter 195
 Logfile Counter 108
 Logfile Formatting 101
 Logfile Size 100
 Logfiles 35
 Logfiles Database 93
 logical alternative 148
 Logical Instruction 116
 Logical Instructions 117
 Login 20, 185
 Login Log 97
 Logout 20
 LongDialPrefix 42
 LT instruction 129
 LTI instruction 129
 MAC 196
 Magic Number 15
 Mailserver 50
 Mask 88, 89
 Math Operations 134
 MAX instruction 134
 MaxCycleTime 195
 MaxDialAttempts 46
 MAXI instruction 134
 maximum 134
 maxInterval 35, 101
 MaxRepeat 56
 M-Bus 188
 Message Job Template 78
 Message Text 72
 meterbus 95
 MID instruction 140
 MIME Attachment 107
 MIN instruction 133
 MINI instruction 133
 minimum 133
 Minute 159
 Mitsubishi 188
 MJT 78
 Mobile Number 48
 Modbus 188
 mode 97
 Mode 155
 ModemOffHook 195
 Moeller 188
 Month 159

MPP instruction 127
MPS instruction 126
MRD instruction 126
MSK instruction 141
MSN 46
MUL instruction 136
MULI instruction 136
multip 30, 95
Multiplication 136
MySelf 48
NE instruction 131
NEG instruction 119
No1 85
NoDate 35, 101
noDTR 18, 85
Nold 35, 101
NoNames 35, 101
NoSec 35, 101
not equal 131
NOT instruction 118
NoTime 35, 101
Number Format 42
Numerator 152, 155
OA 186
offset 30, 95
OnButton 71
OnError Event 56
OnOK Event 56
OnTCPErrror 50
OnTimeout 56
Operator 193
OR instruction 122
Originating Address 186
ORN instruction 123
Output Ports 145
Overview 5
ownhost 50
Pager Number 48
PAP 21
Parameters 10, 72, 172
Parity 85
Parser 140
Password Protection 20, 52, 185
path 94
Periphery 152, 155
persistant 88
Phone Number 42
PIN 46
PLC 5, 110, 188
PollButton 195
POP3 Filter 181
POP3 Password 50
POP3 Query 180
POP3 Server 50
POP3 Username 50
POP3Query Command 65
POP-before-SMTP 50
Port 92
Power Off Delay 138
Power On Delay 138
Power Supply 189
PowerOffTime 196
PowerOnTime 196
PPP Password 50
PPP Username 50
PPP-Server 93
precision 113
Prefix 42
previous 35
Priority 56
PROCCFG 113
Process Command 62
Process Variables 113, 116
Processing Incoming Messages 170
ProcessVar 112
ProcessVars 113
Profile Priorities 167
Project Structure 198
Projects 41
Properties 30, 33
Quality 193
Range 35
Rate 152, 196
Read Logfiles 35
ReadLog Command 35
Reason 196
Receipt Message 183
Receiving Messages 170
Recipient 78
record 93
Records Database 94
Redial Attempts 46, 56
Redial Delay 46, 56
Reference 73
References 41, 144
Remote Control 109
Remote Firmware Update 201
RemoteLogin 52
RemotePhoneNumber 50
Reply Message 183
Reset 15
Reset Command 65
ResultFile 39
RFC822Date 196
Ring Buffer 39
RingCounter 46
rowend 101
rowsep 101
rowstart 101
RTSCTS 18, 85
Run 41
S instruction 74

S0_Sync Command 66
 SAIA 188
 Scale 30, 95
 ScanWLAN 91
 ScheduleDefinition 161
 Scheduler 158
 Scheduler Condition 159
 Scheduler Database 159
 Scheduler Example 161
 ScheduleTest 162
 SD-Card 39, 69
 Sender 78
 Sender Address 186
 Sender Validation 186
 Sending Logfiles 100, 101, 107
 Sending Values By Message 144
 SendMail Command 55, 56
 Sequencer 164
 SequenceTest 168
 Serial Interfaces 189
 Serial Port 189
 ServerName 87
 Set Command 33, 60
 Set PLC Variable Command 146
 Set Port Command 145
 Set Process Variable Command 146
 SetConfig Command 64
 SetConfig Email 184
 SetSequence 165
 SetTime Command 66
 Short Message Service Center 84
 Siemens 188
 Signal LED 157, 195
 SIM Card 46
 SIM phonebook 193
 simpleType 146
 size 93, 94
 Size Of Logfiles 100
 SMS 79
 SMS Providers 83
 SMS_Login 186
 SMTP 79
 SMTP Server 50
 SNR 196
 So Interface 155
 SSID 89, 196
 ST instruction 128
 StartChecksum 77
 Stop 41
 StopChecksum 77
 Store Value 128
 String 95, 146, 151
 SUB instruction 135
 SUBI instruction 135
 Subject 78
 Subnet Mask 88, 89
 SubnetMask 196
 Subtraction 135
 SWP instruction 127
 System group 71
 System Log 35, 97
 System Properties 30, 33, 192
 tabend 101
 tabstart 101
 Tag 8
 tagend 101
 tagstart 101
 TAP 84
 Templates 72
 Text Line 73
 Text Parser 140
 TextFax 79
 TFTP-Server 93
 thousand delimiter 150
 Time 86, 159
 Time Based Processing 158
 TIME instruction 137
 Time Synchronisation 86
 Time-Based Processing 137
 Time-Bitmask 141
 TimeDiff 87
 TimeFormat 87
 Timeout 92
 TimeScale 155
 TimeServer 87
 TimeStamp 30
 Timezone 46
 Tixibus 188
 TiXML 7
 TiXML Mode 7
 TiXML/IP 92
 Tolerance 152
 TransMode 85
 TransMode Command 68
 TransModeClose Command 68
 Transparent Mode 109
 Transport Type 78
 Triggering Events 112, 170, 171
 TxPower 196
 UCP 84
 Uint16 95, 146
 Uint32 95, 146
 Uint8 95, 146
 URLSend 79
 UseAlias 35, 101
 User Data 46
 User Name 20, 185
 Username 52
 UserTemplates 73
 V.110 52
 value 94
 Value 113

variable format 147
Variables 111, 144, 145
Verbose Modem Answers 11
Version Number 30
ViewProperties 30, 76
Viewset 35, 101
VIPA 188
Wait For Dialtone 42
Webserver 93
Weekday 159
WEP 89
WLAN 89
word 95
WriteFile 69, 79
XML 7, 101
XONXOFF 18, 85
XOR instruction 124
XORN instruction 125

Notes

